

TERMAX LIMITED, VILLAGE PAUDH, POST MAJGAON (VIA PATALGANGA) TALUKA
KHALAPUR, DISTRICT RAIGAD 410206 INDIA
TEL: (02192) 276010/36/37/39/41/42
FAX: (02192) 276040



QUALITY ASSURANCE LABORATORY CERTIFIED REPORT

FORMAT No. : QA/660

REV No. : 000

DATE	24-08-2018					
CLIENT	ENERGOCHEMSERVICE LTD, UKRAINE					
PRODUCT	TULSION T 42 H					
SALES ORDER NO	7TH-2018					
IONIC FORM	H					
TYPE	STRONG ACID CATION EXCHANGE RESIN					
PARAMETER	SPECIFICATION	BATCH NOS				
		456403	456408	456410	456411	
TOTAL EXCHANGE CAPACITY (MEQ/ML)	MIN 1.8	1.90	1.88	1.89	1.90	
MOISTURE CONTENT, %	49 – 55	52.31	50.39	52.38	52.11	
PARTICAL SIZE (0.315 TO 1.25 MM)	0.315 TO 1.25 MM	0.3 TO 1.2 MM				

**Q.A. INCHARGE
THERMAX LIMITED**

HEAD OFFICE : THERMAX LIMITED 97-E ,BHOSARI INDUSTRIAL AREA,PUNE 411026,INDIA.
REGD OFFICE : D - 13 , MIDC INDUSTRIAL AREA, CHINCH WAD , PUNE -411019, INDIA