


INSPECTION REPORT

Test object 145 kV RIP condenser bushing for transformer
Designation FPBRWL-145/2000-4 **Serial No.** 2502893-1
145 kV - 2000 A - 50 Hz

Report No.
104132301-25
Revision 0



Manufacturer Bushing (Beijing) HV Electric CO., Ltd.,
Qiangyun Road, Economic Development Zone, Miyun District, Beijing, China
(location as declared by the manufacturer)

Client Bushing (Beijing) HV Electric CO., Ltd.,
Qiangyun Road, Economic Development Zone, Miyun District, Beijing, China

Date(s) of tests July 15 to October 16, 2025

Inspected by KEMA B.V. ("KEMA Labs"),
Klingelbeekseweg 195, Arnhem, The Netherlands

Test locations Bushing (Beijing) HV Electric CO., Ltd.,
Qiangyun Road, Economic Development Zone, Miyun District, Beijing, China
Shenyang Transformer Research Institute Co., Ltd. (STRI),
No. 18, Hushi-Tai South Street, Shenbei New District, Shenyang, Liaoning, China

Test specification The tests were in accordance with IEC 60137:2017.

Regarding Routine and Type Tests

Summary and conclusion The object has complied with the relevant requirements of the standard.

This report applies only to the individual object tested. KEMA Labs makes no representations or warranties with respect to any device other than the object tested. It is the responsibility of the applicable device manufacturer to ensure that any other devices or units having the same name and descriptions as the test object are identical.

This report comprises 49 pages with another 2 annexed.

TYPE I

Issued by KEMA B.V.


Robert Menger
Manager,
Global Inspection Services

Arnhem, November 26, 2025

