

COMPLIANCE CERTIFICATE

We hereby confirm that the items listed below :


EPJMe-1C-24-F-T3 P1 C1.2 + RJSM 95/240
EPJMe-1C-24-IP-T3-C1.2-P1+RJSM185/400



- Are in compliance with the Standard **CENELEC HD 629.1**
- Have been designed and manufactured in accordance with internal **Prysmian Quality Standards** :
 - **PCQ 004**
Electrical core (before expansion phase) :
100% AC test : 30 min @ 60kV
100% PD measurement @ $2U_0$ max 10pC
 - **COR.SMQ.PAQP.021**
100% visual and dimensional inspection

March 20, 26th

PRYSMIAN Cables & Systems
Thierry Grosjean
Network Component R&D Manager



Prysmian Câbles et Systèmes France

R&D NWC
ZI le plein de Xoulces
88310 Cornimont
France
www.prysmiangroup.com

Siège social
23, avenue Aristide Briand
Paron – BP 712
89108 SENS Cedex
www.prysmiangroup.com

Siège social
23, avenue Aristide Briand
Paron – BP 712
89108 SENS Cedex
www.prysmiangroup.com