

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50334627

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DY-15094968 002

Ausstellungsdatum *Date of Issue*
30.03.2016
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL TECHNOLOGY, S.L.
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Fertigungsstätte *Manufacturing Plant*
01-DY-15094968 001

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60898-1:2003+A1+A11+A12+A13

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Circuit Breaker (Miniature Circuit-breaker)

Type Designation	: HDB3wL (HIMEL)	8
Reference Temperature	: 50°C	
Number of Poles	: 1P/1P+N/2P/ 3P/3P+N/4P	
Rated Operation Voltage	: 240/415VAC (1P) 240VAC (1P+N) 415VAC (2P/3P/3P+N/4P)	
Rated Frequency	: 50/60Hz	
Rated Current	: 1/2/3/4/5/6/8/10/13/16/20/ 25/32/40/50/63A (C/D-Type) 6/8/10/13/16/20/25/32/40/ 50/63A (B-Type)	
Instantaneous Tripping Current	: B/C/D-Type	
Rated Service Short-circuit Capacity	: 4,5kA	
Rated Short-circuit Capacity	: 4,5kA	

Continued on page 0002


8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50334627

Blatt *Page*
0002

Ihr Zeichen *Client Reference*
G.J.Q.

Unser Zeichen *Our Reference*
01-DY-15094968 002

Ausstellungsdatum *Date of Issue*
30.03.2016
(day/mo/yr)

Genehmigungsinhaber *License Holder*
HIMEL TECHNOLOGY, S.L.
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Fertigungsstätte *Manufacturing Plant*
01-DY-15094968 001

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60898-1:2003+A1+A11+A12+A13

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Circuit Breaker (Miniature Circuit-breaker)

Continuation from page 0001


Rated Insulation Voltage : 500V
Rated Impulse Withstand Voltage: 4,0kV
Degree of Protection : IP20
Suitability of Isolation : Yes
Pollution degree : 2

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



HIMEL TECHNOLOGY, S.L.
Guo Jianquan
-
calle Bac de Roda,
No. 52, edificio A
08019 BARCELONA
Spain

Date : 30.03.2016
Our ref. : DY 01
Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Miniature Circuit-breaker
Model Designation : See Certificate
Certificate No. : R 50334627 0001
Report No. : 15094968 002

Dear Guo Jianquan,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body


Jie Zhang

cc: DELIXI ELECTRIC LTD

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

DELIXI ELECTRIC LTD

Mr. Guo Jianquan

-
Delixi High Tech Industrial Park,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P.R. China

Date : 30.03.2016

Our ref. : DY 01

Your ref.: G.J.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Miniature Circuit-breaker

Model Designation : See Certificate

Certificate No. : R 50334627 0001

Report No. : 15094968 002

Dear Mr. Guo Jianquan,

Enclosed please find above certification documents.
Please forward these originals to the certificate holder.

If you contact our office, please quote our reference above.

We thank you for your cooperation.

the certificate holder is: HIMEL TECHNOLOGY, S.L.

With kind regards,

Certification Body


Jie Zhang

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询