

HIGH POWER LABORATORY

TEST REPORT



Central Power Research Institute

(A Govt. Of India Society)

Prof. Sir C. V. Raman Road,
Sadashivanagar S.P.O, P.B. No. 8066,
Bangalore - 560 080

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number : CPRI BLRHPL18T0233 **Date:** 07th January, 2018

Name & Address of the Customer : M/s. CG Power and Industrial Solutions Ltd.,
S6, D-2, MIDC, Waluj, Aurangabad – 431136
Maharashtra, India

Name & Address of the Manufacturer : M/s. CG Power and Industrial Solutions Ltd.,
S6, D-2, MIDC, Waluj, Aurangabad – 431136
Maharashtra, India

Particulars of sample tested : 145 kV Current Transformer
Condition of sample on receipt : New
Type : --

Description of test sample : Refer Sheet No. 2 of 6
Serial number : 181162
Number of samples tested : One
Date(s) of Test(s) : 26th October, 2018
CPRI Sample Code No. : HPL18S0423

Particulars of tests conducted : Short time current test.
Test in accordance with Standard/Specification : Clause no. 7.2.201 of IEC 61869-2:2012
Sampling Plan : Nil
Customer's requirement : Nil
Deviation if any : Nil

Name of the witnessing persons
Customer's representative : Mr. Pradip Shinde
Other than Customer's Representative : None

Test subcontracted with address of the laboratory : Nil

Documents constituting this report (In words)
Number of Sheets : Six
Number of Oscillograms : One
Number of Graphs : Nil
Number of Photos : Three
Number of Test circuit Diagrams : One
Number of Drawings : Six
Number of documents : One




(Arunkumar S)
Test Engineer


(S. Sudhakara Reddy)
Head of Division
Approved by

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT



Test Report No. CPRI BLRHPL18T0233

Date: 07th January, 2018 **CPRI**

DESCRIPTION OF SAMPLE TESTED

(As assigned by the manufacturer)

Sample	: Current Transformer				
Type	: CGL – CI 145				
Designation	: --				
Serial number	: 181162				
Rated voltage	: 145 kV				
Highest system voltage	: 145 kV				
Rated insulation level	: 275 kV rms				
Frequency	: 50 Hz				
No. of cores	: I	II	III	IV	V
Accuracy class	: PX	5P	0.2S	0.2S	PX
Rated output-VA	: --	30	30	30	--
ISF/ALF	: --	20	FS5	FS5	--
Transformation ratio					
Core – I to IV	: 500 – 1000/1 – 1 – 1 – 1 A				
Core – V	: 500 – 1000 – 2000/1 A				
Rated short- time current	: 40 kA rms				
Rated peak withstand current	: 100 kA peak				
Duration of short circuit	: 3.0 seconds.				


(Arunkumar S)
TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT



Test Report No. CPRIBLRHPL18T0233

Date: 07th January, 2018 **CPRI**

LIST OF DRAWINGS AND PHOTOGRAPHS

Drawings of the sample tested:

The manufacturer has guaranteed that the sample submitted for the test has been manufactured in accordance with the following drawings. It is verified that these drawings adequately represent the sample tested.

Sample drawing numbers:

Sl. No.	Drawing No.	Sheet No.	REV
1	411931658 CT1 RS/R1	--	--
2	411931658 CT1 GA/R2	--	--
3	411931658 CT1 SB/R1	--	--
4	411931658 CT1 CI/R1	--	--
5	411931658 CT1 SV/R0	--	--
6	411931658 CT1 LD/R2	--	--

Total drawings (Duly attested): Six

Photographs of the sample tested

Mounting arrangement before test : 445
Condition of the sample after short circuit test : 448
Condition of core, conductor after short circuit test : 497
Total photographs : Three


(Arunkumar S)
TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report No. CPRI BLRHPL18T0233

Date: 07th January, 2018 **CPRI**

SCHEDULE OF TESTS SHORT-TIME CURRENT TESTS

Test conditions

Source : Short-circuit generator & High current transformer
 Number of phases : Two
 Frequency : 50 Hz
 Neutral : Grounded

Test sample

Condition before test : Refer photo No. 445
 Mounting arrangement : Primary winding terminal of CT connected to source and all the secondary winding terminals shorted through copper links of negligible impedance. (Refer Photograph No. 445)

Test details

Test circuit drawing number : CRTL/HPL/1SC22B
 Short-circuit point : Grounded

Oscillogram Number	Short time current			Observation during test
	Peak (kA)	(kA rms)	Duration (seconds)	
CPRI BLRHPL18 T0233S003	101.4	42.6*	2.87	No abnormalities
*Equivalent to 41.7 kA rms for 3.0 seconds.				

ROUTINE TEST RESULTS

- The routine tests before and after short time current test were conducted at SC Lab of CPRI, Bengaluru. Please refer the appended SC Lab report (Reference Number: CPRI BLRSCL18T0597)
- Partial discharge test:**
 Partial discharge tests were conducted after Short time current test in Cables lab of CPRI, Bangalore
 Test connection : High voltage connected to primary, all secondary terminals shorted to grounded body
 Sensitivity of measurement : 5 pC
 Pre-stressed voltage : 198 kV ac for 60 seconds

Measuring Voltage (kV)	Observed discharge magnitude (pC)	Specified discharge magnitude (pC) Maximum
0.9 Um (131) kV	Less than 5 pC	10 pC
0.9*1.2*Um/√3 (90.5) kV	Less than 5 pC	5 pC

Arunkumar S
 (Arunkumar S)

TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT



Test Report No. CPRIBLRHPL18T0233

Date: 07th January, 2018 **CPRI**

- 3) Power Frequency voltage withstand test on primary terminals after short circuit test was conducted at high voltage division. Laboratory temperature (Dry, Wet) and atmospheric pressure 25°C, 20°C and 683 of Hg

Test Voltage kV (rms)	Remarks
248	Withstood for one minute

Physical inspection:

The current transformer was untanked and inspected. Following are the observations. No visible damage. The insulation next to the surface of the conductor did not show any significant deterioration/carbonization.

Remarks: The performance of the tested sample complies with the requirements of clause 7.2.201 of IEC 61869-2:2012 for the test conducted.

(Arunkumar S)

TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT



Test Report No. CPRI BLRHPL18T0233

Date: 07th January, 2018 **CPRI**

NOTE

- a) The Test results relate only to the item(s) tested.
- b) Publication or reproduction of this certificate / report in any form other than by complete set of the whole test certificate / report and in the language written is not permitted without the written consent of CPRI.
- c) Any Corrections / erasure invalidate the test certificate / report.
- d) NABL has Accredited this laboratory as per ISO 17025-2005 standard, vide certificate no.TC-5452 for the tests carried out.
- e) CPRI is a member of STL (Short circuit testing liaison)
- f) Any anomaly / discrepancy in the test certificate / report should be brought to notice of CPRI within 45 days from the date of issue.

Additional Information:

CPRI issues following types of reports/certificates:

Test Certificate / Report:

The test certificate / report contains the record of the values of test parameters as obtained during testing, the physical condition of the sample during / after the test(s) and copy of oscillogram(s).

Test certificate is issued when a sample of a particular type and rating has satisfactorily passed all the specified routine tests or type tests or routine & type tests in compliance with the conditions stipulated

in a published National / International standards.

Test report is issued when partial tests are performed as against the complete test requirement for proving specific ratings as per National / International standards or Customer's specific requirements.


(Arunkumar S)

TEST ENGINEER

**SHORT CIRCUIT LABORATORY
CPRI, BENGALURU**

SC Lab Reference Number

CPRIBLRSC18T0597

Sheet 1 of 8

Name & Address of the Customer

M/s. CG. Power and Industrial Solution Ltd.,
56, D-2, MIDC Waluj, Arunangabad – 431 136,
Maharashtra, India.

Name & Address of the Manufacturer

M/s. CG. Power and Industrial Solution Ltd.,
56, D-2, MIDC Waluj, Arunangabad – 431 136,
Maharashtra, India.

Particulars of sample tested

145 kV Current Transformer

CPRI sample code number (s)

HPL18S0423

Date(s) of Test(s)

23rd, 24th, 31st October, 1st & 2nd November, 2018

Particulars of tests conducted

Routine tests before & after short-time current test
as mentioned in below table

SI.NO	TESTS	SUB-CLAUSE	SHEET NO
1	Tests for ratio error and phase displacement of measuring current transformer	7.3.5.201 of IEC 61869-2	3 of 8 to 4 of 8
2	Determination of the instrument security factor (FS) of measuring current transformer	7.2.6.202 of IEC 61869-2	5 of 8
3	Tests for ratio error and phase displacement of class P protective current transformer	7.3.5.202 of IEC 61869-2	5 of 8
4	Test for composite error of class P protective current transformer	7.3.5.203 of IEC 61869-2	6 of 8
5	Test for rated knee point e.m.f. (E_k) and exciting current at E_k	7.3.203 of IEC 61869-2	6 of 8
6	Determination of the secondary winding resistance (R_{ct})	7.3.201 of IEC 61869-2	7 of 8
7	Test for turns ratio error for class PX protective current transformer	7.3.5.206 of IEC 61869-2	7 of 8
8	Power-frequency voltage withstand tests on secondary terminals	7.3.4 of IEC 61869-1	8 of 8

B. Lings
Test Engineer

SC Lab Reference Number: CPRI BLRSCL18T0597

Sheet 2 of 8

Description of sample tested (ratings as assigned by the customer)

Test sample	Current Transformer				
Type	Outdoor				
Designation	CGL-CI145				
Serial number	181162				
Highest voltage for Equipment (U _m)	145 kV				
Rated insulation level	275 / 650 kVp				
Frequency	50 Hz				
Number of cores	I	II	III	IV	V
Accuracy class	PX	5P	0.2S	0.2S	PX
Instrument security factor (FS)	---	20	FS5	FS5	---
Rated Output (VA)	---	30	30	30	---
Accuracy limit factor	---	20	---	---	---
Maximum rated knee point e.m.f (E _k) - V	500 @ 500/1 A 1000 @ 1000/1 A	---	---	---	500 @ 500/1 A 1000 @ 1000/1 A 2000 @ 2000/1 A
Maximum secondary winding resistance at 75° C (Ω)	2.5 @ 500/1 A 5 @ 1000/1 A	---	---	---	2.5 @ 500/1 A 5 @ 1000/1 A 10 @ 2000/1 A
Maximum exciting current at E _k (mA)	30 @ 500/1 A 15 @ 1000/1 A	---	---	---	60 @ 500/1 A 30 @ 1000/1 A 15 @ 2000/1 A
Rated transformation ratio	500-1000/1-1-1-1 A				500-1000-2000/1 A
Rated extended primary current	---	---	150%	---	

B. Lings
Test Engineer

SC Lab Reference Number: CPRIBLRSL18T0597

1. TESTS FOR RATIO ERROR AND PHASE DISPLACEMENT OF MEASURING CURRENT TRANSFORMER

Current ratio : 500/1
Accuracy class : 0.2S
Primary connection : P1 – P2
Secondary connection : 3S1 – 3S2

Burden (VA) & Power factor	Type of error		Error at percentage of rated current					
			150	120	100	20	5	1
30 & 0.8 lag	% Current error	BT	0.099	0.101	0.102	0.029	-0.059	-0.088
		AT	0.073	0.083	0.088	0.026	-0.046	-0.082
	Phase displacement (min)	BT	0.166	0.130	-0.320	0.806	5.510	10.187
		AT	1.537	1.076	0.657	1.459	5.656	8.599
7.5 & 0.8 lag	% Current error	BT	0.128	0.134	0.134	0.108	0.104	0.084
		AT	0.122	0.127	0.130	0.112	0.110	0.083
	Phase displacement (min)	BT	0.441	0.341	0.213	1.552	3.100	3.202
		AT	1.014	0.821	0.648	1.653	2.609	1.798

Current ratio : 1000/1
Accuracy class : 0.2S
Primary connection : P1 – P2
Secondary connection : 3S1 – 3S3-1

Burden (VA) & Power factor	Type of error		Error at percentage of rated current					
			150	120	100	20	5	1
30 & 0.8 lag	% Current error	BT	0.026	0.032	0.032	-0.015	-0.040	0.011
		AT	0.033	0.042	0.042	-0.002	-0.021	0.023
	Phase displacement (min)	BT	0.768	0.361	0.210	1.459	4.989	8.024
		AT	0.406	0.035	-0.219	0.925	4.111	5.892
7.5 & 0.8 lag	% Current error	BT	0.046	0.059	0.061	0.052	0.063	0.117
		AT	0.058	0.065	0.063	0.055	0.067	0.117
	Phase displacement (min)	BT	0.802	0.440	0.287	1.360	2.270	3.605
		AT	0.383	0.104	0.156	1.112	1.757	2.191

BT: Before short time - current test

AT: After short time - current test

B. Luy
Test Engineer

SC Lab Reference Number: CPRIBLRSC18T0597

TESTS FOR RATIO ERROR AND PHASE DISPLACEMENT OF MEASURING CURRENT TRANSFORMER
(contd.,)

Current ratio : 500/1
Accuracy class : 0.2S
Primary connection : P1 – P2
Secondary connection : 4S1 – 4S2

Burden (VA) & Power factor	Type of error		Error at percentage of rated current					
			150	120	100	20	5	1
30 & 0.8 lag	% Current error	BT	0.105	0.103	0.103	0.045	-0.007	-0.036
		AT	0.082	0.126	0.130	0.119	0.111	0.087
	Phase displacement (min)	BT	0.056	0.262	0.038	1.185	4.686	7.282
		AT	1.264	0.902	0.635	1.218	1.740	1.029
7.5 & 0.8 lag	% Current error	BT	0.128	0.131	0.135	0.118	0.109	0.089
		AT	0.117	0.089	0.091	0.046	0.002	-0.029
	Phase displacement (min)	BT	0.361	0.591	0.276	1.129	2.071	1.843
		AT	1.046	1.001	0.691	1.444	4.573	5.724

Current ratio : 1000/1
Accuracy class : 0.2S
Primary connection : P1 – P2
Secondary connection : 4S1 – 4S3-2

Burden (VA) & Power factor	Type of error		Error at percentage of rated current					
			150	120	100	20	5	1
30 & 0.8 lag	% Current error	BT	-0.013	-0.009	-0.013	-0.057	-0.091	-0.043
		AT	-0.016	-0.011	-0.010	-0.050	-0.074	-0.011
	Phase displacement (min)	BT	-0.064	-0.134	-0.108	0.942	4.192	7.325
		AT	0.213	0.094	-0.140	0.835	3.517	5.436
7.5 & 0.8 lag	% Current error	BT	0.007	0.013	0.012	-0.00	0.007	0.054
		AT	0.007	0.014	0.013	0.005	0.016	0.084
	Phase displacement (min)	BT	0.159	0.084	0.130	1.039	1.993	3.648
		AT	0.291	0.095	0.130	0.890	1.456	0.951

BT: Before short time - current test
AT: After short time - current test

B. Prady
Test Engineer

SC Lab Reference Number: CPRI BLSCL18T0597

2. DETERMINATION OF THE INSTRUMENT SECURITY FACTOR (FS) OF MEASURING CURRENT TRANSFORMER

Core	Ratio	Rated Output (VA)	condition	Secondary winding resistance corrected to 75 °C (Ω)	Secondary limiting EMF (calculated) (V)	Voltage applied at secondary to get 0.5 A (V)	Composite Error (%)
3S1-3S2	500/1	30	BT	2.274	159.2	101.5	> 10
			AT	2.287	159.3	102.4	> 10
3S1-3S3-1	1000/1	30	BT	2.855	161.65	80.3	> 10
			AT	2.908	161.9	81.3	> 10
4S1-4S2	500/1	30	BT	2.317	159.4	110.1	> 10
			AT	2.335	159.5	110.7	> 10
4S1-4S3-2	1000/1	30	BT	2.969	162.12	86.9	> 10
			AT	3.020	162.3	87.6	> 10

3. TESTS FOR RATIO ERROR AND PHASE DISPLACEMENT OF CLASS P PROTECTIVE CURRENT TRANSFORMER

Current ratio : 500/1
 Accuracy class : 5P
 Primary connection : P1 – P2
 Secondary connection : 2S1 – 2S2

Burden (VA) & Power factor	Type of error		Error at percentage of rated current
			100
30 & 0.8 lag	% Current error	BT	-0.237
		AT	-0.233
	Phase displacement (min)	BT	1.155
		AT	1.025

Current ratio : 1000/1
 Accuracy class : 5P
 Primary connection : P1 – P2
 Secondary connection : 2S1 – 2S3

Burden (VA) & Power factor	Type of error		Error at percentage of rated current
			100
30 & 0.8 lag	% Current error	BT	-0.121
		AT	-0.119
	Phase displacement (min)	BT	0.475
		AT	0.406

BT: Before short time - current test
 AT: After short time - current test


 Test Engineer

4. TEST FOR COMPOSITE ERROR OF CLASS P PROTECTIVE CURRENT TRANSFORMER

Core	Accuracy class	Ratio	Condition	Secondary winding resistance corrected to 75 °C (Ω)	Secondary limiting E.M.F applied (V)	Excitation current measured (mA)	% Composite error
2S1 – 2S2	5P	500/1	BT	3.785	662.1	28.83	0.14
			AT	3.810	662.5	28.65	0.14
2S1 – 2S3	5P	1000/1	BT	8.919	750.4	7.96	0.039
			AT	8.978	751.4	7.84	0.039

5. TEST FOR RATED KNEE POINT E.M.F (E_k) AND EXCITING CURRENT AT (E_k)

Core	Exciting current – I_e (measured) at Knee-point e.m.f. – E_k (applied)		
	E_k (V)	I_e (mA)	
		Before STC test	After STC test
1S1-1S2	(1.1 E_k) 550	17.61	17.56
	(E_k) 500	14.97	15.08
	(0.75 E_k) 375	11.46	11.58
	(0.5 E_k) 250	8.75	8.74
	(0.25 E_k) 125	5.35	5.35
	(0.1 E_k) 50	2.60	2.49
1S1-1S3	(1.1 E_k) 1100	8.55	8.49
	(E_k) 1000	7.32	7.28
	(0.75 E_k) 750	5.63	5.60
	(0.5 E_k) 500	4.23	4.22
	(0.25 E_k) 250	2.57	2.57
	(0.1 E_k) 100	1.21	1.20
5S1-5S2	(1.1 E_k) 550	18.09	18.25
	(E_k) 500	15.57	15.69
	(0.75 E_k) 375	12.18	12.19
	(0.5 E_k) 250	9.18	9.27
	(0.25 E_k) 125	5.73	5.65
	(0.1 E_k) 50	2.67	2.71
5S1-5S3	(1.1 E_k) 1100	8.92	8.98
	(E_k) 1000	7.71	7.72
	(0.75 E_k) 750	5.96	5.95
	(0.5 E_k) 500	4.46	4.47
	(0.25 E_k) 250	2.74	2.73
	(0.1 E_k) 100	1.30	1.31
5S1-5S4	(1.1 E_k) 2200	4.31	4.46
	(E_k) 2000	3.76	3.90
	(0.75 E_k) 1500	2.86	2.92
	(0.5 E_k) 1000	2.07	2.05
	(0.25 E_k) 500	1.23	1.19
	(0.1 E_k) 200	0.58	0.56

B. Singh
Test Engineer

SC Lab Reference Number: CPRIBLRSC18T0597

6. DETERMINATION OF SECONDARY WINDING RESISTANCE (R_{ct})

Core	Ratio	Secondary winding resistance (Ω)		Secondary winding resistance corrected to 75° C (Ω)	
		Before STC test (32.5° C)	After STC test (29.8° C)	Before STC test	After STC test
1S1-1S2	500/1	1.7595	1.7554	2.0396	2.0556
1S1-1S3	1000/1	3.574	3.565	4.143	4.175
5S1-5S2	500/1	1.3458	1.3402	1.560	1.569
5S1-5S3	1000/1	3.068	3.053	3.556	3.575
5S1-5S4	2000/1	6.590	6.555	7.639	7.676

7. TEST FOR TURNS RATIO ERROR FOR CLASS PX PROTECTIVE CURRENT TRANSFORMER

Primary	Secondary	Ratio	Accuracy Class	Condition of the sample	% Ratio error
P1-P2	1S1-1S2	500/1	PX	BT	-0.008
				AT	0.002
P1-P2	1S1-1S3	1000/1	PX	BT	0.002
				AT	0.002
P1-P2	5S1-5S2	500/1	PX	BT	0.003
				AT	0.005
P1-P2	5S1-5S3	1000/1	PX	BT	0.003
				AT	0.003
P1-P2	5S1-5S4	2000/1	PX	BT	0.003
				AT	0.005

BT: Before short time - current test

AT: After short time - current test

B. Lings
Test Engineer

SC Lab Reference Number: CPRI BLSCL18T0597

Sheet 8 of 8


8. POWER FREQUENCY VOLTAGE WITHSTAND TESTS ON SECONDARY TERMINALS

Condition of the sample: As after short time current test

Procedure	Applied voltage (kV)	Duration (s)	Observation
Power frequency voltage applied between secondary winding terminals (1S1 – 1S3) connected together and earth. All the other secondary winding terminals (2S1 – 2S3), (3S1 – 3S3-1), (4S1 – 4S3-2), (5S1 – 5S4) & the primary winding terminals (P1 – P2) connected together to earth.	2.7	60	Withstood
Power frequency voltage applied between secondary winding terminals (2S1 – 2S3) connected together and earth. All the other secondary winding terminals (1S1 – 1S3), (3S1 – 3S3-1), (4S1 – 4S3-2), (5S1 – 5S4) & the primary winding terminals (P1 – P2) connected together to earth.	2.7	60	Withstood
Power frequency voltage applied between secondary winding terminals (3S1 – 3S3-1) connected together and earth. All the other secondary winding terminals (1S1 – 1S3), (2S1 – 2S3), (4S1 – 4S3-2), (5S1 – 5S4) & the primary winding terminals (P1 – P2) connected together to earth.	2.7	60	Withstood
Power frequency voltage applied between secondary winding terminals (4S1 – 4S3-2) connected together and earth. All the other secondary winding terminals (1S1 – 1S3), (2S1 – 2S3), (3S1 – 3S3-1), (5S1 – 5S4) & the primary winding terminals (P1 – P2) connected together to earth.	2.7	60	Withstood
Power frequency voltage applied between secondary winding terminals (5S1 – 5S4) connected together and earth. All the other secondary winding terminals (1S1 – 1S3), (2S1 – 2S3), (3S1 – 3S3-1), (4S1 – 4S3-2) & the primary winding terminals (P1 – P2) connected together to earth.	4.5	60	Withstood

Remarks: The sample tested complies with the sub-clauses of the standards referred to.

B. Lujy
Test Engineer



High Power Laboratory
CPRI, Bengaluru


Signature
Test Engineer

CPRI BLRHPL18
T0233S003
26-10-2018

CENTRAL POWER RESEARCH INSTITUTE



Test Report No. CPRI BLRHPL18T0233



Photograph No. 445: Mounting arrangement before short-circuit test


(Arunkumar S)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



Test Report No. CPRI BLR HPL18T0233



Photograph No. 448: Condition of sample after short circuit test

Arunkumar S
(Arunkumar S)
Test Engineer

ULR-TC5452180HPLT0233F

HIGH POWER LABORATORY
P. B.NO. 8066, SADASHIVANAGAR
PROF. SIR.C.V. RAMAN ROAD, BENGALURU-560 080, INDIA
PHONE: + 91- (0) 80-22072511

CENTRAL POWER RESEARCH INSTITUTE



Test Report No. CPRI BLR HPL18T0233




Photograph No. 497: Condition of core, conductor after short circuit test

Arunkumar
(Arunkumar S)
Test Engineer

ULR-TC5452180HPLT0233F

HIGH POWER LABORATORY
P. B.NO. 8066, SADASHIVANAGAR
PROF. SIR.C.V. RAMAN ROAD, BENGALURU-560 080, INDIA
PHONE: + 91- (0) 80-22072511



S 2500 MVA short circuit generator

R_N Generator neutral grounding resistor

MCB Master circuit breaker

MS Make switch

X Variable current limiting reactor

T 300 kA testing transformer

VD Voltage divider

CT1, CT2 & CT3 Measuring current transformer

A Apparatus under test

I₁ I₂ I₃ Currents recorded on primary side of 300 kA transformer

RG Rogowski Coil

Arun Kumar
Test Engineer

LIST OF DRAWINGS

ITEM NO. 1		145 KV CURRENT TRANSFORMER	
SR.NO.	TITLE	DRAWING.NO.	REV.
1	GENERAL ARRANGEMENT DRAWING	411931658 CT1 GA	R2
2	RATING & SCHEMATIC DIAGRAM	411931658 CT1 RS	R1
3	SECONDARY BOX ASSEMBLY	411931658 CT1 SB	R1
4	SECTIONAL VIEW	411931658 CT1 SV	R0
5	COMPOSITE INSULATOR	411931658 CT1 CI	R1

AA : Application for Approval
 RA : Reapplication for Approval
 FD : Final Drawing
 RD : Reference Drawing
 AP : Approved
 AC : Approved with Corrections
 RC : Return for Corrections
 CC : Customer Comments

सीपीआरआई द्वारा इस रेखाचित्र का सत्यापन जहाँ
 कहीं भी संभाव होसिर्फ विमीय जांच तक ही सीमित है।
 THE VERIFICATION OF THIS DRAWING
 BY CPRI IS LIMITED TO DIMENSIONAL
 CHECKS ONLY. WHEREVER POSSIBLE

परीक्षण अभियन्ता / Test Engineer
 उच्च शक्ति प्रयोगशाला / H.P. LAB
 सी. पी. आर. आई / CPRI
 FOR Line and ST bay ngaluru

SURFACE FINISH.....
 MILD STEEL COMPONENTS : SHOT BLAST + HOT DIP GALVANIZED.

CUSTOMER : TATA POWER COMPANY LIMITED, JAMSHEDPUR
 PO. NUMBER : LOI : TPCL/LOI/15-14888, Dated-15.06.2018
 ITEM NO. : 1
 QUANTITY : 11 NO's.


PACKING DIMENSIONS : L-3150 x W-750 x H-1225 mm.
 NET WEIGHT : 450 Kg.
 GROSS WEIGHT : 600Kg.

Document Pertaining to
 Report No... 6.2.2.1.3.4.5.6.7.8.9.10.11.12.13.14.15.16.17.18.19.20.21.22.23


LIST OF DRAWINGS		TYPE : CGC-CI 145	
NO.	REVISION	SIGNATURE	DATE
R6			
R5			
R4			
R3			
R2			
R1			
R0			



TATA POWER AND INDUSTRIAL SOLUTIONS LIMITED, JAMSHEDPUR
 DRG.NO: 411931658 CT1 LD/R2



VIEW FROM 'A'
MOUNTING DETAILS



EARTHING & LIFTING DETAILS

सं. सहायक दस्तावेज
Document Pertaining to
Report No. C.D.R.I.B.G.R.H.P. 4.1.570233

Amithur
गरीक्षम अभियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सी. पी. आर. आई. CPRI
बेंगलुरु / Bengaluru

NOTE : PLEASE REFER INSTRUCTION MANUAL FOR HANDLING & TRANSPORTATION OF CT.

NO.	QTY.	DESCRIPTION	MATERIAL
1	2	PRIMARY TERMINAL SIZE-- #50x125L	ALUMINIUM
2	1	RATING & SCHEMATIC DIAGRAM	DRG.NO.411931656 CT1 RS
3	1	SECONDARY TERMINAL BOX	DRG.NO.411931656 CT1 SB
4	1	COMPOSITE INSULATOR	GREY COLOUR
5	1	BELLOWS	STAINLESS STEEL
6	1	BASE	MILD STEEL
7	1	OIL FILLING / DRAIN VALVE	STEEL PLATED.

सीसीआरआई द्वारा इस रेखाचित्र का सत्यापन जहाँ कहीं भी संभाव होसिर्फ विमीय जांच तक ही सीमित है।
THE VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECKS ONLY. WHEREVER POSSIBLE

EARTHING & LIFTING DETAILS

सं. सहायक दस्तावेज
Document Pertaining to
Report No. C.D.R.I.B.G.R.H.P.4.1.570233

Ananth
गरीक्षम अभियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सी. पी. आर. आई. CPRI
बेंगलुरु / Bengaluru

[illegible]

R6					R4	
R5					R3	
NO		REVISION	SIGNATURE	NO	REVISION	



⑫ DETAILS OF 'C'
OIL FILLING/DRAIN VALVE ASSEMBLY

GENERAL NOTES :-

- 1) NO. OF PRIMARY TURNS = 2 TURNS.
- 2) TYPE OF WINDING = BAR TYPE PRIMARY.
- 3) PRIMARY CONDUCTOR = ALUMINIUM ROD & ALUMINIUM TUBE
- 4) CROSS SECTION OF PRIMARY CONDUCTOR : 1962.5 Sq.mm.

		TOTAL NO. OF SECONDARY TURNS (40)	SECONDARY WINDING	MATERIAL OF SECONDARY WINDING	TAPPED SECONDARY WINDING
CORE I	2000	16x1.15x1/ 2.075,2.627	COPPER	COPPER	YES
CORE II	2000	16x1.15x1/ 2.075,2.627	COPPER	COPPER	YES
CORE III	2000	0.0107,1.167 1.0371,1.2647	COPPER	COPPER	YES
CORE IV	2000	21x2.1x1/ 1.0371,1.5567	COPPER	COPPER	YES
CORE V	4000	16x1.15x1.162/ 1.0371,1.5567	COPPER	COPPER	YES

SECTIONAL VIEW

CG Power and Industrial Solutions Limited, Aurangabad
(Formerly Crompton Greaves Limited)

18 ALL DIMENSIONS ARE IN mm


IF IN DOUBT ASK

सीपीआरआई द्वारा इस रेखाचित्र का सत्यापन जहाँ
कहीं भी संभाव होसक विमोच जांच तक ही सीमित है।
THE VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECK ONLY. WHEREVER POSSIBLE

145 KV CURRENT TRANSFORMER

RATING & SCHEMATIC DIAGRAM
MFG. BY : CG Power and Industrial Solutions Limited, Aurangabad
(Formerly CG Power and Industrial Solutions Limited)
MADE IN INDIA

CUSTOMER : TATA POWER COMPANY LIMITED, JAMSHEDPUR		PO. NUMBER : LOI : TPL/LOI/15-14888, Dated-15.06.2018		RATED CURRENT = 1000 Amp.	
TYPE	CGC - CI 145	INSULATION LEVEL	275KV/1850KVp	FREQUENCY	50 Hz
SHORT TIME CURRENT RATING	40 KA / 3 SEC.	DYNAMIC	100 kAp	RATING FACTOR	1.5
		TOTAL CREEPAGE DISTANCE	4495 mm.	TAN DELTA	
		SERIAL NO.	411931658	YEAR	2018
		SPECIFICATION	IEC:61869-1&2		



CORE NO.	I	II	III	IV	V
RATIO	500/1	1000/1	500/1	1000/1	500/1
PRIMARY TERMINAL	P1-P2	P1-P2	P1-P2	P1-P2	P1-P2
SECONDARY TERMINAL	1S1-1S2	2S1-2S2	3S1-3S2	4S1-4S2	5S1-5S2
BURDEN (VA)	PS	PS	PS	PS	PS
CLASS	PS	PS	PS	PS	PS
IS/IALF	500	1000	500	1000	2000
KPV (MIN) V	30 mA	15 mA	30 mA	15 mA	15 mA
Iexc (max.) AT V _k / 2	≤ 2.5 Ω	≤ 5 Ω	≤ 2.5 Ω	≤ 5 Ω	≤ 10 Ω
Rct @ 75°C Ω	≤ 2.5 Ω	≤ 5 Ω	≤ 2.5 Ω	≤ 5 Ω	≤ 10 Ω

CAUTION : SHORT ALL SEC. TERMINALS WHEN NOT IN USE OR BEFORE DISCONNECTING BURDENS.
CONNECT CX TERMINAL TO EARTH WHEN NOT IN OPERATION.

Ø 4.5 Holes, 4Nos.

MATERIAL & PROCESS : ALUMINIUM ANODISED
THICKNESS : 1.0mm
COLOUR : BACKGROUND NATURAL ALUMINIUM & LETTER: BLACK

परीक्षण अभियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सी. पी. आर. आई. / CPRI
बेंगलुरु / Bengaluru


DRG.NO: 411931658 CT1 RS/R1

IF IN DOUBT ASK


IF IN DOUBT ASK

6	1	GASKET FOR BACK SIDE	NEOPRENE-3Thk.
5	1	GASKET FOR COVER	NEOPRENE-10Thk.
4	1	GASKET FOR GLAND PLATE	NEOPRENE-5Thk.
3	1	GLAND PLATE	160x110x4mm.Thk.
2	19	SEC.TERMINAL BLOCK WITH MARKER	MAKE:ELMEX TYPE-KBT M5-15
1	1	SECONDARY BOX ASSEMBLY	ALUMINIUM (Min.4mm.Thk)
SL.NO.	QTY	ITEM	RM SIZE/SPECIFICATION


सीटीएमआई द्वारा इस रेखाचित्र का सत्यापन जहाँ कहीं भी संभाव होसकिए विमीय जांच तक ही सीमित है ।
THE VERIFICATION OF THIS DRAWING BY CPTI IS LIMITED TO DIMENSIONAL CHECKS ONLY. WHEREVER POSSIBLE




GASKET FOR COVER
ITEM NO.5



BOTTOM VIEW (FROM 'A')




GASKET FOR GLAND PLATE



GASKET FOR BACK SIDE
ITEM NO.6




COVER



NOTES :

- 1) SECONDARY BOX ASSEMBLY TO CONFIRM IP 55 AS PER IEC 60529.
2) Cx:TERMINAL FOR CAPACITANCE & TAN DELTA MESEUREMENT ONLY.
SHOULD BE KEPT EARTHED WHEN NOT IN USE.



ELEVATION

Ankur
परिधिर्ण अपियन्ता / Test Engineer
उच्च शक्ति प्रयोगशाला / H.P. LAB
सी. पी. आर. आई. CPRI
बंगलुरु / Bengaluru

SIDE VIEW

[illegible]

सीसीआईआई द्वारा इस रेखाचित्र का सत्यापन जहाँ कहीं संभाव होसिर्फ विभीय जांच तक ही सीमित है।
 THE VERIFICATION OF THIS DRAWING BY CPRI IS LIMITED TO DIMENSIONAL CHECKS ONLY. WHEREVER POSSIBLE

1500

280

105

FRP TUBE

AL FLANGE

SILICON RUBBER

DETAILS AT 'A'

NOTES:-

1. INSULATOR TO CONFIRM TO IEC:61462 (1998)
2. MAXIMUM MECHANICAL LOAD-BENDING (MML) : 1000 kg.
3. SPECIFIED MECHANICAL LOAD-BENDING (SML) : 2500 kg.
4. SEALING SURFACE : $\nabla\nabla\nabla$ FINISH ON BOTH FLANGES.
5. MINIMUM CREEPAGE DISTANCE : 4495 mm.
6. COLOUR OF INSULATOR SHEDS : RAL 7040
7. MATERIAL OF FLANGES : ALUMINIUM ALLOY.
8. ALTERNATING SHED PROFILE TO MEET REQUIREMENT
9. MAKE : SHEMAR , CHINA

रिपोर्ट क्रम कः.....
 से संबंधित दस्तावेज
 Document Pertaining to
 Report No. CPRI/BZL/H.Rd/1570233

अभियन्ता / Test Engineer
 शक्ति प्रयोगशाला / H.P. LAB
 पी. पी. आर. आई. / CPRI
 बंगलुरु / Bengaluru

NOTES:-

1. INSULATOR TO CONFIRM TO IEC:61482 (1998)
2. MAXIMUM MECHANICAL LOAD-BENDING (MML) : 1000 kg.
3. SPECIFIED MECHANICAL LOAD-BENDING (SML) : 2500 kg.
4. SEALING SURFACE :  FINISH ON BOTH FLANGES.
5. MINIMUM CREEPAGE DISTANCE : 4495 mm.
6. COLOUR OF INSULATOR SHEDS : RAL 7040
7. MATERIAL OF FLANGES : ALUMINIUM ALLOY.
8. ALTERNATING SHED PROFILE TO MEET REQUIREMENT OF IEC 60815
9. MAKE : SHEMAR , CHINA

[illegible]