



VERIFICATION OF COMPLIANCE

This Verification of Compliance is hereby issued to the below named company. The test results of this report relate only to the tested sample identified in this report.

**Technical Standard: EMC DIRECTIVE 2014/30/EU
(EN 62040-2)**

General Information

Applicant: Powercom Co., Ltd.
9F, No. 246, Lien Chen Road, Chung Ho Dist.,
New Taipei City, Taiwan, R.O.C.

Product Description

EUT Description: UPS
Brand Name: PCM
Model Number: RPT-2000AP; RPT-1500AP; RPT-1025AP

Measurement Standard

EN 62040-2: 2006 / AC: 2006 (Category C1 UPS)

CISPR 22: 2008 (Ed 6.0)

EN 61000-3-2: 2014

IEC 61000-4-2: 2008; IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010; IEC 61000-4-4: 2012;

IEC 61000-4-5: 2014; IEC 61000-4-6: 2013; IEC 61000-4-8: 2009; IEC 61000-2-2: 2002

Measurement Facilities

Xindian Lab.: **Compliance Certification Services Inc.**
No.163-1, Jhongsheng Rd., Xindian Dist., New Taipei City, 23151 Taiwan.
Tel: +886-2-22170894 / Fax: +886-2-22171029

This device has been shown to be in compliance with and was tested in accordance with the measurement procedures specified in the Standards & Specifications listed above and as indicated in the measurement report number: T161107D17-E

Sam Hu / Assistant Manager

Date: November 29, 2016

CCSRF

程智科技股份有限公司
Compliance Certification Services Inc.