



Quality Control Certificate

Doc. No : FPH.03.14
Rev. No : 00
Rev. Date : 01.02.2019
Sayfa No : 1 / 1

PRODUCT NAME	TYTAN PU FOAM GUN GRADE 750 ml all season - 10C/+30C
PRODUCT QUANTITY / EXPIRY DATE	1920 cans (exp:03.08.2023) 5280 cans (exp: 04.08.2023)
REPORT DATE	30.09.2021

TECHNICAL PROPERTIES

ANALYSIS	TEST METHOD	UNIT	REF. VALUE	CERT. VALUE
COLOR	TM001		Yellow	Yellow
Tack-free time (23°C %50 Humidity)	TM 1014-2013	[min]	6-15	08:10 / 08:15
Cutting time (23°C %50 Humidity)	TM 1005-2013	[min]	30-60	35:40 / 35:55
Full cure time	RB024	[h.]	24 h.	24 h.
Flammability class	DIN 4102		B3	B3
Extrusion Rate	TM006	[g/min]	4700-5500	5258

CONCLUSION: The above mentioned product has passed the quality control tests and conforms to our high quality product standards.

PRODUCT WARRANTY: The above product(s) are guaranteed against production faults and quality non-conformities, until the expiry date of the products, which is written on top of the cans.

Yunus KESGÜN
Quality Assurance Specialist

QC PASSED

Selena Yapı Malzemeleri Sanayi ve Ticaret Limited Şirketi

Tatlısu Mahallesi Şenol Güneş Bulvarı Mira Tower No:2/A Kat:14 D 68 34774 Ümraniye İSTANBUL - TÜRKİYE

Telefon : + 90 216 466 26 26 – Faks : + 90 216 549 89 00

Mail: info@selenaturk.com – Web: www.selenaturk.com.tr