

Certificate of compliance

Date: 24/07/2024

We certify and declare that the following products meet the specifications and standards listed below. We further certify and declare that the products comply with relevant safety and health standards related to filtration equipment. Any modification to the products listed below will invalidate this declaration.

Country of manufacturing:	The Netherlands, Europe
EPA establishment No.:	96672-NLD-I
Certificates:	NSF on the fibers BRL I40I0 on the module BRL KI4022 on the module KIWA watermark on the module
Certificate check valve:	Conform EN I7I7 KIWA BelgAqua
Quality control:	I00% Dry PDT testing conform ASTM D6908-03
Nominal pore size:	0.02 micron
MWCO:	IIO-I50 kDa
Material filter housing:	PVCU
Material potting:	Epoxy resin

Products:

Art. Nr.	Product FiltaER	KIWA name
IIO7IIO500	FiltaER totaalset UFM IIO-500	
IIO7IIO750	FiltaER totaalset UFM IIO-750	
IIO7IIOI00	FiltaER totaalset UFM IIO-I000	
IIO7I40I00	FiltaER totaalset UFM I40-I000	
IIO70635I0	Ultrafiltratie totaalset UFM 63-5I0, capaciteit 8.3L/min	UFKM 63-5I0
IIO7090750	Ultrafiltratie totaalset UFM 90-750, capaciteit I0L/min	UFK 90-750
IIO7I25750	Ultrafiltratie totaalset UFM I25-750, capaciteit 20L/min	UFK I25-750
IIO7I60I00	Ultrafiltratie totaalset UFM I60-I000 , capaciteit 40L/min	UFK I60-I000
IIO7I60750	Ultrafiltratie totaalset UFM I60-750, capaciteit 30L/min	UFK I60-750

Signature: Casper ten Bokkel

