

Declaration of Incorporation

In accordance with Directive 2006/42/EC on machinery, Annex II 1. B



The manufacturer: Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 - 6
82256 FÜRSTENFELDBRUCK
GERMANY
Tel.: +49 8141 242-0
Fax: +49 8141 242-155

We herewith declare that the following partly completed product

Gerätebezeichnung - Unit name	GACC RX 031.1/2WN/HHA7E.UNNN
Projektnummer - Project number	101236927
Seriennummer - Serial number	504363650/09.01062
Herstellungsjahr - Year of manufacture	2025

complies with the requirements of the following Directives – including any amendments valid at the time of publication of this declaration:

Directive 2006/42/EC on machinery, Annex I, Article 1.1.2, 1.1.5, 1.2.1, 1.2.3, 1.2.4, 1.3.1, 1.3.2, 1.3.3, 1.3.4, 1.3.7, 1.3.8, 1.4.1, 1.4.2, 1.5.1, 1.5.5, 1.5.6, 1.5.7, 1.5.8, 1.5.9, 1.5.15, 1.5.16, 1.6.1, 1.6.2, 1.7.1, 1.7.3, 1.7.4, 4.1.2.1, 4.1.2.3, 4.1.2.5

EMC Directive 2014/30/EU

The following standards have been applied:

EN ISO 12100: 2010	Safety of machinery, general principles for design
EN ISO 13857: 2019	Safety of machinery, safety distances to prevent hazard zones being reached by upper limbs
EN 378: 2016	Refrigerating systems and heat pumps - safety and environmental requirements
EN 60204-1: 2018	Safety of machinery - electrical equipment of machinery (VDE 0113 Part 1)
EN 60034-1: 2010	Rotating electrical machines; rating and performance - general conditions (VDE 0530 Part 1)
EN 14276-2: 2020	Pressure equipment for refrigerating systems and heat pumps - Part 2: Piping

The following further standards have been applied:

EN 13487: 2019	Heat exchangers - forced convection air-cooled refrigerant condensers and dry coolers - sound measurement
----------------	---

The special documents pertaining to the partly completed machinery have been compiled in acc. with Annex VII Part B of the Directive 2006/42/EC on Machinery.

The manufacturer commits to electronically conveying the special documents concerning the partly completed machinery further to a reasoned request from a competent national authority.

This partly completed machinery must not be put into service until the final machinery, into which it is to be incorporated, has been declared in conformity with provisions of the Directive 2006/42/EC on machinery.

Authorized for documentation:

Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 - 6
82256 Fürstenfeldbruck
GERMANY

01.03.2025

Michael Freiherr
Managing Director

Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 – 6
82256 Fürstenfeldbruck
Germany
T +49 8141 242-0
info@guntner.com
guntner.com/de

Sitz: Fürstenfeldbruck
München HRA 88723
USt-IdNr. DE250304912
HU 26964104
RO 35825078
CHE-306.057.342

persönlich haftende
Gesellschafterin:
Güntner Management GmbH
Sitz: Fürstenfeldbruck
München HRB 163595
Geschäftsführer: Michael Freiherr

Commerzbank AG
BLZ 700 800 00
Kto. 697 04 00 00
S.W.I.F.T. DRES DE FF 700
IBAN-Nr.
DE98 7008 0000 0697 0400 00

Deutsche Bank AG
BLZ 700 700 10
Kto. 682 22 33
S.W.I.F.T. DEUT DE MM
IBAN-Nr.
DE44 7007 0010 0682 2233 00



PRESSURE TEST PROTOCOL

The manufacturer: Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 - 6
82256 FÜRSTENFELDBRUCK
GERMANY
Tel.: +49 8141 242-0
Fax: +49 8141 242-155

We herewith declare that the following product:

Projektnummer - Project number	101236927
Gerätebezeichnung - Unit name	GACC RX 031.1/2WN/HHA7E.UNNN
Gerät Seriennummer - Unit serial number	504363650/09.01062
Ventilator/ID/Drehzahl/Stromaufn. - Fan/ID/Speed/Current	VT0603 / 1730 / 1350 min -1 / 0.4 A
Umgebungstemperatur - Ambient air temperature	-30 °C / +50 °C
Herstellungsjahr - Year of manufacture	2025

with the pressure equipment:

Druckgerät Seriennr. - Pressure equipment serial no.	504363650/09.01062	
Volumen - Volume (V)	7.1 l	
Max. zulässiger Druck (PS) Max. permissible pressure (PS)	32 / 0 bar	0 / -1 bar
Zulässige min./max. Temperatur (TS) Permissible min./max. temperature (TS)	-50 °C / +100 °C	-50 °C / +40 °C
* Prüfdruck (PT) / Prüfmedium * Test pressure (PT) / Test medium	45.8 bar / Druckluft - Compressed air	
Prüfdatum - Test date	2025.03.01	
Fluidgruppe / Zustand - Group of fluid / State	2 / gasförmig - gaseous	

* The pressure test was carried out with calibrated pressure gauges and measuring equipment and resulted in no complaints.

at most is category I according to 2014/68/EU and is excluded according to article 1 (2) f) i) from this directive. It is covered by the EC machinery directive 2006/42/EC .

Sibiu, 01.03.2025

This document is generated by computer and is legally binding even without signature.



Projektnummer - Project number	101236927	
Gerätebezeichnung - Unit name	GACC RX 031.1/2WN/HHA7E.UNNN	
Gerät Seriennummer - Unit serial number	504363650/09.01062	
Ventilator/ID/Drehzahl/Stromaufn. - Fan/ID/Speed/Current	VT0603 / 1730 / 1350 min -1 / 0.4 A	
Umgebungstemperatur - Ambient air temperature	-30 °C / +50 °C	
Herstellungsjahr - Year of manufacture	2025	
Druckgerät Seriennr. - Pressure equipment serial no.	504363650/09.01062	
Volumen - Volume (V)	7.1 l	
Max. zulässiger Druck (PS) Max. permissible pressure (PS)	32 / 0 bar	0 / -1 bar
Zulässige min./max. Temperatur (TS) Permissible min./max. temperature (TS)	-50 °C / +100 °C	-50 °C / +40 °C
Prüfdruck (PT)/Prüfmedium - Test pressure(PT)/Test medium	45.8 bar / Druckluft - Compressed air	
Prüfdatum - Test date	2025.03.01	
Fluidgruppe / Zustand - Group of fluid / State	2 / gasförmig - gaseous	



Declaration of Incorporation

In accordance with Directive 2006/42/EC on machinery, Annex II 1. B



The manufacturer: Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 - 6
82256 FÜRSTENFELDBRUCK
GERMANY
Tel.: +49 8141 242-0
Fax: +49 8141 242-155

We herewith declare that the following partly completed product

Gerätebezeichnung - Unit name	GACC RX 031.1/2WN/HHA7E.UNNN
Projektnummer - Project number	101236927
Seriennummer - Serial number	504363651/09.00764
Herstellungsjahr - Year of manufacture	2025

complies with the requirements of the following Directives – including any amendments valid at the time of publication of this declaration:

Directive 2006/42/EC on machinery, Annex I, Article 1.1.2, 1.1.5, 1.2.1, 1.2.3, 1.2.4, 1.3.1, 1.3.2, 1.3.3, 1.3.4, 1.3.7, 1.3.8, 1.4.1, 1.4.2, 1.5.1, 1.5.5, 1.5.6, 1.5.7, 1.5.8, 1.5.9, 1.5.15, 1.5.16, 1.6.1, 1.6.2, 1.7.1, 1.7.3, 1.7.4, 4.1.2.1, 4.1.2.3, 4.1.2.5

EMC Directive 2014/30/EU

The following standards have been applied:

EN ISO 12100: 2010	Safety of machinery, general principles for design
EN ISO 13857: 2019	Safety of machinery, safety distances to prevent hazard zones being reached by upper limbs
EN 378: 2016	Refrigerating systems and heat pumps - safety and environmental requirements
EN 60204-1: 2018	Safety of machinery - electrical equipment of machinery (VDE 0113 Part 1)
EN 60034-1: 2010	Rotating electrical machines; rating and performance - general conditions (VDE 0530 Part 1)
EN 14276-2: 2020	Pressure equipment for refrigerating systems and heat pumps - Part 2: Piping

The following further standards have been applied:

EN 13487: 2019	Heat exchangers - forced convection air-cooled refrigerant condensers and dry coolers - sound measurement
----------------	---

The special documents pertaining to the partly completed machinery have been compiled in acc. with Annex VII Part B of the Directive 2006/42/EC on Machinery.

The manufacturer commits to electronically conveying the special documents concerning the partly completed machinery further to a reasoned request from a competent national authority.

This partly completed machinery must not be put into service until the final machinery, into which it is to be incorporated, has been declared in conformity with provisions of the Directive 2006/42/EC on machinery.

Authorized for documentation:

Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 - 6
82256 Fürstenfeldbruck
GERMANY

28.02.2025

Michael Freiherr
Managing Director

Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 – 6
82256 Fürstenfeldbruck
Germany
T +49 8141 242-0
info@guntner.com
guntner.com/de

Sitz: Fürstenfeldbruck
München HRA 88723
USt-IdNr. DE250304912
HU 26964104
RO 35825078
CHE-306.057.342

persönlich haftende
Gesellschafterin:
Güntner Management GmbH
Sitz: Fürstenfeldbruck
München HRB 163595
Geschäftsführer: Michael Freiherr

Commerzbank AG
BLZ 700 800 00
Kto. 697 04 00 00
S.W.I.F.T. DRES DE FF 700
IBAN-Nr.
DE98 7008 0000 0697 0400 00

Deutsche Bank AG
BLZ 700 700 10
Kto. 682 22 33
S.W.I.F.T. DEUT DE MM
IBAN-Nr.
DE44 7007 0010 0682 2233 00



PRESSURE TEST PROTOCOL

The manufacturer: Güntner GmbH & Co. KG
Hans-Güntner-Straße 2 - 6
82256 FÜRSTENFELDBRUCK
GERMANY
Tel.: +49 8141 242-0
Fax: +49 8141 242-155

We herewith declare that the following product:

Projektnummer - Project number	101236927
Gerätebezeichnung - Unit name	GACC RX 031.1/2WN/HHA7E.UNNN
Gerät Seriennummer - Unit serial number	504363651/09.00764
Ventilator/ID/Drehzahl/Stromaufn. - Fan/ID/Speed/Current	VT0603 / 1730 / 1350 min -1 / 0.4 A
Umgebungstemperatur - Ambient air temperature	-30 °C / +50 °C
Herstellungsjahr - Year of manufacture	2025

with the pressure equipment:

Druckgerät Seriennr. - Pressure equipment serial no.	504363651/09.00764	
Volumen - Volume (V)	7.1 l	
Max. zulässiger Druck (PS) Max. permissible pressure (PS)	32 / 0 bar	0 / -1 bar
Zulässige min./max. Temperatur (TS) Permissible min./max. temperature (TS)	-50 °C / +100 °C	-50 °C / +40 °C
* Prüfdruck (PT) / Prüfmedium * Test pressure (PT) / Test medium	45.8 bar / Druckluft - Compressed air	
Prüfdatum - Test date	2025.02.28	
Fluidgruppe / Zustand - Group of fluid / State	2 / gasförmig - gaseous	

* The pressure test was carried out with calibrated pressure gauges and measuring equipment and resulted in no complaints.

at most is category I according to 2014/68/EU and is excluded according to article 1 (2) f) i) from this directive. It is covered by the EC machinery directive 2006/42/EC .

Sibiu, 28.02.2025

This document is generated by computer and is legally binding even without signature.



Projektnummer - Project number	101236927	
Gerätebezeichnung - Unit name	GACC RX 031.1/2WN/HHA7E.UNNN	
Gerät Seriennummer - Unit serial number	504363651/09.00764	
Ventilator/ID/Drehzahl/Stromaufn. - Fan/ID/Speed/Current	VT0603 / 1730 / 1350 min -1 / 0.4 A	
Umgebungstemperatur - Ambient air temperature	-30 °C / +50 °C	
Herstellungsjahr - Year of manufacture	2025	
Druckgerät Seriennr. - Pressure equipment serial no.	504363651/09.00764	
Volumen - Volume (V)	7.1 l	
Max. zulässiger Druck (PS) Max. permissible pressure (PS)	32 / 0 bar	0 / -1 bar
Zulässige min./max. Temperatur (TS) Permissible min./max. temperature (TS)	-50 °C / +100 °C	-50 °C / +40 °C
Prüfdruck (PT)/Prüfmedium - Test pressure(PT)/Test medium	45.8 bar / Druckluft - Compressed air	
Prüfdatum - Test date	2025.02.28	
Fluidgruppe / Zustand - Group of fluid / State	2 / gasförmig - gaseous	

