



TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



RP-2425-031357

TEST REPORT**ULR NO.: TC538925000001317F****SHEET NO.: 1 OF 4**

NAME & ADDRESS OF CUSTOMER M/s. CG Power and Industrial Solutions Limited S6, Instrument Transformer and Bushings D2 & D1/2, MIDC, Waluj, Aurangabad - 431 136, Maharashtra, India.		REPORT NO.: RP-2425-031357 DATE OF ISSUE: 17.01.2025 CUSTOMER REF. NO.: LETTER DATED : 06.01.2025	
		DATE OF SAMPLE RECEIPT 07.01.2025	DATE OF TESTING 08.01.2025
SAMPLE DESCRIPTION (As provided by customer) 132 kV Inductive Voltage Transformer Rated Voltage : 132 kV H.S.V. : 145 kV Ratio : 132000/√3//110/√3-110/√3-110/√3 V Burden : 200/ 50 / 50 VA Acc. Class : 3P / 3P / 0.5 V.F. : 1.2 Count /1.5 for 30 sec. Insulation Level : 275 kVrms / 650 kVp Frequency : 50 Hz Insulation Class : A		SAMPLE IDENTIFICATION Sr. No. : 234656 Type : VEOT:145/650/50 Year of Mfg. : 2024 Make : M/s. CG Power and Industrial Solutions Limited ERDA Sample Code No.: ERDA-00613165	
TEST DETAIL Transmitted overvoltage test		TEST SPECIFICATION IEC : 61869-1 (2023), IEC : 61869-3 (2011)	
ENCLOSURE: Drg. No.: 1) 413695829 IVT4900 GA/R0 2) 413695829 IVT4900 RS_R0 WITNESSED BY: Mr. Sarang Porandare - M/s. CG Power and Industrial Solutions Limited REMARKS: As per SHEET NO.: 2 OF 4			
CHECKED BY 		APPROVED BY  T. S. Vishwakarma	
Note: 1. This report relates only to the particular sample received for testing in good condition at ERDA, Savli. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. This report shall not be used for any purpose such as PR brochures, propaganda, advertisement and legal proceedings, unless for the granted purpose. 5. Only the tests asked for by the customer have been carried out. 6. Particulars of manufacturer/supplier, given in this report are based on information supplied by the customer, along with the test request/sample. ERDA does not assume any responsibility for the correctness of the information for above mentioned Sample Under Test (SUT). ERDA will not be responsible for any changes in SUT made after the test. This test report is given as per instrument status while testing. 7. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arisen. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA within 10 years of date of issue of report			

TC 3744138



TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org

**ULR NO.: TC538925000001317F****Discipline: Electrical****Group: High Voltage Test Facility****REPORT NO.: RP-2425-031357****SHEET NO.: 2 OF 4****DATE OF ISSUE: 17.01.2025****Transmitted overvoltage test**(As per Cl. No. 7.4.4 of IEC : 61869-3 (2011) and
Cl. No. 7.4.2 of IEC : 61869-1 (2023))**Atmospheric condition**

Dry bulb temperature : 28.0°C

Wet bulb temperature : 24.0°C

Atmospheric pressure : 758.0 mm of Hg

Test parameters: U_1 : A voltage impulse applied between one of the primary terminals and earth. U_2 : Transmitted voltage (Measured at the open secondary terminals) U_{tov} : Overvoltage transmitted to the secondary winding U_{pref} : Peak value of reference voltage = $1.6 \times \frac{\sqrt{2}}{\sqrt{3}} \times U_m = 189.42 \text{ kVp}$ U_m : H.S.V. = 145 kV**Observation table:**

Winding No.	U_1 in kVp (Applied)	Wave shape of U_1 in μs	Winding No.	U_2 in Vp (Measured)	$U_{tov} = U_{pref} \times \frac{U_2}{U_1}$ in kVp
Primary Terminal Winding (A - N)	52.501	1.015/72.965	Winding 1 (1a - 1n)	125.980	0.454
	51.925	0.992/74.339	Winding 2 (2a - 2n)	120.121	0.438
	51.935	0.985/74.312	Winding 3 (3a - 3n)	103.519	0.378

Note: The transmitted overvoltage peak value limits (U_{tov}) : 1.6 kVp**REMARKS:** "Conforms"**CHECKED BY**

TC 3744142



TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : <http://www.erda.org>



ULR NO.: TC538925000001317F

REPORT NO.: RP-2425-031357

SHEET NO.: 3 OF 4

DATE OF ISSUE: 17.01.2025

PHOTOGRAPH OF TEST SAMPLE



[Signature]
CHECKED BY

TC 3744140



TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodra-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org

Web : http://www.erda.org



ULR NO.: TC538925000001317F

REPORT NO.: RP-2425-031357

SHEET NO.: 4 OF 4

DATE OF ISSUE: 17.01.2025

PHOTOGRAPH OF NAME PLATE

132 KV INDUCTIVE VOLTAGE TRANSFORMER
RATING & SCHEMATIC DIAGRAM
MFG. BY : CG Power and Industrial Solutions Limited, D2 MIDC Watuj, Aurangabad
MADE IN INDIA

Customer : CG Power and Industrial Solutions Limited, Aurangabad (MS&TCL)

TYPE: VEDT-145/50/50 S.O.NO.: 413095829 YEAR: 2024
SPEC: IS: 16227-1A/3 RATED FREQ: 50 Hz IVT SR NO: 234656

	A - N	WINDING-I 1a - 1n	WINDING-II 2a - 2n	WINDING-III 3a - 3n
VOLTS	132000 $\Delta/\sqrt{3}$	110 $\sqrt{3}$	110 $\sqrt{3}$	110 $\sqrt{3}$
BURDEN (VA)	-	200	50	50
ACCURACY CLASS	-	3P	3P	0.5
HIGHEST SYSTEM VOLTAGE	145 KV	INSULATION LEVEL: 275 KV/650 kVp		
VOLTAGE FACTOR	1.2 CONT. S-30SEC.	CREEPAGE DISTANCE: 3625 mm		
TOTAL WEIGHT	800 PPM KG	OIL VOLUME: 90 \pm 10% Litre		

PO NO: -

1. PRIMARY TERMINAL (H.V.)
2. CAPACITANCE TAN DELTA LEADOUT FROM BUSHING ACTIVE PART
3. NEUTRAL END OF HV WINDING
4. EARTH SHIELD BETWEEN HV & LV (CONNECTED TO EARTH INSIDE HOUSING.)
5. CORE EARTHING LEAD (CONNECTED TO EARTH INSIDE HOUSING.)
6. SECONDARY LEADOUT.

CAUTION
ENSURE LV TERMINALS ARE NOT SHORTED IN OPERATION.
ENSURE CK AND N ARE CONNECTED TO EARTH BEFORE CHARGING IVT.

TERMINAL BOX

RG



P. Patel

CHECKED BY



***** END OF TEST REPORT *****

TC 3744141



ERDA, MAKARPURA

Test Report No. RP-2425-031357

Date 17.01.2025

Product 132kV Inductive Voltage Transformer

Verified by [Signature]

Verification of this drawing by ERDA is limited to relevant dimensional checks only. Verified dimensions are marked with '*'.

DRG / 16-002



ITEM NO.	QTY	DESCRIPTION	MATERIAL
1	1	PRIMARY TERMINAL - 30x80 (Min.)	COPPER
2	1	TANK	ALUMINIUM CAST
3	1	PORCELAIN INSULATOR	PORCELAIN BROWN COLOUR
4	1	RATING & SCHEMATIC DIAGRAM	ALUMINIUM
5	1	SECONDARY TERMINAL BOX	ALUMINIUM CAST

TECHNICAL SPECIFICATIONS

132 kV INDUCTIVE VOLTAGE TRANSFORMER

SPECIFICATION	UNIT	RATING
HIGHEST SYSTEM VOLTAGE (Ph-Ph)	Kilo Volts	145
HIGHEST SYSTEM VOLTAGE (Ph-E)	Kilo Volts	145/V $\sqrt{3}$
1 MIN. AC WITHSTAND VOLTAGE	Kilo Volts	275
LIGHTNING IMPULSE WITHSTAND VOLTAGE (kV)	Kilo Volts/Peak	550
TOTAL CREEPAGE DISTANCE (MINIMUM)	Millimeter	3625
TOTAL WEIGHT ($\pm 10\%$)	Kilogram	400
OIL VOLUME ($\pm 10\%$)	Litre	90
APPLICABLE STANDARDS		IEC-61869-1 & 3
VOLTAGE FACTOR		1.2 CONTINUOUS / 1.5-30SEC
INSULATION CLASS		A

- 1) PRIMARY WINDING NO OF TURNS : 37120
- 2) CROSS SECTION AREA OF PRIMARY WINDING : 38 SWG (0.01824 Sq.mm)
- 3) SECONDARY WINDING :

NO. OF WINDING	NUMBER OF TURNS	SWG/Sq.mm
WINDING-I	31	(14x2)/6.48
WINDING-II	31	(14x2)/6.48
WINDING-III	31	(14x2)/2.97

4) CORE MATERIAL : CRGO M.4

NOTE : PLEASE REFER INSTRUCTION MANUAL FOR HANDLING & TRANSPORTATION OF IVT.

Dimensions shown are tentative and may change during detailed design/engineering

REVISION	NO.	DATE	SIGNATURE	REVISION	NO.	DATE	SIGNATURE
	R6				R2		
	R5				R1		
	R4						
	R3						
	R2						
	R1						


DRN: [Signature] CHD: [Signature] APPD: [Signature] SDS: [Signature]

SCALE: N.T.S. DATE: 14.12.2023 ALL DIMENSIONS ARE IN MM. DRG-NO: 41365029 MT-8000 DA/702

GENERAL APPROVED BY: [Signature]

132 kV Inductive Voltage Transformer

IF IN DOUBT ASK



4 HOLES OF $\phi 45$ mm

MATERIAL : ALUMINUM METALIC

IVT SR.NOS. 234656

R6			R4							SIGN	NAME	RATING & SIGNATURE BLOCK 132 BY PROJECT NOTICE TRANSMITTED
										DR-4	KSH	
R5											STJ	
										APPD	SDS	
NO	REVISION	SIGN	DATE	NO	REVISION	SIGN	DATE	NO	SCALE	DATE	ALL DIMENSIONS ARE IN mm	



CC Project and Industrial Solutions Limited - Kurnool/Jadcherla
DRC-III--41369-SEEN INT-4900 RS_R0