



S.C TehnoWorld SRL

Loc. Baia, nr. 1616, DN2E km 2
Jud. Suceava, RO-727020

office@tehnworld.ro
www.tehnworld.ro

RC: J33/145/2003
CUI: RO15231305
RO87BACX0000003023781012
UNICREDIT BANK

CERTIFICAT DE CALITATE	
Nr.	Data
Beneficiar	
Adresa	Loc : Jud:
Aviz nr.	AVTW -
Produs	Teava corugata PE
Executat dupa	SR EN 61386-24
Lot	
Cant. Livrata	M
Marcaj	

REZULTATE INCERCARI LOT PRODUS FINIT

Nr. Crt.	Tip de incercare	Norma	UM	Valori prevazute	Valori determinate
1	Aspect	SR EN 61386-24		Suprafete interioare si exterioare: curate, netede, fara crestaturi sau alte defecte	Conform
2	Culoare	-		Perete exterior - Perete interior negru	Conform
3	Diametrul exterior mediu (d _e)	SR EN 61386-24	mm		Conform
4	Diametrul interior mediu (d _i)	SR EN 61386-24	mm	>	Conform
5	Rezistenta la compresiune	SR EN 61386-24	N	>450/750	Conform

CONCLUZII: Lotul testat de teava corugata cu pereti dubli din polietilena de inalta densitate corespunde cerintelor standardului de referinta SR EN 61386-24

SC TEHNO WORLD SRL

Carmen Maria Benea

Sef Laborator

