



EFFECTIS ERA AVRASYA TEST VE BELGELENDİRME A.Ş.
Dilovası OSB 5. Kısım Fırat Caddesi No:18
41455 Dilovası KOCAELİ
www.effectis.com

TEST CERTIFICATE

Certificate Nr: EEA – 1800 – 0045

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratories** on 08.05.2018 in accordance with DIN 4102-12:1998 standard for the product as described below:

Cable System – Power and signal cables fixed on cable trays, cable ladders and wire mesh cable tray “METAKSAN”

FIRE RESISTANCE RESULT	
Cable Tray - APK 140 15 HDG	E 60
Cable Tray – APK 530 20 PG	E 90
Cable Ladder – CKM 140 15 HDG	E 90
Cable Ladder – SKM 530 15 HDG	E 30
Wire Mesh Cable Tray – TOK 620 40 EG	E 90
Cable Tray – APK 530 15 HDG	E 60

Placed on the market by
METAKSAN ELEKTRİK VE İNŞAAT MALZEMELERİ SAN. VE TİC. LTD. ŞTİ.
Ortaköy Org. San. İlter Blv. 160 Ada 24 Parsel No:16 Selimpaşa-Silivri, İstanbul,
Turkey

And Produced In the Factory
METAKSAN ELEKTRİK VE İNŞAAT MALZEMELERİ SAN. VE TİC. LTD. ŞTİ.
Ortaköy Org. San. İlter Blv. 160 Ada 24 Parsel No:16 Selimpaşa-Silivri, İstanbul,
Turkey

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report Nr. **RFTR18064**.

This certificate is initially valid until 06th June 2022 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.

Ali BAYRAKTAR
Laboratory Manager
06.06.2018

