



QUALITY CERTIFICATE			
No.	25339010	Date	04.02.2025

Customer	VOLTA SRL		
Address	Loc: Chisinau Jud: Chişinău		
Invoice no.	FX0000026821 / 04.02.2025		

Product	Corrugated cable protection PE pipe DE 50 450 N/m ELCOR red C50 ML
Normative	EN 61386-24
Batch	22500064
Quantity	5500.00 M
Marking	TEHNO WORLD ELCOR DN/OD 50 SR EN 61386-24 TIP 450 N/mp PROTECTIE LOT

FX0000026821
FX0000026821-04.02.2025

THE FINAL PRODUCT BATCH TESTING RESULTS

No. Crt.	Features	Test method	Unit	Requirements	Results
1	Surface visual control	Visual	Inside and outside pipe surfaces are clean, smooth, without any scratches, deformations or foreign inclusions, without pinholes or other defects		Complied
2	Colour	Visual	Outer wall Red Inner wall - black		Complied
3	Outside diameter (d_e)	SR EN 61386-24	mm	50-51	Complied
4	Inside diameter (d_i)	SR EN 61386-24	mm	>37	Complied
5	Compression force	SR EN 61386-24	N	=450	Complied
The tested corrugated pipe batch meets the requirements of the reference standard EN 61386-24.					

SC TehnoWorld SRL

Carmen Maria Benea
Laboratory Manager

