Laboratory Test report

R-Tech
Rue de Mons 3 – B-4000 Liège – Belgium
Tel.: +32 4 224 71 40 – Fax: +32 4 224 25 90
Member of Schréder Group

FORM L-54 Edition 01 - Revision 03 - Date : 20/05/2020

Electrical safety

General information

Subject: VOLTANA EVO 1 - 16 Oslon Square Giant - Philips 75W - 1200mA - CL I

Asked by: SZÜGYI János Péter

<u>Created on</u>: 12/01/2021 <u>Started on</u>: 27/01/2021 <u>Test number</u>: D210052

Reference norm: IEC/EN 60598-1 Standard

<u>Sample(s)</u>: E210037 <u>Folder</u>: P-F21002

Test conditions

Luminaire: VOLTANA EVO 1

Number of LED: 16

LED: Osram OSLON SQUARE GIANT

Electrical class: Class I EU

<u>Driver</u>: DRIVER_SIGNIFY_FP_75W_500-1500mA_220-240V_DALI_C133_

/ 00-49-491

<u>Number of driver(s)</u>: 1 <u>SPD</u>: VS SPC3/230/10K/i Operator: CLOSSET Frédérick



D210052

1/4

IMG_7897-1200

Conclusion



Success

Conclusion:

Conformity Statement:

Protective conductor current (§ 10.3 of IEC 60598-1): passed

Earth continuity (§ 7.2.3 of IEC 60598-1): passed

Insulation resistance for basic insulation other than SELV (§10.2.1 of IEC 60598-1): passed Electric strength for basic insulation other than SELV (§10.2.2 of IEC 60598-1): passed

Creepage and clearances according IEC 60598-1:2014, AMD1:2017: passed

Validated by : Duplicate to : RACANELLI Frank, SZÜGYI János Péter,

GHYSENS Gilles HORVÁTH Csaba, CSIKÓS Balázs, BEDŐ Péter

LAB: 15/03/2021

Test(s)

Name	Description	Result
Cll	Protective conductor current (§ 10.3 of IEC 60598-1)	Success
	Earth continuity (§ 7.2.3 of IEC 60598-1)	
	Insulation resistance for basic insulation other than SELV (§10.2.1 of IEC 60598-1)	
	Electric strength for basic insulation other than SELV (§10.2.2 of IEC 60598-1)	
Creepage and clearances	Evaluation of the creepage and clearances according IEC 60598-1:2014, AMD1:2017.	Success

<u>Cl I</u>

Result(s)

ı										
Testname	Test time	Test statistic	Min	Reading	Max	Test Number	Ю	NIO	error	Result
Data input				d210052		1	1	0	None	Passed
Leakage current	20.0s	239.30 V	0.000 mA	151.72 μΑ	3.500 mA	1	1	0	None	Passed
Protective earth	60.0 s	10.0 A		55 mΩ	500 mΩ	1	1	0	None	Passed
Insulation	60.0 s	500.0 V	4.0 ΜΩ	400 ΜΩ		1	1	0	None	Passed
High voltage AC	60.0 s	1.50 kV	0.0 mA	1.0 mA	100.0 mA	1	1	0	None	Passed
Insulation	60.0 s	500.0 V	4.0 MΩ	400 ΜΩ		1	1	0	None	Passed
	Data input Leakage current Protective earth Insulation High voltage AC	Testname Test time Data input Leakage current 20.0s Protective earth 60.0 s Insulation 60.0 s High voltage AC 60.0 s	Testname Test time Test statistic Data input Leakage current 20.0s 239.30 V Protective earth 60.0 s 10.0 A Insulation 60.0 s 500.0 V High voltage AC 60.0 s 1.50 kV	Testname Test time Test statistic Min Data input Leakage current 20.0s 239.30 V 0.000 mA Protective earth 60.0 s 10.0 A Insulation 60.0 s 500.0 V 4.0 MΩ High voltage AC 60.0 s 1.50 kV 0.0 mA	Testname Test time Test statistic Min Reading Data input d210052 Leakage current 20.0s 239.30 V 0.000 mA 151.72 μA Protective earth 60.0 s 10.0 A 55 mΩ Insulation 60.0 s 500.0 V 4.0 MΩ 400 MΩ High voltage AC 60.0 s 1.50 kV 0.0 mA 1.0 mA	Testname Test time Test statistic Min Reading Max Data input d210052 Leakage current 20.0s 239.30 V 0.000 mA 151.72 μA 3.500 mA Protective earth 60.0 s 10.0 A 55 mΩ 500 mΩ Insulation 60.0 s 500.0 V 4.0 MΩ 400 MΩ High voltage AC 60.0 s 1.50 kV 0.0 mA 1.0 mA 100.0 mA	Testname Test time Test statistic Min Reading Max Test Number d210052 1 Leakage current 20.0s 239.30 V 0.000 mA 151.72 μA 3.500 mA 1 Protective earth 60.0 s 10.0 A 55 mΩ 500 mΩ 1 Insulation 60.0 s 500.0 V 4.0 MΩ 400 MΩ 1 High voltage AC 60.0 s 1.50 kV 0.0 mA 1.0 mA 100.0 mA 1	Testname Test time Test statistic Min Reading Max Test Number IO Data input	Testname Test time Test statistic Min Reading Max Test Number IO NIO Data input d210052 1 1 1 0 Leakage current 20.0s 239.30 V 0.000 mA 151.72 μA 3.500 mA 1 1 0 Protective earth 60.0 s 10.0 A 55 mΩ 500 mΩ 1 1 0 Insulation 60.0 s 500.0 V 4.0 MΩ 400 MΩ 1 1 0 High voltage AC 60.0 s 1.50 kV 0.0 mA 1.0 mA 100.0 mA 1 1 0	Testname Test time Test statistic Min Reading Max Test Number IO NIO error Data input d210052 1 1 1 0 None Leakage current 20.0s 239.30 V 0.000 mA 151.72 μA 3.500 mA 1 1 0 None Protective earth 60.0 s 10.0 A 55 mΩ 500 mΩ 1 1 0 None Insulation 60.0 s 500.0 V 4.0 MΩ 400 MΩ 1 1 0 None High voltage AC 60.0 s 1.50 kV 0.0 mA 1.0 mA 100.0 mA 1 1 0 None

Annex(es)



tested

D210052 2/4

Creepage and clearances

Result(s)

TABLES: Creepage distances and clearances (mm)							
BMS weathing valence (V) and averaging 250V		Criteria	Measurement				
RMS working voltage (V) not exceeding 250V	ClI	Cl II	ClI	Cl II			
Live parts of different polarity	≥ 1,5	≥ 1,5	≥ 1,5				
the code and constitute make and	. 4.5	≥ 5 (creepage)	>15				
Live parts and accessible metal parts	≥ 1,5	≥ 3 (clearances)	≥ 1,5				
Live parts with single insulation and accessible metal parts	≥ 0	≥ 1,5	≥ 0				

Annex(es)





creep02 creep03



creep01

D210052 3/4

Test room temperature (°C):

25

Measurement equipment:

ETL ATS400 (E133) with connecting box

Thermometer (A039/4)

Quantities measured:

Earth continuity test:

Resistance of the earth connection between accessible metal parts and the earth terminal according PT-S-18.

Insulation resistance test:

Resistance of the insulating materials for use in a luminaire according PT-S-19.

Dielectric strength test:

Dielectric strength of materials for use in a luminaire according PT-S-20.

<u>Uncertainties</u> :

Statement of uncertainties (K=2, 95% of confidence level):

Temperature: 0,6 K

<u>Earth continuity test</u>:

Current (10A) : 0.47A

Resistance (500m Ω): 9.87m Ω

Insulation resistance test: Resistance (1M Ω): 0.05M Ω Resistance (2M Ω): 0.16M Ω Resistance (4M Ω): 0.30M Ω Voltage (0.5kV): 0.01kV

<u>Dielectric strength test</u>: Voltage (1,5kV): 0.05kV Voltage (3kV): 0.07kV

Leakage current (100mA): 1.70mA

Decision rules:

Pass/fail criteria according IEC 60598-1:

Earth continuity test:

By resistance measurement:

Resistance of the earth connection between all accessible metal parts of the DUT and the earth terminal below or equal to

0.5Ω : Pass Otherwise : Fail

Insulation resistance test:

By resistance measurement:

Resistance of the insulating materials in line with the requirements of table 10.1 of IEC 60598-1: Pass

Otherwise: Fail

Dielectric strength test:

By current measurement and visual inspection:

No flashover, breakdown, nor tripping of the 100mA relay when applying the requirements of table 10.2 of IEC 60598-1:

Pass

Otherwise : Fail

End of test report :

D210052 4/4