

# ATTESTATION OF CONFORMITY

Issued to: Renac Power Technology Co.,Ltd  
Building 6,No.2,West Jinzhi Road,High-Tech District,Suzhou City,Jiangsu  
Province,China

For the product: Grid tied PV inverter

Trade name: **RENAC**

Type/Model: R3-10K-G5, R3-15K-G5, R3-17K-G5, R3-20K-G5, R3-25K-G5, R3-25K-G5-P

Ratings: Output: 380/400 ( $\pm 20\%$ ) Vac, 50/60 Hz  
Input: 150-1100 Vdc

Manufactured by: Renac Power Technology Co.,Ltd  
Building 6,No.2,West Jinzhi Road,High-Tech District,Suzhou City,Jiangsu  
Province,China

Requirements: EN 61000-6-1:2007  
EN 61000-6-2:2005  
EN 61000-6-3:2007+A1:2011+AC:2012  
EN 61000-6-4:2007+A1:2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 2140809R-PV-CE-P01V01.

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic Compatibility Directive 2014/30/EU.


The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 23 July 2021

Number: 3181243.134AOC

DEKRA Testing and Certification (Shanghai) Ltd.

A handwritten signature in black ink, appearing to read "Kreny Lin", is placed over the name of the Certification Manager.

Kreny Lin  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

