

СИП-2 3x16+1x25 ДСТУ 4743:2007, ТУ У 27.3-00214534-066:2013

Self-supporting wires with light-stabilized cross-linked polyethylene insulation, with neutral carrier insulated conductor

Used for laying:

- *trunks of aerial electric power lines and line branches for the rated voltage of 0.6/1 kV*
- *in air, types II and III according to ГОСТ 15150-69, including on sea coasts, salt lakes, in industrial areas and areas of saline sands*

It is possible to manufacture the wire with longitudinal core sealing by water-blocking materials

TECHNICAL SPECIFICATIONS:


Rated voltage	kV	0.6 / 1
Number and rated area of phase conductors	mm ²	3 x 16
Carrier neutral conductor rated area	mm ²	25
Phase insulation thickness	mm	1.3
Current ratings *		
• <i>Continuous</i>	A	100
• <i>at short circuit (not more than 1 s)</i>	kA	1.5
Maximum permissible conductor temperature		
• <i>Continuous</i>	°C	+90
• <i>at short circuit (not more than 5 s)</i>	°C	+250
Operating temperature range	°C	-60 ... +50
Permissible temperature of laying (installation), no less than	°C	-20
Minimum bending radius by laying	mm	232
Rated outer diameter of the cable (for reference) **	mm	23.2
Weight (approximate)	kg/km	300
Rated factory cable length and gross weight of the delivery on the drums	m, t	# 16a: 1760 • 0.8 # 18: 2010 • 1.1 # 20: 3210 • 1.6

Notes:

When ordering it is necessary to agree the factory length of the product with the manufacturer

* Long permissible current loads are calculated for the following conditions: ambient temperature plus 25 °C, wind speed 0.6 m/s, the intensity of solar radiation 1000 W/m²

** The external diameter may differ from the rated up to ± 10 %



СИП-2 3x16+1x25 ДСТУ 4743:2007, ТУ У 27.3-00214534-066:2013

Self-supporting wires with light-stabilized cross-linked polyethylene insulation, with neutral carrier insulated conductor

CONSTRUCTION:

1. Aluminium multiwire compacted conductor
2. Multiwire aluminium-alloy compacted supporting conductor
3. Light-stabilized cross-linked polyethylene insulation

Note: wire lay-up is not illustrated

