



VILNIUS, 11/01/2021

## DECLARATION OF CONFORMITY NO.: B11/01/21-1

1. Producer: **BLUCAST JSC, Zirmunu str. 66, LT09131 VILNIUS, Lithuania**
2. Product name:  
**Gate valves 115 PN10/16 (F4, F5, BS) DN40 – DN600**
3. Destination and product range to apply:  
**Ductile cast iron fittings are designed for installation in drinking, sewage water pipe lines, at the temperature of 70°C and the pressure up to 16 bar.**
4. Documents of reference:  
**HYGIENIC CERTIFICATE – BK/W/0545/01-2018**  
**WRAS CERTIFICATE– No.1606371**  
**ACS CERTIFICATE – No.20ACC LY586**  
**CHEMICAL TESTING DIVISION OF NATIONAL PUBLIC HEALTH SURVEILLANCE LABORATORY – Ch3529(Ch 3529)**
5. Technical characteristics:  
**Range of diameters DN: 40 – 600**  
**Flange end connections EN1092-2, ISO2531**  
**Pressure class: PN16**  
**Stem: stainless steel**  
**Drilling of flanges: PN10/16, starting from DN200 – PN10 or PN16**  
**Body material- ductile iron EN-GJS-500-7**  
**Wedge – ductile iron GGG-50, EPDM coating**  
**Coating- epoxy powder coating min. 250ym, RAL5015**  
**PN-EN1074-1; PN-EN1074-2;**

I declare with full responsibility that the products mentioned in point 2 are consistent with the documents of reference mentioned in point 4.

Sincerely,  
General Manager  
Tomas Čepaitis