

Laboratory Service PHYSICAL TEST REPORT



R-Tech
Rue de Mons 3 – B-4000 Liège – Belgium
Tel.: +32 4 224 71 40 – Fax: +32 4 224 25 90
Member of Schröder Group

Subject: VOLTANA 0 – 8 led's – Flat glass protector

Sample n°: P-E16377, P-E16394

Test purpose: Tightness test IP66 following IEC/EN 60598-1 Standard

Remarks:

Test request n°: P-D16575

Folder n°: P-F16041

TEST CONDITIONS:

Operator: BOMBIL Patrick

VOLTANA-0 8 led's with flat glass protector

Pre-conditioning: endurance test

Test	Result
<u>IP6X</u> : -Luminaire switched ON until stable T° -Talcum in suspension (blowing ON) -After 1', luminaire OFF -Talcum for 3 hours	OK
<u>IPX6</u> : - Luminaire switched ON until stable T° - Luminaire switched OFF and immediately sprayed with water jet - Hose Φ 12,5 mm - Water pressure: 1 kg/cm ² - Spraying distance: 3 m - Duration of test: 3 minutes	OK

CONCLUSIONS:



VOLTANA-0 8 led's with flat glass protector complies with IP66 test following IEC/EN 60598-1 Standard.

Duplicate to: Mr M. Thijs
LAB 21/11/2016
L. Maghe

//P-16CR575