



केन्द्रीय विद्युत अनुसंधान संस्थान
(भारत सरकार की सोसाइटी, विद्युत मंत्रालय)
यू एच वी अनुसंधान प्रयोगशाला
वरंगल हाईवे, मेडिपल्ली पोस्ट, हैदराबाद - ५०००९८, भारत
CENTRAL POWER RESEARCH INSTITUTE

(A Govt of India Society, Ministry of Power)

UHV Research Laboratory

Warangal Highway, Medipally P.O., Hyderabad - 500098, INDIA

वेब साइट Website: [http:// www.cpri.res.in](http://www.cpri.res.in), ई - मेल E-mail: uhvrl@cpri.in

दूरभाष / Telephone: +91 80 - 22072051 / 2052



CPRI

पत्र सं / L. No: Pollution test
सेवा मे, / To.

दिनांक: 17. 5. 2024

एम/ एस. सीजी पावर एंड इंडस्ट्रियल सॉल्यूशंस
लिमिटेड,
डी-2, एमआईडीसी, वालुज, औरंगाबाद-431136,
महाराष्ट्र राज्य, भारत

M/s. CG Power and Industrial Solutions
Limited,
D-2, MIDC, Waluj, Aurangabad-431136,
Maharashtra State, India

Kind Attn:

श्री गजानन खड़के

Mr. Gajanan Khadke

विषय / Sub: - 132 केवी प्रेरक वोल्टेज ट्रांसफार्मर - टेस्ट रिपोर्ट्स

Test reports of 132 kV Inductive Voltage Transformer - Reg

सम्बन्धित / Ref: - शून्य / Nil

महोदय / Sir,

उपरोक्त विषय पर पत्र / परिक्षण रिपोर्ट सं CPRIHYDUHV24T0115 &
CPRIHYDUHVMISC24T0079, दिनांक: 1 April 2024 इसके साथ संलग्न है।

We are enclosing herewith letter / Test report No. CPRIHYDUHV24T0115 &
CPRIHYDUHVMISC24T0079, dated: 1 April 2024 on the subject mentioned above.

संलग्न उपरोक्त

Encl: As above.

भवदीय,
Yours faithfully,

संयुक्त निदेशक

Joint Director

संयुक्त निदेशक JOINT DIRECTOR
केन्द्रीय विद्युत अनुसंधान संस्थान
CENTRAL POWER RESEARCH INSTITUTE
यू एच वी आर एल / UHVRL
हैदराबाद / HYDERABAD - 500 098

CPRI

TEST REPORT



Central Power Research Institute
(A Govt. of India Society)
Medipally P.O., Warangal Road,
Hyderabad – 500 098 (INDIA)

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number	:	CPRIHYDUHV24T0115	Date: 01 April 2024
Name and Address of the Customer	:	M/s. CG Power and Industrial Solutions Limited, D-2, MIDC, Waluj, Aurangabad-431136, Maharashtra State, India	
Name and Address of the Manufacturer	:	M/s. CG Power and Industrial Solutions Limited, D-2, MIDC, Waluj, Aurangabad-431136, Maharashtra State, India	
Particulars of sample tested	:	132 kV Inductive Voltage Transformer	
Type	:	VEOT:145/650/50	
Description of test sample	:	132 kV Inductive Voltage Transformer	
Serial Number	:	234656	
Number of samples tested	:	One	
Date(s) of test(s)	:	19 March 2024 to 23 March 2024	
CPRI Sample Code number(s)	:	UHV24S0073	
Particulars of test conducted	:	Refer sheet 3 of 12	
Test in accordance with	:		
Standard/ Specification	:	IEC 61869-1: 2007 and IEC 61869-3: 2011	
Sampling plan	:	Not applicable	
Customer's requirement	:	1. Temperature rise test shall be performed at 1.2 U_{pr} 2. During temperature rise test the secondary winding terminals 1a-1n, 2a-2n and 3a-3n shall be loaded with unity power factor burden equivalent to 200VA, 50VA & 50VA respectively. 3. Temperature rise at bellow top, top and bottom flange, middle of insulator housing and two sides of bottom tank shall be measured and recorded and during temperature rise test. 4. Test voltages for impulse withstand voltage test Indicated by the customer.	
Deviations, if any	:	Nil	
Name of the witnessing persons	:	Mr. Gajanan Khadke	
Customer representatives	:		
Other than customer's representatives	:	Nil	
Test subcontracted with address of the laboratory	:	None	
Documents constituting this report (in words)			
Number of Sheets(s)	:	Twelve	
Number of Oscillogram(s)	:	Thirty four	
Number of Graph(s)	:	Nil	
Number of Photograph(s)	:	Nil	
Number of Test circuit diagram(s)	:	Five	
Number of Drawing(s)	:	Two	


(Dr. P. Rajamani)
Test Engineer




(K. Devender Rao)
Joint Director

Reviewed and Authorized by

ULR-TC6198240UHV20115F
Discipline: Electrical testing
Group: Inductors and
Transformers

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

Sheet 1 of 12

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number: CPRIHYDUHV24T0115

Dated: 01 April 2024

DESCRIPTION OF SAMPLE TESTED

(As assigned by the manufacturer)

145 kV Inductive Voltage Transformer

Rated primary voltage (U_{pr}) : 132 / $\sqrt{3}$ kV_{rms}
Highest system voltage (HSV) : 145 kV_{rms}
Frequency : 50 Hz
Insulation Level : 275 kV_{rms} / 650 kV_p
Voltage factor : 1.2 continuous and 1.5 for 30 seconds

Rated secondary voltage (V)	Terminal marking	Burden (VA)	Accuracy class
110 / $\sqrt{3}$	1a – 1n	200	3P
110 / $\sqrt{3}$	2a – 2n	50	3P
110 / $\sqrt{3}$	3a – 3n	50	0.5


(Dr. P. Rajamani)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRIHYDUHV24T0115

Date: 01 April 2024

SUMMARY OF TEST CONDUCTED

1. Tests conducted : Type and special tests
2. Rating for which tested : 132 kV_{rms}
3. Schedule of test results

Tests conducted	Clause Number and Standard	Sheet Number
Temperature rise test	7.2.2 of IEC 61869-3:2011 and customer request	4 & 5 of 12
Impulse voltage withstand test on primary terminal	7.2.3 of IEC 61869-3:2011 and customer request	6 of 12
Electro Magnetic Compatibility (EMC) tests	7.2.5 of IEC: 61869-3:2011	7 of 12
Test for Accuracy	7.2.6 of IEC: 61869-3:2011	8 & 9 of 12
Chopped impulse voltage withstand test on primary terminal	7.4.1 of IEC 61869-3:2011 and customer request	10 of 12
Capacitance and dielectric dissipation factor measurement at power frequency after dielectric tests	7.4.3 of IEC 61869-3:2011	11 of 12

4. Oscillogram Numbers : Refer Sheets 6 & 10 of 12
5. Graph Numbers : Nil
6. Photograph Numbers : Nil
7. Test Circuit Diagram Numbers : CPRIHYDUHV24T0115TCD01,
CPRIHYDUHV24T0115TCD02,
CPRIHYDUHV24T0115TCD03,
CPRIHYDUHV24T0115TCD04 and
CPRIHYDUHV24T0115TCD05

Drawing Numbers

The manufacturer has guaranteed that the sample submitted for the test(s) has been manufactured in accordance with the following drawings:

Sl. No.	Drawing Number	Sheet Number	Revision Number
1	413695829 IVT4900 GA/R0	---	---
2	413695829 IVT4900 RS_R0	---	---

It is verified that these drawings adequately represent the sample tested. Verification of these drawings by CPRI is limited to dimensional check only wherever possible.


(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical testing
Group: Inductors and
Transformers

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

Sheet 3 of 12

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Test: Temperature rise test (7.2.2 of IEC 61869-3:2011 and customer request)

Test condition : Under dry condition
Test frequency : 50 Hz

Ambient conditions :
Dry bulb temperature : 29°C
Wet bulb temperature : 24°C
Atmospheric pressure : 94.79 kPa

Test procedure: The High voltage AC source connected to primary terminal of IVT. The secondary terminals 1a – 1n, 2a – 2n and 3a – 3n, are loaded with unity power factor burden equivalent to 200 VA, 50 VA & 50 VA respectively.

Resistance of secondary windings measured before start of the test at ambient temperature. The IVT excited to 120% of rated primary voltage (i.e., $1.2 \times 132 \text{ kV} / \sqrt{3} = 91.5 \text{ kV}_{\text{rms}}$). The temperature at various points on IVT as specified by the customer, viz. top bellow, top flange, middle of the porcelain insulator, bottom flange and two sides of bottom tank are recorded by using thermocouple. After reaching steady state, i.e., when temperature rise of 1°C per hour is reached. Then, the voltage increased to 150% of the rated voltage (i.e. $1.5 \times 132 \text{ kV} / \sqrt{3} = 114.3 \text{ kV}_{\text{rms}}$) and maintained for 30 seconds. The temperature of secondary windings also calculated by resistance method. All temperature measurements were repeated.

Time (Hr)	Ambient Temperature (°C)	Temperature rise of IVT (°C)					
		Top bellow	Top flange	Middle of insulator	Bottom flange	Tank side-1	Tank side-2
		T1	T2	T3	T4	T5	T6
11:00	28.7	28.9	28.7	28.8	28.9	28.7	28.7
12:00	29.0	29.8	29.6	29.8	29.6	29.8	29.7
13:00	29.2	31.0	31.2	31.0	31.3	31.2	31.2
14:00	29.3	32.2	32.6	32.5	32.8	32.5	32.5
15:00	29.8	33.4	33.6	33.5	33.1	33.6	33.6
16:00	30.0	34.6	34.6	34.6	34.6	34.6	34.2
17:00	30.1	35.4	34.8	34.9	35.4	35.1	34.8
18:00	30.2	35.5	35.0	35.1	36.2	35.4	35.6
After 30 s at 150% of rated voltage							
18:05	30.3	35.6	35.1	35.2	36.8	36.9	36.1
Rise in Temperature Observed		5.3	4.8	4.9	6.5	6.6	5.8

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical testing
Group: Inductors and Transformers

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

Sheet 4 of 12

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number : CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Measured resistance of secondary windings:

Sl. No	Winding under test	Before start of the test corrected to 75°C (mΩ)	After steady state at 120% of rated voltage corrected to 75°C (mΩ)	After 150% of rated voltage for 30 s corrected to 75°C (mΩ)
1	1a – 1n	69.309	71.448	71.532
2	2a – 2n	70.985	72.613	72.676
3	3a – 3n	54.350	56.008	56.455

Temperature rises of secondary windings by resistance method:

S. No	Winding under test	After steady state at 120% of rated voltage (°C)	After 150% of rated voltage for 30 s (°C)
1	1a – 1n	6.621	6.841
2	2a – 2n	4.637	4.773
3	3a – 3n	6.426	8.487

Test Result: Temperature rise on IVT by thermocouple method and by resistance method are within the specified limits for insulation class A.


(Dr. P. Rajamani)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Test: Lightning impulse voltage withstand test on primary terminal
(As per cl. 7.2.3 of IEC 61869-3:2011 and customer request)

Test condition : Under dry condition

Ambient conditions:

Dry bulb temperature	:	30 °C
Wet bulb temperature	:	25 °C
Atmospheric pressure	:	95.59 kPa

Specified Basic Impulse Level (BIL)

by customer : $\pm 650 \text{ kV}_{\text{peak}}$

The specified test voltage was applied under the ambient conditions mentioned above.

Test arrangement		Test voltage	Result	Ref. Oscillogram nos.	Remarks
Voltage applied to	Earthed	kV, peak	No. of impulses applied / No of Disruptive discharges observed		
Primary terminal of IVT	Terminal 'N' connected to earth along with base tank	-446.8 (RFW)	01 / 0	01	Withstood
		-050 (FW)	15 / 0	02, 05 to 18	Withstood
		+451.4 (RFW)	01 / 0	19	Withstood
		+650 (FW)	15 / 0	20 to 34	Withstood

Note: Secondary winding terminals 1n, 2n and 3n were shorted and connected to earth through shunt

RFW: Reduced Full Wave (50% to 75% of BIL)
FW: Full Wave (100% of BIL)


 (Dr. P. Rajamani)
 Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Test: Electromagnetic Compatibility (EMC) test (As per cl. 7.2.5.1 of IEC: 61869-3:2011)

Test condition : Under dry condition

Ambient conditions:

Dry bulb temperature : 29 °C
Wet bulb temperature : 24 °C
Atmospheric pressure : 94.79 kPa

Applicable additional technical specification : CISPR 18 – 2: 2017

Detector : Quasi Peak

Measuring frequency : 1 MHz

Permissible RIV Limits : 2500 μ V

Ambient RIV level across 300 Ω : 13.6 μ V

The sample was pre-stressed at 125.5 kV_{rms} for 30 s and reduced to measuring voltage 92.1 kV_{rms} within 10 s and maintained at this test voltage for 30 s

Test arrangement		Specified test voltage (kV _{rms})	Measured RIV level across 300 Ω (μ V)	Remarks
HV AC applied to	Earthed			
Primary terminal of IVT	Terminal 'N' along with base tank	92.1	106	Measured RIV is less than 2500 μ V
Note: One end of Secondary winding terminals 1n, 2n and 3n were shorted and connected to earth along with base tank.				


(Dr. P. Rajamani)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Test: Test for Accuracy (7.2.6 of IEC 61869-3: 2011)

Test condition : Under dry condition
 Test frequency : 50 Hz
 Ambient conditions :
 Dry bulb temperature : 29°C
 Wet bulb temperature : 24°C
 Atmospheric pressure : 94.92 kPa
 1. Primary voltage : 132 / $\sqrt{3}$ kV_{rms}
 2. Secondary voltage : 110 / $\sqrt{3}$ V_{rms}

Secondary winding under test	Burden (VA)	Test Voltage in percentage of primary voltage (%)	Voltage (Ratio) Error (%)	Phase Displacement (Minutes)	Remarks
1a – 1n Accuracy class: 3P PF: 0.8 (lag)	200	150	-0.413	10.05	The winding is within limits of voltage ratio error ($\pm 3\%$) and phase displacement (± 120 minutes) as specified in the standard
		120	-0.257	4.53	
		100	-0.1933	2.25	
		5	-0.210	2.39	
		2	-0.219	1.89	
	50	150	-0.0966	8.94	
		120	0.0807	2.81	
		100	0.1378	0.789	
		5	0.1267	0.410	
		2	0.1298	0.389	

Secondary winding under test	Burden (VA)	Test Voltage in percentage of primary voltage (%)	Voltage (Ratio) Error (%)	Phase Displacement (Minutes)	Remarks
2a – 2n Accuracy class: 3P PF: 0.8 (lag)	50	150	-0.0626	9.15	The winding is within limits of voltage ratio error ($\pm 3\%$) and phase displacement (± 120 minutes) as specified in the standard
		120	0.0841	3.4	
		100	0.1332	1.259	
		5	0.1296	0.731	
		2	0.1239	0.568	
	12.5	150	0.0177	8.86	
		120	0.1698	2.70	
		100	0.217	0.493	
		5	0.216	-0.188	
		2	0.223	-0.210	

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHVT0115F
 Discipline: Electrical testing
 Group: Inductors and Transformers

UHV RESEARCH LABORATORY
 MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500098
 PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

Sheet 8 of 12

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number : CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

1. Primary voltage : 132 / $\sqrt{3}$ kV_{rms}
 2. Secondary voltage : 110 / $\sqrt{3}$ V_{rms}

Secondary winding under test	Burden (VA)	Test Voltage in percentage of primary voltage (%)	Voltage (Ratio) Error (%)	Phase Displacement (Minutes)	Remarks
3a – 3n Accuracy class: 0.5 PF: 0.8 (lag)	50	120	0.1296	2.96	The winding is within limits of voltage ratio error ($\pm 0.5\%$) and phase displacement (± 20 minutes) as specified in the standard
		100	0.1725	0.775	
		80	0.1842	0.300	
	12.5	120	0.179	3.05	
		100	0.230	0.587	
		80	0.239	0.174	


 (Dr. P. Rajamani)
 Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Test: Chopped impulse voltage withstand test on primary terminal
(As per cl. 7.4.1 of IEC 61860-3:2011 and customer request)

Test condition : Under dry condition

Ambient conditions:

Dry bulb temperature : 29 °C
Wet bulb temperature : 25 °C
Atmospheric pressure : 94.79 kPa
Basic Impulse Level (BIL) specified by customer : 650 kV_{peak}

The specified test voltage was applied under the ambient conditions mentioned above.

Test arrangement		Test voltage	Result	Ref. Oscillogram nos.	Remarks
Impulse Voltage applied to	Earthed	kV, peak	No. of impulses applied / No of Disruptive discharges observe		
Primary terminal of IVT	Terminal 'N' connected to earth along with base tank	-446.8 (RFW)	01 / 0	01	Withstood
		-650 (FW)	01 / 0	02	Withstood
		-747.5 (CFW)	02 / 0	03 & 04	Withstood
		-650 (FW)	14 / 0	05 to 18	Withstood
Note: Secondary winding terminals 1n, 2n and 3n were shorted and connected to earth through shunt.					

RFW: Reduced Full Wave (50% to 75% of BIL)

FW: Full Wave (100% of BIL)

CFW: Chopped Full Wave (121% of BIL)


(Dr. P. Rajamani)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 01 April 2024

TEST RESULTS

Test: Capacitance and dielectric dissipation factor measurement (7.4.3 of IEC 61869-3:2011)

Test condition : Under dry condition
Test frequency : 50 Hz
Ambient conditions :
Dry bulb temperature : 29°C
Wet bulb temperature : 24°C
Atmospheric pressure : 94.92 kPa
Specified test voltage : 76.2 kV_{rms}

Test arrangement		Test voltage	Result.	
HV AC applied to	Earthed	kV _{rms}	Measured Capacitance (pF)	Dielectric dissipation factor
Primary terminal of IVT	1n, 2n & 3n along with base tank	76.2	303.96	0.00201
Note: Terminal 'N' connected to Capacitance and tan δ measuring bridge.				

Conclusion: Test sample tested complies with the requirement of clause no. 7.2.2, 7.2.3, 7.2.5, 7.2.6, 7.4.1 and 7.4.3 of 61869-3: 2011 and customer request for the tests conducted.


(Dr. P. Rajamani)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 01 April 2024

NOTE

- The Test results relate only to the sample(s) tested.
- Publication or reproduction of this Test Report /Test Certificate in any form other than by complete set of the whole Test Report /Test Certificate and in the language written is not permitted without the written consent of CPRI.
- Any Corrections/erasure invalidates the Test Report/Test Certificate
- NABL has Accredited this laboratory as per ISO/IEC17025:2017, vide certificate no.TC-6198 for the tests carried out.
- Any anomaly/discrepancy in the Test Report / Test Certificate should be brought to the notice of CPRI within 45 days from the date of issue.



TC-6198




(Dr. P. Rajamani)
Test Engineer

-----End of Test Report-----

CENTRAL POWER RESEARCH INSTITUTE



CPRI


TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 01 April 2024

TEST CIRCUIT DIAGRAMS

1. Temperature rise test




Legend:

- 1: HV AC source
- 2: Voltage Divider
- 3: Test Sample
- 4: RMS Voltmeter

Test Circuit Diagram Number. CPRIHYDUHV24T0115TCD01

2. Impulse & Chopped lightning impulse voltage withstand test on primary terminals



Legend:

- 1: Impulse voltage generator
- 2: Impulse voltage divider
- 3: Digital recorder for measurement of voltage and current
- 4: Test object
- 5: Shunt
- 6: Chopping device (During chopped test)
- V: Voltage I: Current

Test Circuit Diagram Number. CPRIHYDUHV24T0115TCD02

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV24T0115F
Discipline: Electrical testing
Group: Inductors and Transformers


UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGH WAY, HYDERABAD – 500098.
Phone: 080-22072051, 080-22072052, E-mail: uhvrl@cpri.in

TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 1 April 2024

3. Electromagnetic Compatibility (EMC) test




Legend

- | | |
|------------------------------|---|
| 1: HV AC Cascade Transformer | 2: RF Rejection Coil |
| 3: PD / RIV Impedance Box | 4: AC Voltage Divider measuring impedance |
| 5: Peak Voltmeter | 6: PD / RIV Processing unit |
| 7: Test Sample | |

Test Circuit Diagram Number. CPRIHYDUHV24T0115TCD03

4. Accuracy test



Legend:

- | |
|--|
| 1: HV AC Source |
| 2: HV Divider |
| 3: Voltmeter |
| 4: IVT under test |
| 5: Standard Capacitor with LV arm |
| 6: Burden |
| 7: Automatic instrument transformer test set with electronic potential divider |



(Dr. P. Rajamani)
Test Engineer


Test Circuit Diagram Number: CPRIHYDUHV24T0115TCD04

TEST REPORT

Test Report Number. CPRIHYDUHV24T0115

Date: 1 April 2024

5. Capacitance and dielectric dissipation measurement test



Legend:

- 1: HV AC SOURCE
- 2: VOLTAGE DIVIDER
- 3: RMS VOLTMETER
- 4: STANDARD CAPACITOR
- 5: CAPACITANCE & TAN-DELTA MEASURING BRIDGE
- 6: TEST SAMPLE
- T: N TERMINAL OF IVT
- P: HV TERMINAL OF IVT
- S: BOTTOM FLANGE OF PORCELAIN HOUSING

Test Circuit Diagram Number. CPRIHYDUHV24T0115TCD05


(Dr. P. Rajamani)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI



Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024


OSCILLOGRAMS



No.: 1
CH1 No. 1
Ut= -446.8kV
beta_k= 1.29%
T1= 1.007μs
T2= 57.82μs
CH2 No. 1
Ip= -922.1A
Imax1= 805.1A
Imax2= -922.1A



No.: 2
CH1 No. 2
Ut= -643.9kV
beta_k= 0.53%
T1= 1.077μs
T2= 49.4μs
CH2 No. 2
Ip= -1514A
Imax1= 1247A
Imax2= -1514A



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV T0115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD - 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024




(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHVT0115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvri@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Signature)
(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Signature)

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



[Signature]

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



[Signature]

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD - 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD - 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Signature)

(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV24T0115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Signature)
(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV T0115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Hajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024



(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHVT0115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvrl@cpri.in

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number: CPRIHYDUHV24T0115

Date: 01 April 2024





(Dr. P. Rajamani)
Test Engineer

ULR-TC6198240UHV20115F
Discipline: Electrical Testing
Group: Transmission line
equipment and accessories

UHV RESEARCH LABORATORY
MEDIPALLY P.O., WARANGAL HIGHWAY, HYDERABAD – 500 098
PHONE: 080-2207 2051, 080-2207 2052, e-mail: uhvri@cpri.in

IF IN DOUBT ASK



NOTE : PLEASE REFER INSTRUCTION MANUAL FOR HANDLING & TRANSPORTATION OF IVT.

Dimensions shown are tentative and may change during detailed design/engineering.

ITEM NO.	QTY.	DESCRIPTION	MATERIAL
1	1	PRIMARY TERMINAL - #30x80L (Min.)	COPPER
2	1	TANK	ALUMINIUM CAST
3	1	PORCELAIN INSULATOR	PORCELAIN BROWN COLOUR
4	1	RATING & SCHEMATIC DIAGRAM	ALUMINIUM
5	1	SECONDARY TERMINAL BOX	ALUMINIUM CAST

TECHNICAL SPECIFICATIONS

SPECIFICATION	UNIT	RATING
HIGHEST SYSTEM VOLTAGE (Ph-Pt)	Kilo Volts	145
HIGHEST SYSTEM VOLTAGE (Ph-E)	Kilo Volts	145/ $\sqrt{3}$
1 MIN. AC WITHSTAND VOLTAGE	Kilo Volts	275
LIGHTNING IMPULSE WITHSTAND VOLTAGE	Kilo Volts(Peak)	650
TOTAL CREEPAGE DISTANCE(MINIMUM)	Millimeter	3625
TOTAL WEIGHT ($\pm 10\%$)	Kilogram	400
OIL VOLUME ($\pm 10\%$)	Litre	90
APPLICABLE STANDARDS	—	IEC:61869-1&3
VOLTAGE FACTOR	= 1.2 CONTINUOUS/1.5-30SEC.	
INSULATION CLASS	A	

NOTE :

- 1) PRIMARY WINDING NO OF TJRNS : 37120
2) CROSS SECTION AREA OF PRIMARY WINDING :
38 SWG. (0.01824 Sq.mm)
5) SECONDARY WINDING :

NO. OF WINDING	NUMBER OF TURNS	SWG/Sq.mm
WINDING-I	31	(14x2)/6.48
WINDING-II	31	(14x2)/6.48
WINDING-III	31	(14x4)/12.97

4) CORE MATERIAL : CRGO M4

सीपीआरआई के इस आरेख का सत्यापन जहाँ भी संभव हो, केवल आयाम जाँच तक ही सीमित है।
VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECK ONLY WHEREVER POSSIBLE

यह आरेख सीपीआरआई से संबंधित है।
THIS DRAWING PERTAINS TO CPRI
परीक्षण रिपोर्ट / TEST REPORT

दिनांक / Date: 01-04-2024

परीक्षण इंजीनियर
यूएचवीआरएल, सीपीआरआई
हैदराबाद

[illegible]

सीपीआरआई के इस आरेख का सत्यापन जहाँ भी संभव हो, केवल आयाम जाँच तक ही सीमित है।
VERIFICATION OF THIS DRAWING
BY CPRI IS LIMITED TO DIMENSIONAL
CHECK ONLY WHEREVER POSSIBLE

यह आरेख सीपीआरआई से संबंधित है।
THIS DRAWING PERTAINS TO CPRI
परीक्षण रिपोर्ट / TEST REPORT
सं / NUMBER : CPRI/HYD/01/04/2024
दिनांक / Date : 01.04.2024

IF IN DOUBT ASK

परीक्षण इंजीनियर
यूएचवीआरएल, सीपीआरआई
हैदराबाद
Test Engineer
UHVRL, CPRI,
HYDERABAD

32 kV INDUCTIVE VOLTAGE TRANSFORMER

RATING & SCHEMATIC DIAGRAM

MFG. BY : CG Power and Industrial Solutions Limited, D2 MIDC Waluj, Aurangabad

MADE IN INDIA

Customer : CG Power and Industrial Solutions Limited, Aurangabad (MSETCL)

TYPE

SPEC.

VEOT-145/65/50

IS : 16227-83/
IEC : 61865-1&3

S.O.NO.

413595829

YEAR

2024

PO NO. :-

1. PRIMARY TERMINAL (H.V.)

2. CAPACITANCE TAN DELTA
LEADOUT FROM BUSHING
ACTIVE PART.

3. NEUTRAL END OF HV
WINDING.

4. EARTH SHIELD BETWEEN
HV & LV. (CONNECTED TO
EARTH INSIDE HOUSING.)

5. CORE EARTHING LEAD
(CONNECTED TO EARTH
INSIDE HOUSING)

6. SECONDARY LEADOUT.

CAUTION:

-ENSURE LV TERMINALS
ARE NOT SHORTED
IN OPERATION.

-ENSURE CK AND N ARE
CONNECTED TO EARTH
BEFORE CHARGING IVT.

परीक्षण इंजीनियर

यूएचवीआरएल, सीपीआरआई

हैदराबाद

Test Engineer

UHVRL, CPRI,

HYDERABAD

BURDEN

(VA)

ACCURACY

CLASS

A N

13200.0/√3

-

-

1a - 1n

1 0/√3

200

3P

2a - 2n

~10/√3

5C

3P

3a - 3n

110/√3

50

0.5

INSULATION

LEVEL

275 kV/650 kVp

CREEPAGE

DISTANCE

3625 mm

CIL VOLUME

90 ±10% Litre

TOTAL

WEIGHT

400 ±0.4% Kg

HIGHEST

SYSTEM

VOLTAGE

145 kV

VOLTAGE

FACTOR

1.2 CO-NT/1.5-30SEC.

4 HOLES OF Ø4.5 mm

MATERIAL : AL(PHOTO METAL IC)

IVT SR.NOS. : 234656

R6

R4

R3

R5

NO

REVISION

SIGN

DATE

NO

REVISION

SIGN

DATE

SCALE

1:1

DATE

15.12.2023

DRN

KSH

STJ

SDS

APPD

ALL DIMENSIONS ARE IN mm

CG Power and Industrial Solutions Limited, Aurangabad

DRG.NO:-413695829 IVT4900 RS_R0

RATING & SCHEMATIC DIAGRAM

132 kV INDUCTIVE VOLTAGE TRANSFORMER