

CERTIFICATE OF ANALYSIS

TEST OBJECT:	<i>FA124 Strong Base Anion Exchange Resin, Gel, Type I</i>
LOT NO.:	<i>G5B-4FLT22MAY07-9</i>
TEST NO.:	<i>No. 20220508-2</i>
TEST COMPLETION DATE:	<i>May 9th, 2022</i>
TEST STANDARD:	<i>HG / T2164 – 1991 DL / T519 – 2004 SH 2605.05 – 2003</i>

TEST ITEMS	REQUIREMENTS	RESULT
Ionic form	Cl-	Cl-
Moisture Retention %	48 - 54	52.3
Shipping Weight (approx.) g/L	680 - 715	693
Specific Gravity	1.08	1.08
Whole Beads %	95.0 min.	98.0
Perfect Beads %	90.0 min.	95.7
Particle Size (%)	0.3 - 1.2mm	≥ 94%
	< 0.3mm	≤ 1%
Uniformity Coefficient	1.7 max.	1.6

PERFORMED BY
Lisa Jiang
APPROVED BY
Jie Yang
ALL RESINS ARE FRESH NEW AND UNUSED.
ALL RESINS ARE PRODUCED UNDER ISO9001.
