

STEELMET ROMANIA S.A.
 42nd DRUMUL INTRE TARLALE STR.
 032982 BUCHAREST 3rd SECTOR

INSPECTION CERTIFICATE

Type 3.1 acc. EN 10204

Certificate No : 1000401723

DATE: 24.07.2019

Delivery No : 0085191560

Customer	STEELMET ROMANIA S.A.			Cust's Part No	
Cust's Ref No	OR084			Inspection Lot	020000559447
Our Order No	1200099261 / 10	Quantity	2.100,00 MTR		

Designation	CuT m 012,000x1,00x25000 JH HPO M				
according to	EN 12735-1 R220 & EN 13348.				
Material	Cu-DHP				
Chem. Anal.:	CU>99,90-P:0,015-0,040 OK				

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	11,960 - 12,040	12,010	1
Smin	mm	>=0,870	0,900	1
Smax	mm	<=1,130	0,940	1
LENGTH	mm	>=25000	25090	1
OVALITY	mm	<=0,84	0,04	1
Rm	N/mm ²	>=220,0	241,3	1
A50	%	>=40,0	49,3	1
EXPANSION	%	>=30,0	OK	1
C TOT. RES. IN.	mg/dm ²	<=0,20	0,07	1
ECT EN 1971	%	100	OK	-

DECLARATION OF CONFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

25.07.2019

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

ISSUE: C

REV: 2

DATE: DEC. 2017

FORM N3

e-mail: info@halcor.com
 website: www.halcor.com
 VAT number: EL094061318

Offices @ Copper Tube Plant (Mailing Address)
 62nd km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry
 60th km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept
 252 Pireos str.
 GR-17778, Tavros, Athens, GREECE
 Tel.: +30 210 4898111, Fax: +30 210 4898397