Form No.: 003-EN Issue date: 10.12.2022



CERTIFICATE OF ANALYSIS

Accreditation No: AZS ISO/IEC 17025:2020/AZ 01.0571.01.21

From: ALCO LLC

3 Vali Mammadov st Sabail dist

Date of issue: 17/11/2023

3, Vali Mammadov st., Sabail dist. AZ1095, Baku, Azerbaijan

Test sample

Product: EUROTEC TRANSFORMER OIL T 1500 Manufacture date: 17/11/2023

Date of sampling: 17/11/2023 Batch number: 23111873

Tank ID: T61.1

Test result

Date of analysis: 17/11/2023

| Parameters | Unit | Test result | Limit | Test method | Conclusion |
|---|-------------------|-----------------------|----------------|-------------|------------|
| Appearance | - | Bright & Clear | Bright & Clear | Visual | Pass |
| Kinematic viscosity -at 40°C -at 50°C -at 100°C | mm²/s | 10.47 7.60 2.56 | - Max. 8.0 | ASTM D445 | Pass |
| Water content | % | None | Max. 0.05 | ASTM D95 | Pass |
| Mechanical impurities | % | None | None | ASTM D 4807 | Pass |
| Closed Cup Flash Point | °C | 143 | Min. 135 | ASTM D93 | Pass |
| Pour Point | °C | -45 | Max45 | ASTM D97 | Pass |
| TAN | mg KOH/g | 0.007 | Max. 0.01 | ASTM D974 | Pass |
| Color | - | 0.5 | Max. 1.5 | ASTM D1500 | Pass |
| Dielectric dissipation factor at 90°C | % | 0.20 | Max. 0.50 | IEC 60247 | Pass |
| Dielectric Breakdown Voltage | kV | 60.6 | Min. 30 | IEC 60156 | Pass |
| Density at 20 °C | g/cm ³ | 0.8822 | Max. 0.885 | ASTM D4052 | Pass |

Shelf life: 5 years from the date of manufacture of the product if proper storage conditions are followed. This product meets the specification set out in its product data sheet (PDS) and has been manufactured in a facility fully complying with the requirements of Integrated Management System standards.

Form No.: 003-EN Issue date: 10.12.2022



Notes & Instructions:

- Tests conducted according to International Standard Test Methods are routinely verified to be in compliance with the latest published versions. Minor changes may be made where they have no material impact on test results and are necessitated by reasons such as safety, environmental standards and method effectiveness.
- This certificate is only valid in its entirety.
- This certificate shall not be reproduced except in full, without the written approval of the laboratory.

Authorised singnatory

Matilda Yusifova

Technologist

© 2016-2022 | All rights reserved

The logos and trademarks used herein are properties owned by ALCO LLC.

