

CPRI

TEST REPORT



**Central Power Research Institute
(A Govt. of India Society)
P.B. No.9, Medipally P.O.,
Uppal - Warangal Highway
HYDERABAD - 500 098 (INDIA)**

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : UHV / T / 378 **Date:** 22.02.2012

Name & Address of the Customer : M/s. Crompton Greaves Ltd.,
EHV Switchgear Division (S₃), A-3, MIDC,
Ambad, Nashik- 422010

Name & Address of the Manufacturer : M/s. Crompton Greaves Ltd.,
EHV Switchgear Division (S₃), A-3, MIDC,
Ambad, Nashik- 422010

Particulars of sample tested

Condition of the sample on receipt : New

Type : 120-SFM-32B

Designation : 145 kV, 3150 A, 40 kA, SP-SP, SF₆ Gas Circuit Breaker

Serial Number : 37649C

Number of Samples tested : One

Date(s) of test(s) : 21.02.2012

CPRI Sample Code no(s) : UHV12S0039

Particulars of test conducted : Radio interference voltage (RIV) test

Standard/ Specification : IEC: 62271 – 100 / 2008

Sampling plan : Not applicable

Customer's requirement : Nil

Deviations if any : Nil

Name of the witnessing persons

Customer representatives : 1) Mr. Lalit Mahale
2) Mr. Santosh Gundap

Other than customer's representatives : Nil

Test subcontracted with address of the Laboratory : Nil

Documents constituting this report (in words)

Number of sheets : Four

Number of oscillogram/s : Nil

Number of graphs : One

Number of photos : Nil

Number of test circuit diagrams : One

Number of drawings : Four


(K. A. ARAVIND)
Test Engineer




(Dr. D. DEVENDRANATH)
Joint Director

Sheet 01 of 04

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : UHV / T / 378

Date: 22.02.2012

MOUNTING ARRANGEMENTS & TEST CONNECTIONS DURING TEST:

Mounting arrangements: The sample was mounted at outdoor as per GA drawing: 3949627 R0
Reference Drawing Nos: 1) 4,94,9632 R0 2) 2940037 R3 3) 3943042 R1

Test connections:

Test Connection No.	Status of Breaker	HV Connected to	Earthed terminals
1	Closed	Bb	Aa, Cc, F
2	Open	B	Aa, Cc, b & F
3	Open	b	Aa, Cc, B & F

F- Frame of the circuit breaker, SF₆ Gas Pressure: 6.2 kg/cm² (gauge) @ 30°C

AMBIENT CONDITIONS:

Test	Temperature in Degree Celsius		Atmospheric pressure in kPa
	Dry bulb	Wet bulb	
Radio interference voltage (RIV) test	30	24	95.73

TEST PROCEDURE: IEC: 62271 – 100 / 2008.


Test Engineer

Sheet 02 of 04

CENTRAL POWER RESEARCH INSTITUTE



CPRI

Test Report Number : UHV / T / 378

Date: 22.02.2012

RESULTS & OBSERVATIONS:

TEST 1: Radio interference voltage (RIV) test


Applicable additional standard CISPR 18-2/1986

Detector: Quasi Peak Measuring frequency: 1MHz,

RIV test voltage specified by the customer: 92.1 kV (RMS)

Test Voltage kV(RMS)	RIV level in μV across 300 Ω		
	Test connection no. 1	Test connection no. 2	Test connection no. 3
92.1*	495.5	495.5	495.5
83.7	473.2	478.6	489.8
75.4	473.2	462.4	473.2
67.0	451.9	441.6	451.9
58.6	441.6	412.1	384.6
50.2	421.7	384.6	358.9
47.9	402.7	358.9	342.8
33.5	384.6	346.7	335.0
25.1	375.8	335.0	323.6
Ambient RIV	190.5	190.5	213.8

* Preconditioned for 5 minutes



The RIV level at the specified RIV test voltage of 92.1 kV RMS is less than 500 μV

[Signature]
Test Engineer

Sheet 03 of 04

CENTRAL POWER RESEARCH INSTITUTE



CPRI


Test Report Number

: UHV / T / 378

Dated: 22.02.2012

TEST CIRCUIT DIAGRAM

Radio interference voltage (RIV) test



Legend:


- | | |
|-----------------------|----------------------|
| 1: AC Transformer | 2: Voltage Divider |
| 3: RMS Voltmeter | 4: RF Rejection Coil |
| 5: Coupling Capacitor | 6: Impedance Box |
| 7: EMI Test receiver | 8: Test Sample |

NOTE

- The test results relate only to the item(s) tested.
- Publication or reproduction of the test report /Certificate in any form other than by complete set of the whole test report /Certificate and in the language written is not permitted without the written consent of CPRI.
- Any Corrections/ erasure invalidates the test report /Certificate
- NABL has Accredited this laboratory as per ISO 17025:2005 standard for the tests carried out.
- Any anomaly / discrepancy in the test report /Certificate should be brought to the notice of CPRI within 45 days from the date of issue.


Test Engineer

Sheet 04 of 04



- NOTE :-
- 1) TOTAL WEIGHT INCLUSIVE OF COLUMN:-1450Kg.(APPROX.)
 - 2) TOTAL GAS WEIGHT :-6 Kg. (APPROX.)
 - 3) MAXIMUM SHOCK LOAD DURING OPERATION :-2000 Kg.
 - 4) FINISH :- ALL EXPOSED FERROUS PARTS ARE PAINTED WITH SHADE 631 OF IS:5
 - 5) CREEPAGE DISTANCE: 3625mm
 - 6) HARDWARES EXPOSED TO ATMOSPHERE ARE H.D.G./S.S.

CONCRETE LEVEL ENGINEER
GROUND LEVEL Research Institute
HYDERABAD

यह चित्र परीक्षण दस्तवेज से संबंधित है
This drawing pertains to Test report No
UHV/7/378... dt. 22.02.2012

इस चित्र का सांख्यिकीय विभा की आंच तब ही संश्लिष्ट है
Restation of drawing is limited
The checking of dimensions only

NO	REVISION	SIGN	DATE	SCALE	N.T.S.	DATE	28/03/11
2		DRN	HCH	NAME	THIRD ANGLE PROJECTION		
1		CHD	SSS	GENERAL ARRANGEMENT			
		APPD	SSS	FOR 145KV-40KA SP SP			
				SINGLE STACK GCB			

FOUNDATION DESIGN
DETAILS OF VIEW - "A"

Crompton Greaves Ltd.
SURVEILLANCE DIVISION 33
AMBALA, HARYANA.

DRG.NO. 3949627 R0



Crompton Greaves Ltd.
SWITCHGEAR DIVISION S3
AMBAD, NASHIK

GAS CIRCUIT BREAKER

TYPE 120-SFM-32B		SR. NO. : YEAR 2011	
RATED VOLTAGE	145 KV	RATED FREQUENCY	50 Hz
RATED NORMAL CURRENT	3150 A	RATED MAKING CAPACITY	100 KA
RATED SHORT CIRCUIT BREAKING CURRENT	40 KA	RATED SHORT TIME CURRENT	40 KA FOR 3 SECONDS
RATED LIGHTNING IMPULSE WITHSTAND VOLTAGE	650 KVp	FIRST POLE TO CLEAR FACTOR	1.5
RATED GAS PRESSURE	7 kg/cm ² -g(AT 20°C)	RAT.OPR.SEQ. 0-0.3SEC-CO-3MIN-CO	
RATED COIL VOLTAGE - CLOSING 110 V DC		GAS WT	6 Kg
		TOTAL WT.	2450 Kg
MOTOR VOLTAGE	230 V AC/DC	AUX CIRCUIT VOLTAGE 1Ø,230V AC,50/60 Hz.	
REF.STD.IEC-62271-100			

MATERIAL : STAINLESS STEEL 0.5THK

TEST ENGINEER
Central Power Research Institute
HYDERABAD

कटु गिनि परीक्षण दस्तर्वज सं.
हो संबंधित है

UHV/T/378 22-02-2012

इस चित्र का साक्षात्कन बिमा की सांच तव
ही सीमित है


• The checking of dimensions only

[illegible]

NOTES ::

1. UNSCRIPED TOLLANCES AS PER IS : 5621-1980 & IEC 82155-2003
2. MINIMUM NOMINAL CREEPAGE DISTANCE - 3700mm
3. PARALLELISM BETWEEN END SURFACES OF UPPER AND LOWER FLANGES - LESS THAN 0.5mm.
4. PARALLELISM BETWEEN END SURFACES OF PORCELAIN AND FLANGES - LESS THAN 0.25mm.
5. CONCENTRICITY BETWEEN UPPER AND LOWER FLANGES - LESS THAN 1.5mm(MAX)
6. CONCENTRICITY BETWEEN FLANGES AND PORCELAIN - LESS THAN 2.0mm.(MAX)
7. ANGULAR MISMATCH BETWEEN MATING HOLES OF UPPER AND LOWER FLANGES -LESS THAN 2.0mm.
8. OTHER ROUTINE AND ACCEPTANCE TESTS AS PER IEC:82155-2003 & IEC 82155-2003
9. SURFACE MARKED VV TOBE GROUND SMOOTH AND PARALLEL TO EACH OTHER.
10. MINIMUM CEMENTING THICKNESS 4mm UNDER ANY CONDITION OF WARPAGE & SHELL O.D. VARIATION.
11. CAMBER AS MEASURED BY STRING OVER SHED 4mm MAX.
12. SHED PROFILE AS PER IEC:815-1986
13. VISUAL DEFECTS AS PER IEC:82155-2003
14. MATERIAL SPEC'S AS PER SP-09


1		j = d1 / C = 42	d1 = 23.65 d2 = 58.72
2	k1 k2 = 88 d1 d2	221 23.65 58.72	3.44, 3.5
3	S/P P=57.5	S=72	1.25
4	Average dia. Dm		185
5	Inclination Of Shed		top 18° bottom 10°
6	Profile factor	$\frac{291+263+2}{2 \times 2 \times 2}$ $\frac{118+263+75}{2 \times 2 \times 2}$	1.13
7	Creepage factor	$\frac{j}{S} = \frac{3700}{1170}$	3.16
8	Form factor = $\frac{\text{Total Cd}}{110m}$	$\frac{3700}{3.14 \times 185}$	6.36
9	Net Weight (approx.)		74 Kg



SHED PROFILE (FOR REF. ONLY.)



CONCENTRICITY



TEST ENGINEER
UPPER PLANCE
Central Power Research Institute
ANGULAR MISMATCH
HYDERABAD

1
यह चित्र परीक्षण दस्तवर्ज सं. 2022-02-2012
UHV/T/378 परीक्षा दिनांक 22-02-2012

[illegible]

② #15 HOLE, 6 NOS. EQUALLY SPACED
ON PC #225 ±0.3

ROUTINE TEST:

1. DIMENSION & VISUAL INSPECTION.
2. DYE PENETRATION TEST GROUND ON SURFACE OF PORCELAIN
3. INTERNAL PRESSURE TEST 20kg/cm² FOR 5 MINUTES.
4. DI-ELECTRIC TEST AS PER IEC-62155-2003
5. 4 WAY BEND TEST 790 kg.-m.
6. ULTRASONIC TEST ON GROUND SURFACE OF PORCELAIN.

ACCEPTANCE TEST:

1. DIMENSIONAL & VISUAL INSPECTION.
2. TEMP CYCLE TEST AS PER IEC-62155-2003
3. BURST PRESSURE TEST 40 kg/cm² FOR 5 MINUTE
4. 4 WAY BEND TEST 1580 kg-m
5. POROCITY TEST AS PER IEC-62155-2003
6. CEMENT CUBE TEST 300kg./cm²

TYPE TEST:

1. REPEATED BENDING TEST AT 1106 kg-m FOR 50 CYCLES.

CODE NO: 940111325

[illegible]

Ø15 HOLE, 6 NOS. EQUALLY SPACED
ON PC Ø225 ±0.3

DETAIL - "X"

IF IN DOUBT ASK

All information contained in this document is confidential and should not be used without prior consent of CROFTON GRAVES LTD.