



Czech Metrology Institute

Okružní 31, 638 00 Brno, Czech Republic

phone: +420 545 555 111 fax: +420 545 222 728



V 3136

*TESTCOM – Certifying Body for Certification of Products, No.: 3136 accredited by CAI according to ČSN EN ISO/IEC 17 065:2013;
Hvoždanská 3, 148 00 Praha 4; phone: +420 271 192 158, e-mail: fsebek@cmi.cz*

CERTIFICATE OF THE PRODUCT

No. 0120-CC-V0018-16

Applicant: SUNDRAX Ltd.
707, Westgate House, Westgate Road
London W5 1YY, Great Britain

Manufacturer: SUNDRAX Ltd.
707, Westgate House, Westgate Road
London W5 1YY, Great Britain

Product: Central Controller

Type: Qulon-C S/N ---

Basic parameters:

Relay outputs	4
Max. voltage and current at inputs	230V, 5A
Max. voltage and current at outputs	230V, 5A
Number of sensor inputs	2
Radio channel used	GSM900/1800/1900
Interfaces supported	RS485, CAN
Setup	remotely over GSM, locally over RS 485 (MODBUS)
Operating temperature range	-40°C to +60 °C
Power supply	100VAC - 240VAC, 50/60 Hz
Size	(105x210x75) mm

This certificate confirms:


The compliance
of the above mentioned product with essential requirements of
EU Directive 1999/5/EC (Government Decree No.: 426/2000 Coll.),
and the following technical regulations (standards, specifications):
ETSI EN 301 489-1 V1.9.2, ETSI EN 301 489-7 V1.3.1,
EN 60950-1, ed.2:2006, +A1:2010, +A11: 2009, +A12:2011, +Cor.:2011-10

The Basis of the assessment:

- Certification scheme according to EU Directive 1999/5/EC, Annex IV (Government Decree No.: 26/2000 Coll., Annex 4).
- The Certifications System is based on the product testing and its documentation verification.
The basis for the issuing of the certificate are the following documents:
- The final report 0120-ZA-Z0018-16 issued by TESTCOM-COV in Prague, which is its an integral part.
The Instruction for use is on the second page of this Certificate.

Prague, October 20th, 2016




Miloš Prchlík
Head of Certification Body

The Certificate can be used as a basis for the "Declaration of Conformity, in pursuing the Act No. 22/97 Coll., as amended by the Act No. 71/2000 Coll., on technical requirements for products.

The Certificate confirming the measures implemented in the production domain is only valid for the manufacturer and his/her business premises that are indicated in the Certification.

The Certificate is valid only for the Product (Equipment) who's Serial Number (S/N) is identical with S/N mentioned in this Certificate.

The Holder of the Certificate is obligated use only this range of the declaration, which is writing on the Certificate.