



EVPÜ[®]

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0655 Rev.1

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

**Conventional manual call point
SensoMAG MCP50, SCP-2R, Jade MCP50,
Precise MCP50, Herald MCP50, RunwayLeo MCP50**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**Teletek Electronics JSC
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

and produced in the manufacturing plant

**Teletek Electronics JSC
2, Iliyansko Shose Str., NPZ Voenna Rampa, 1220 Sofia, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11:2001, EN 54-11:2001/A1:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 6th, 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, November 6th, 2023


Michal Mišiak

054837

Annex to Certificate No. 1293 - CPR – 0655 Rev.1 from November 6th, 2023

General Information

SensoMAG MCP50 and derived variants are manual call points, designed to work with conventional fire panels.

In stand-by mode, the resettable (flexible) call point element is in a middle position. The call point is powered off and the LED is off. When pressed on, the resettable element is moving down and a color strip is shown on at its upper side. The call point is powered on and the LED is on - this is a "Fire alarm" condition. The resetting of the flexible element back in stand-by mode is done with the special key tool.


Products parameters

Operating voltage	9+30VDC
Nominal operating voltage	24VDC
Current consumption in alarm state	23mA/15V, 38mA/24V, 48mA/30V
Installation wires	0.4+2.0 mm ²
Operation temperature	-10°C + +60°C
Relative humidity	≤ 93% @ +40°C
Degree of protection	IP40
Dimensions	90x90x56mm
Weight	≤150g
Material (plastic), colour	ABS, red
Type (according to EN 54-11)	A
Type of the frangible element	Resettable (flexible)
Indication "Fire alarm"	red LED

Essential characteristics	Harmonised technical specifications	Performance
	EN 54-11:2001 EN 54-11/A1:2005	
Nominal activation conditions / Sensitivity and Performance under fire conditions	cl. 4.3.2, 4.4, 4.7.1, 4.7.4=N/A, 5.2, 5.3	Pass
Operational reliability	cl. 4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8=N/A, 5.4, 5.5	Pass
Durability of operational reliability: temperature resistance	cl. 5.7, 5.8=N/A, 5.9	Pass
Durability of operational reliability: vibration resistance	cl. 5.14 to 5.17	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11=N/A, 5.12, 5.19=N/A	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11=N/A, 5.13	Pass
Durability of operational reliability: electrical stability	cl. 5.6, 5.18	Pass

History of certification

No.	Certificate No.	Description	Date of issue
1.	1293-CPD-0655	Original certificate issued	August 16 th , 2019
5	1293-CPR-0655 Rev.1	New location of the company	November 6 th , 2023



Nová Dubnica, November 6th, 2023

Michal Mišiak