

## TEST REPORT

**Report No. : CH:TX:1042003821**

**DATE : 25/01/2019**



SHHL1811067691SD

**LYNCMED MEDICAL TECHNICAL(BEIJING)CO.LTD**  
ROOM 119, FLOOR 1, GUOTOUSHANGKE BUILDING NO 111, SOUTH HUIHE R  
CHINA  
**A/C F619301 SGS-CSTC STANDARDS TECHNICAL SERVICES (SHANGHAI) CO., LTD.**  
**CONTACT PERSON :**

**THE FOLLOWING SAMPLE(S) WAS/WERE SUBMITTED AND IDENTIFIED BY/ON BEHALF OF THE CUSTOMER AS :**

**SAMPLE DESCRIPTION** GLOVES  
NITRILE GLOVE  
**STYLE NO.** M  
**PHOTO APPENDIX.**



**SAMPLE RECD ON** 22/01/2019 **TESTING PERIOD :** 22/01/2019 – 25/01/2019

### Summary of Test Results/Conclusion

Test Method / Standard	Clause/Test Name	Status / Performance Level
EN 374-2:2014	<b>Protective gloves against chemicals and micro-organisms:Determination of resistance penetration</b>	
	Clause 4.1 – Air leak test	Pass
	Clause 4.2 – Water leak test	Pass
EN 16523-1:2015	<b>Permeation by Liquid chemical under conditions of continuous contact.</b>	
	Methanol	Level - 0
EN 374-4:2013	<b>Resistance to Degradation by Chemicals</b>	
	Methanol	Refer results.

Per pro SGS India Private Ltd.



**K. PACHAIYAPPAN**  
**ASST. MANAGER**

Email your Test Report Related Enquiries at [Feedback.SLT@sgs.com](mailto:Feedback.SLT@sgs.com)

**TEST REPORT**

**Report No. : CH:TX:1042003821**

**DATE : 25/01/2019**



SHHL1811067691SD

**RESULTS**

**EN 374-2 : 2014 Protective gloves against chemicals and micro-organisms – Part-2: Determination of resistance penetration**

Clause	Test Name	Test Results		Performance level
4.1	Air leak Test (Air Pressure Used : 0.5 kPa)	<b>Specimen #</b>	<b>Leakage</b>	Pass
		Size M	No Leakage	
		Size M	No Leakage	
		Size M	No Leakage	
		Size M	No Leakage	
4.2	Water leak test	<b>Specimen #</b>	<b>Leakage</b>	Pass
		Size M	No Leakage	
		Size M	No Leakage	
		Size M	No Leakage	
		Size M	No Leakage	

**EN 16523-1:2015 Determination of material resistance to permeation by chemicals – Part-1: Permeation by Liquid chemical under conditions of Continuous contact.**

Chemical CAS NO	Loop system/collection medium	Analytical technique used	Mean thickness (mm)	NBT at NPR 1.0 µg cm <sup>-2</sup> min <sup>-1</sup> (minutes)	Performance level accordance to EN ISO 374-1: 2016 Table 1	Observation
Methanol 67-56-1	Open loop/ Nitrogen	Continuous measurement With GC-FID	0.06 0.05 0.06	<1 <1 <1	Level - 0	Severe swelling

EN ISO 374-1:2016 – Protective gloves against dangerous chemicals and micro-organisms.  
Part 1: Terminology and performance requirements for chemical risks.  
Table 1: Permeation performance levels.

Permeation performance level	Measured breakthrough time (minutes)
1	>10
2	>30
3	>60
4	>120
5	>240
6	>480

Performance levels are based on the lowest individual results achieved per chemical

\*\*\*\* End of page\*\*\*\*

**TEST REPORT**

Report No. : CH:TX:1042003821


DATE : 25/01/2019



SHHL1811067691SD

## RESULTS

Methanol Permeation Graph



**EN 374-4:2013 Protective Gloves against Chemicals and Micro Organisms – Determination of resistance to degradation by chemicals**

Chemical / CAS NO	Exposure Duration	Test Results		Observation
		Percentage change in puncture resistance		
Methanol 67-56-1	60±5 minutes	<u>Glove sample</u>	<u>Result (%)</u>	Severe swelling
		1	38.8	
		2	48.7	
		3	45.2	
		Mean	44.3	
		Standard Deviation	5.045	

\*\*\*\*\* End of Report\*\*\*\*\*