

IEC 60598-2-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- Test with standard test finger after the test		N/A
3.12 (12.7.2)	Luminaire with temperature sensing control		N/A
	- thermal link	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	—
	- manual reset cut-out	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	—
	- auto reset cut-out	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	—
	- case of abnormal conditions	N/A	—
	- highest measured temperature of fixing point/ exposed part (°C):	N/A	—
	Ball-pressure test:	See Test Table 3.15 (13.2.1)	N/A
3.12.1 (-)	Temperature reduction if for outdoor use only		P
3.12.2 (-)	(See above)		—
3.12.3 (-)	Glass covers used within the thermal limits declared by the glass manufacturer		N/A

3.13 (9)	RESISTANCE TO DUST AND MOISTURE		P
3.13.1 (-)	If IP > IP 20 the order of tests as specified in clause 3.12		P
3.13 (9.2)	Tests for ingress of dust, solid objects and moisture:		P
	- classification according to IP	IP66	—
	- mounting position during test	On the mast arm	—
	- fixing screws tightened; torque (Nm)	N/A	—
	- tests according to clauses	9.2.2, 9.2.7	—
	- electric strength test afterwards		P
	a) no deposit in dust-proof luminaire		N/A
	b) no talcum in dust-tight luminaire	IP6X	P
	c) no trace of water on current-carrying parts or on insulation where it could become a hazard	IPX6	P
	c.1) For luminaires without drain holes – no water entry	IPX6	P
	c.2) For luminaires with drain holes – no hazardous water entry		N/A
	d) no water in watertight or pressure watertight luminaire		N/A
	e) no contact with live parts (IP 2X)		N/A
	e) no entry into enclosure (IP 3X and IP 4X)		N/A
	e) no contact with live parts through drain holes and ventilation slots (IP3X and IP4X)		N/A

IEC 60598-2-3			
Clause	Requirement + Test	Result - Remark	Verdict
	f) no trace of water on part of lamp requiring protection from splashing water		N/A
	g) no damage of protective shield or glass envelope		P
3.13 (9.3)	Humidity test 48 h		P
3.14 (10)	INSULATION RESISTANCE AND ELECTRIC STRENGTH		P
3.14 (10.2.1)	Insulation resistance test		P
	Cable or cord covered by metal foil or replaced by a metal rod of mm Ø	Metal foil	—
	Insulation resistance (MΩ)	>2 MΩ	—
	SELV		N/A
	- between current-carrying parts of different polarity :		N/A
	- between current-carrying parts and mounting surface		N/A
	- between current-carrying parts and metal parts of the luminaire		N/A
	- between the outer surface of a flexible cord or cable where it is clamped in a cord anchorage and accessible metal parts		N/A
	- Insulation bushings as described in Section 5		N/A
	Other than SELV		P
	- between live parts of different polarity	>2 MΩ	P
	- between live parts and mounting surface	>2 MΩ	P
	- between live parts and metal parts	>2 MΩ	P
	- between live parts of different polarity through action of a switch		N/A
	- between the outer surface of a flexible cord or cable where it is clamped in a cord anchorage and accessible metal parts	>2 MΩ	P
	- Insulation bushings as described in Section 5		N/A
3.14 (10.2.2)	Electric strength test		P
	Dummy lamp		N/A
	Luminaires with ignitors after 24 h test		N/A
	Luminaires with manual ignitors		N/A
	Test voltage (V)	1480 V	P
	SELV		N/A
	- between current-carrying parts of different polarity :		N/A