



Poz.	Insem.	Denumirea	Can-ea	Nota
1		Panou de dirijare - PD-П1	1	
2	A	Controlor Arcon-4 (Raut)	1	TS
3	SK1	Termoregulator in complex cu traductor de temperatura TG-K330,	1	TE
4	SK2	Traductor de temperatura aer, plaja masura. -30...50°C, L=150mm, Pt1000, STa-02	1	TE
5	SK3	Traductor de temperatura apa, plaja masura 0...+70 C°, Pt1000, STw-02	1	TE
6	SK4	Traductor de temperatura aer, plaja masurare -30...+50°C, Pt1000 ST-01	1	TE
7	SK5	Traductor de temperatura aer, plaja masurare 0...40°C, Pt1000, ST-02	1	TE
8		Termometru tehnic drept in carcasa metalica. Scara -30...+50°C	1	TI
		ТТП2.1.240.103		
9		Termometru tehnic drept in carcasa metalica. Scara 0...+100°C	2	TI
		ТТП4.1.240.103		
	M1	Motor electric ventilator ~380V	1	vezi IVC
	M2	Motor electric pompa ~220V	1	vezi IVC
	M3(YA1)	Servomotor ~220V	1	vezi IVC
	M4(YA2)	Servomotor 24V	1	vezi IVC

						06/02-D/23-AIVC			
						Reparatia capitala a blocului alimentar a institutiei de educatietimpurie nr.6, str. Cicicalo, 6 din mun. Balti			
Modif.	Sector	Planse	N doc.	Semnatura	Data	Bloc alimentar	Faza	Plansa	Planse
							PE	2	
Sp. prin.	Loghin I.			03.23			SRL "GEO-CAD-PROIECT" mun. Balti		
Elaborat	Loghin I.			03.23					