

Vojenský technický ústav, s.p.
odštěpný závod VTÚPV
Víta Nejedlého 691, 682 01 Vyškov, Czech Republic

C E R T I F I C A T E
N° VTÚPV - 038 / 2020 / ZAHR

Applicant: **LLC "IEK HOLDING"**
107/49 Prospect Lenina, Office 457, Podolsk, Moscow Region, Russian Federation, 142100

Product: **Circuit breakers with the electronic release VA88 type MASTER Series trade mark IEK**

Tested Model: VA88-32
Derived Models: VA88-35, VA88-39, VA88-40

Manufacturer: **TENGEN GROUP**
Tengen Building, Dongfeng Industrial Park, Liushi Wenzhou, Zhejiang, P.R.C.

Rating and principal characteristics: **Rated Voltage: 400, 690 V;**
Rated Frequency: 50 Hz;
Rated Current: 125, 250, 400, 630, 800 A

Test results are described in the Test Reports No.:
11X/H-16.07/19, 12X/H-16.07/19, 13X/H-16.07/19, 14X/H-16.07/19 (tests made by
«CERTIFICATION GROUP», TL «HARD GROUP», Moscow, Russia)

The sample of tested product conforms with the requirements of the following standards harmonized with the EMC Directive No. 2014/30/EU and LVD Directive No. 2014/35/EU:

- EN 60947-1:2007
- EN 60947-2:2017

This certificate is valid until: **07. 09. 2023**

Vyškov 07. 09. 2020

Tel./Fax: +420 910 105 580
e-mail: milan.bezdek@vtusp.cz
<http://www.vtusp.cz>


Milan Bezdek
Certification Head

