



S&C ELECTRIC COMPANY

GENERAL OFFICES • CHICAGO

Specialists in High-Voltage Switching and Protection

6601 NORTH RIDGE BOULEVARD
CHICAGO, ILLINOIS 60626-3997, USA
TELEPHONE: (773) 338-1000
FAX: (773) 338-3657

Reference Number: CERT-512
Original Issue Date: July 12, 2002
Revision Date: July 23, 2002

CERTIFIED TEST ABSTRACT

**Mechanical Tests
Mechanical Operations
Thermal Cycle**

TYPE OF EQUIPMENT

S&C Fuse Cutout — Type XS — Outdoor Distribution — Overhead Pole-Top Style, with the following mounting configuration, catalog number, and ratings:

Catalog Number	Style*	kV Max.	kV BIL
89021R10-P	EHD	15	110
89031R10-P	UHD	15	110
89071R11-P	EHD	15	110
89221R10-P	DISC	15	110

*EHD = Extra-Heavy Duty

*UHD = Ultra-Heavy Duty

*DISC = Disconnect

APPLICABLE TEST SPECIFICATIONS

Test procedure in accordance with ANSI/IEEE C37.41-2000, *IEEE Standard Design Tests for High-Voltage Fuses, Distribution Enclosed Single-Pole Air Switches, Fuse Disconnecting Switches, and Accessories.*

TEST RESULTS

S&C Test Reference Numbers: 11410, 11428

The samples tested were all Type XS Fuse Cutout Catalog No. 89021R10-P. The testing results are fully applicable to the other Type XS Fuse Cutouts listed under Type of Equipment,

