

STEELMET ROMANIA S.A.
 42nd DRUMUL INTRE TARLALE STR.
 032982 BUCHAREST 3rd SECTOR

INSPECTION CERTIFICATE
Type 3.1 acc. EN 10204
Certificate No : 1000459465
DATE: 08.12.2020
Delivery No : 0085220188

Customer	STEELMET ROMANIA S.A.			
Cust's Ref No	OR166		Cust's Part No	
Our Order No	1200112596 / 10	Quantity	2.460,00 MTR	Inspection Lot 020000659456

Designation	CuT m 010,000x1,00x5000 JH HSH D M			
according to	EN 12735-1 R290, P.E.D 97/23/EC, EN 13348.			
Material	Cu-DHP			
Chem. Anal.:	CU>99,90-P:0,015-0,040		OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODmin	mm	>=9,960	10,000	1
ODmax	mm	<=10,040	10,020	1
ODav	mm	9,960 - 10,040	10,010	1
Smin	mm	>=0,870	0,880	1
Smax	mm	<=1,130	0,920	1
Sav	mm	<=0,910	0,900	1
LENGTH	mm	>=5000	5008	1
WGHT/m	kg/m	<=0,2323	0,2293	1
Rm	N/mm ²	>=290,0	466,2	1
A50	%	>=3,0	4,8	1
EXPANSION	%	>=30,0	OK	1
C TOT. RES. IN.	mg/dm ²	<=0,20	0,12	1
ECT EN 1971	%	100	OK	-

DECLARATION OF COMFORMITY

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

Athens

09.12.2020

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

ISSUE: C

REV: 2

DATE: DEC. 2017

FORM N3

e-mail: info@halcor.com
 website: www.halcor.com
 VAT number: EL094061318

Offices & Copper Tube Plant (Mailing Address)
 62nd km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 48111, Fax: +30 22620 48911

Foundry
 60th km Athens-Lamia National Road,
 GR-32011 Inofita-Viotia, GREECE
 Tel.: +30 22620 53479, Fax: +30 22620 53925

Domestic Sales Dept
 252 Pireos str.
 GR-17778, Tavros, Athens, GREECE
 Tel.: +30 210 4898111, Fax: +30 210 4898397