



Centrum stavebního inženýrství a.s. Praha
Centre of Building Construction Engineering Prague

Akreditované zkušební laboratoře, Autorizovaná osoba,
Oznámený subjekt, Certifikační orgán
Accredited Test Laboratories, Authorised Body,
Notified Body, Certification Body
Pražská 16, 102 00 Praha 10



Notified Body 1390

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1390 – CPR – 0256/10/P

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Factory made mineral wool product ROCKWOOL used for thermal insulation of buildings, sold under the trade mark

Trade mark	Thermal conductivity W/mK	Reaction to fire	Type code according to EN 13 162	line
FRONTROCK MAX E FRONTROCK SUPER	0,036	A1	MW - EN 13162 - T5-DS(70,-) - DS(70,90) - CS(10)20 - TR10 - PL(5)250 - WS - WL(P) - MU1	CIG 3

placed on the market by : **ROCKWOOL Polska, Sp.z o.o.**
ul. Kwiatowa 14
66-131 Cigacice, Poland

and produced in the:
manufacturing plant **ROCKWOOL Polska, Sp.z o.o.**
ul. Kwiatowa 14
66-131 Cigacice, Poland
(production line CIG 3)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 13 162:2012+A1:2015

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product**.

This certificate was first issued on 15. 03. 2010 as a certificate in accordance with CPD and will remain valid as long as neither the harmonised standard, the construction product, the AVPC methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body

Notified Body 1390
Prague, 26. 06. 2019




Ing. Petr Kučera, Ph.D.
Deputy of Notified Body 1390