



DYAYAN PROTECTION

DRY CHEMICAL FIRE EXTINGUISHING POWDERS AND FOAM COMPOUNDS



ISO 9001:2015

MINISTRY OF THE INTERIOR
CHIEF DIRECTORATE FIRE SAFETY AND CIVIL PROTECTION (CDFSCP)
Sofia 1309, 171A, Pirotska Str.

CERTIFICATE

For being in the conformity of fire-extinguisher products with the provisions of Regulation № 81213-906/2015 about the requirements toward fire-extinguisher products, procedures for assessment and verification of compliance with these requirements, obligations of producers, importers and distributors of fire-extinguisher products and procedures for control exercising, promulgated in the State Gazette № 62/14th August 2015

(acc.to Art. 14, paragraph 1 Regulation № 81213-906/2015)

Reg.No. 1983re-16/07.09.2021

1. **PRODUCT NAME:** FOAM CONCENTRATE, brand name „DimiLex AFFF 6%, F-15"
2. **APPLICANT:** „DYAYAN PROTECTION" LTD, Kazanlak city, 8, Gen. Dragomirov bul.
3. **MANUFACTURER:** „DYAYAN PROTECTION" LTD, VAT No 202299286
4. **DESCRIPTION AND PURPOSE:** The foam concentrate „DimiLex AFFF 6%, F-15" is a synthetic, film-forming foam concentrate, with a concentrate freezing temperature minus 16°C, 6 % working concentration and extinguishing performance class and lowest burn back resistance level **I C**. The characteristics of the foam concentrate are evaluated in accordance with Art.7, paragraph 2 of Regulation № 81213-906/30.07.2015.

The foam concentrate meets the requirements of the standard BDS EN 1568-3:2018 "Fire extinguishing media. Foam concentrates. Part 3: Specification for low expansion foam concentrates for surface application to water-immiscible liquids" about: percentage of sediment contents; viscosity; hydrogen index (pH); surface tension of the foam concentrate, foam expansion and foam drainage, extinguishing capacity and marking.

5. **TERM OF VALIDITY:** 5 years from the issue date.
6. **THE CERTIFICATE IS ISSUED ON THE GROUNDS OF:** Request No 198300-4140/24.06.2021; Test records №№ IZ-40-46/30.05.2016, № IZ-40-47/30.05.2016, № IZ-3-13/13.08.2020, № IZ-33-26/12.05.2021, № IZ-10-33/01.09.2021 and Analysis № 1983p-1665/31.01.2020, issued by the Test center for Fire and emergency safety of the CDFSCP, Ministry of the Interior; Letter dated 18.06.2021 with test results issued by MPA Dresden GmbH, Certificate № 15151 for applied Quality Management System.
7. **THE CERTIFICATE WILL SERVE FOR:** Verification of the conformity of the fire-

Head office:
8,Gen.Dragomirov bul.,6100 Kazanlak,Bulgaria
Tel:00359 431 6 33 44,Fax:00359 431 6 24 58
e-mail:office@dyayan-protection.com
www.dyayan-protection.com

VAT Number BG 202299286
EUR:BG 93 UNCR 7000 1522 7738 48
BIC: UNCRBGSF
Unicredit BulBank-Kazanlak



DYAYAN PROTECTION

DRY CHEMICAL FIRE EXTINGUISHING POWDERS AND FOAM COMPOUNDS



ISO 9001:2015

extinguishing product with the requirements under Second Chapter of the Regulation № 81213-906/2015.

The certificate can be appealed through administrative channels before the higher administrative authority through the issuing administrative body within 14 days from its

notification under the Code of Administrative Procedure.

The certificate can be appealed by legal steps through the issuing administrative body before the Administrative Court – Sofia within 14 days from its notification under the Code of Administrative Procedure.

Notes: 1. The present certificate concerns only this product.

2. The present certificate becomes invalid if the components of the product for which the certificate is issued are changed as well as in the cases under Art.15, paragraph 4 of the Regulation № 81213-906/2015.

3. Extracts from the present certificate cannot be duplicated without the written consent of the CDFSCP, Ministry of the Interior.

DIRECTOR

CHIEF COMMISSIONER: (signed)

Eng.I.Nikolov

Seal of the Ministry of Interior, CDFSCP, city of Sofia

Tel.+ 359 2 98 21 222, E-mail: nspab@nvr.bg

1983k-1359/27.08.21

