

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50414008

Blatt Sheet
0001

Ihr Zeichen Client Reference L. Z.	Unser Zeichen Our Reference 01-JJX-50163017 002	Ausstellungsdatum Date of Issue 26.09.2018 (day/mo/yr)
---------------------------------------	--	--

Genehmigungsinhaber License Holder
LEADER TECHNOLY (SHENZHEN)
CO., LIMITED
UNIT 04, 7/F, BRIGHT WAY TOWER,
NO.33 MONG KOK RD
Hong Kong

Fertigungsstätte Manufacturing Plant
030-0000442296

Prüfzeichen Test Mark



Geprüft nach Tested acc. to
EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Cable (Cables for Photovoltaic Systems)

Type Designation : H1Z2Z2-K 1X2,5...6mm²
LEADER TECHNOLY (SHENZHEN)
CO., LIMITED

Rated Voltage : DC 1,5kV
AC 1,0/1,0kV

7

Ambient Temperature : -40°C to +90°C

Max. Temperature
at Conductor : 120°C

7

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50500672 Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
L.Z.	01-SYF-50082664 013	22.07.2021 (day/mo/yr)

Genehmigungsnehmer License Holder
LEADER TECHNOLY (SHENZHEN)
CO., LIMITED
FLAT/RM 1402B 14/F THE BELGIAN BANK
NOS. 721-725 NATHAN ROAD MONGKOK.KL
Hong Kong

Fertigungsstätte Manufacturing Plant
040-0002086538

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
IEC 62930:2017

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzenzgelte - Einheit
License Fee - Unit

Cable (Cables for Photovoltaic Systems)

Type Designation : 62930 IEC 131 1X2,5...35mm² 11
HALOGEN FREE LOW SMOKE
LEADER

Rated Voltage : DC 1,5kV
AC 1,0/1,0kV

Ambient Temperature : -40°C to +90°C

Max. Temperature
at Conductor : 120°C

11

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Kenny Shi

LEADER TECHNOLY (SHENZHEN)
CO., LIMITED
Lily Zou

Date : 22.07.2021
Our ref. : SYF 01
Your ref.: L.Z.

FLAT/RM 1402B 14/F THE BELGIAN BANK
BUILDING
NOS. 721-725 NATHAN ROAD MONGKOK.KL
Hong Kong

Ref : R TÜV-Mark Approval

Type of Equipment : Cables for Photovoltaic Systems
Model Designation : See Certificate
Certificate No. : R 50500672 0001
Report No. : 50082664 013

Dear Lily Zou,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,


Certification Body

Kenny Shi

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3868 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50528631

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
L.Z.

Unser Zeichen *Our Reference*
01-WJJ-50082664 020

Ausstellungsdatum *Date of Issue*
08.06.2022 (day/mo/yr)

Genehmigungsinhaber *License Holder*
LEADER TECHNOLY (SHENZHEN)
CO., LIMITED
FLAT/RM 1402B 14/F THE BELGIAN BANK
NOS.721-725 NATHAN ROAD MONGKOK.KL
Hong Kong

Fertigungsstätte *Manufacturing Plant*
040-0002086538

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to* EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV-Cables (Cables for Photovoltaic Systems)

Code Designation : 2361950-EN

8

Type Designation : H1Z2Z2-K
LEADER TECHNOLY (SHENZHEN)

Scope of Sizes : 2X2,5...10mm²

Rated Voltage : DC 1,5kV
AC 1,0/1,0kV

Ambient Temperature : -40°C to +90°C

Max. Temperature at Conductor : 120°C

8



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

Kenny Shi

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 911 806-3935



Product Service

C E R T I F I C A T E

No. B 105361 0003 Rev. 00

**Holder of Certificate: LEADER TECHNOLOGY
(SHENZHEN) CO., LIMITED**

Flat/Rm 1402b 14f

The Belgian Bank Building Nos.721-725 Nathan Road
999077 KowLoon
HONG KONG**Certification Mark:****Product:****Electric Cables****Electric cables for photovoltaic systems
with a voltage rating of 1,5 kV DC****Model(s):****62930 IEC 131 1x2.5mm², 1x4mm², 1x6mm², 1x10mm²
1x16mm², 1x25mm², 1x35mm²****62930 IEC 131 2x2.5mm², 2x4mm², 2x6mm², 2x10mm²
2x16mm², 2x25mm², 2x35mm²****Parameters:**

Rated Voltage:	DC 1500V (between conductors and between conductor and earth) AC U ₀ / U : 1.0/1.0 kV
Application Class:	A
Protection Class:	II
Ambient Temperature:	-40°C ~ +90°C
Max. Temperature at conductor:	120°C

Tested according to: IEC 62930(ed.1)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262211702-00
Valid until: 2027-07-11

Date, 2022-11-17

(Yaqun Alex Liu)

CERTIFICATE OF COMPLIANCE

Certificate Number E518364
Report Reference E518364-20201019
Issue Date 2020-OCTOBER-19

Issued to: LEADER TECHNOLOGY SHENZHEN CO LIMITED
FLAT/RM 1402B 14/F THE BELGIAN BANK BUILDING
NOS.721-725 NATHAN ROAD MONGKOK, KL, HONG
KONG

**This certificate confirms that
representative samples of**

PHOTOVOLTAIC WIRE
PV Wire


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 4703 - Photovoltaic Wire;
UL 44 - Thermoset-Insulated Wires and Cables
Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





ISET S.r.l. Unipersonale

Sede Legale e Uffici
Via Donatori di sangue, 9 - 46024 Moglia (MN)
Tel. e fax +39 (0)376 598963
www.iset-italia.com commerciale1@iset-italia.com

Cap. soc. i.v. € 10.200,00
Cod. Fisc. e P.IVA Reg. Imprese 02 332 750 369
REA 02 332 750 369
Cap. soc. i.v. MN 0221098

CERTIFICATE

Certificat - Certificado- Сертификат - Zertifikat - 證書

- 1) **APPLICANT:** (who finally puts the product on the market)
LEADER TECHNOLOGY SHENZHEN CO.,LIMITED
FLAT/RM1402B,14/F, THE BELGIAN BANK BUILDING NO5.721-725 NATHAN RD, MONGKOK KL,HK
- 2) **CERTIFICATE NO.:** ISETC.000320210409
TECHNICAL REFERENCE: TCF210406186CPR
- 3) **ISET MARK:**



- 4) **CAUTION ABOUT CE MARKING** (Instruction for the Applicant who puts the product on the EU market):



The label of the CE Marking on the left side should be not less than 5mm height. CE Marking and EC Declaration of Conformity are duties for the manufacturer or its applicant who puts the product on the market. This one is responsible to start the CE marking and certification procedure as required by the legislation in force. Only for the products which are compulsorily included into specific Directives or Regulations will be necessary to appoint a Notified Body.

- 5) **TYPE OF PRODUCT:** Solar Pv Cable
TRADE MARK: LEADER
MODEL(S): LEADER H1Z2Z2-K1*2.5mm², 1*4mm², 1*6mm², 1*10mm², 1*16mm²,
1*25mm², 1*50mm², 2*2.5mm², 2*4mm², 2*6mm², 2*10mm², DC1500V/AC1000V
- 6) **LIST OF DIRECTIVES / REGULATIONS /STANDARDS** (as declared by the manufacturer itself)
Construction products Regulation (EU) No 305/2011
EN 50575:2014+A1:2016
- 7) **NOTE:** This document is not referred to any evaluation that could be considered as included in the scope of the activities covered by the standard BS EN ISO/IEC 17065:2012 or European Regulation 765/2008.
- 8) **REMARK:** Certificate is issued on voluntary application from the Client and it gives to the applicant the right to use and affix the ISET Mark on their products, even if it doesn't imply any assessment on the safety and compliance of the product. ISET declares that the only scope of the assessment is to verify the existence of the declaration issued by the manufacturer or an applicant under its own responsibilities.
- 9) **DATE OF ISSUE:** 09/04/2021
- 10) **SIGNATURE:** Xiao Ming
(On behalf of the Legal representative)

EXPIRY DATE: 08/04/2026



Certificate of constancy of performance

according to Regulation (EU) No. 305/2011



Certificate No.: 1008-CPR-MC 69266496 0001

Report No.: HU23VN4S 001

Applicant: Leader Technology (Shenzhen) Co., Limited.
Flat/Rm 1402b 14f The Belgian Bank Building Nos. 721-725
Nathan Road, Mongkok, Hongkong, China

Manufacturer: Leader Technology (Shenzhen) Co., Limited.
Flat/Rm 1402b 14f The Belgian Bank Building Nos. 721-725
Nathan Road, Mongkok, Hongkong, China

Manufacturing plant: Leader Technology (Shenzhen) Co., Limited.
No. 24, Hexing Road, Fifth Industrial Zone, Xiegang Town,
Dongguan Guangdong, P.R. China

Product: Photovoltaic Cable (PV) family

Identification: H1Z2Z2-K 1x2,5...35 mm²

Intended use: Cables for Communication Systems

FPC Report No.: HU233Z3X 001

**System of assessment
and verification:** 1+

Tested according to: EN 50575:2014+A1

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2023-01-26 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:

Budapest, 2023-01-30

A handwritten signature in blue ink, appearing to read 'János' or 'Ferencne Schmidt'.

Ferencne Schmidt

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

Annex to certificate No. 1008-CPR-MC 69266496 0001

Page 1/1

Azonosító / Identification	Védjegy / Trade Mark	Tűzvédelmi Osztály / Reaction to Fire classification
H1Z2Z2-K 1×2,5 mm ²	Leader	C _{ca} -s1a,d1,a1
H1Z2Z2-K 1×4 mm ²	Leader	C _{ca} -s1a,d1,a1
H1Z2Z2-K 1×6 mm ²	Leader	C _{ca} -s1a,d1,a1
H1Z2Z2-K 1×10 mm ²	Leader	C _{ca} -s1a,d1,a1
H1Z2Z2-K 1×16 mm ²	Leader	C _{ca} -s1a,d1,a1
H1Z2Z2-K 1×25 mm ²	Leader	C _{ca} -s1a,d1,a1
H1Z2Z2-K 1×35 mm ²	Leader	B2 _{ca} -s1a,d0,a1


Certification Body
Date of issue:

Budapest, 2023-01-30


 Ferencne Schmidt