



ORGANISMUL DE CERTIFICARE
PRODUSE ICȘP "INMACOMPROIECT" SRL

MD 2015, mun. Chișinău, str.Sarmizegetusa, 15, tel:+37322522066



CERTIFICAT DE CONFORMITATE a controlului producției în fabrică

OCpr-018 11A 1669-22

BETOANE

Clase: C8/10 X0; C12/15 X0, C16/20 X0, C20/25 XC1, C25/30 XC2 XF2,
C30/37 XC3 XF3

Domeniu de utilizare: fabricarea structurilor turnate "in situ", structurilor prefabricate,
elementelor de structură, prefabricate pentru clădiri și structuri de geniu civil.

Fabricate de:

S.R.L. "BETACON PLUS"

Republica Moldova, UTA Găgăuzia, mun.Comrat, str.Lenin, 2

Acest certificat atestă:

îndeplinirea tuturor prevederilor privind controlul producției specificate în articol 9
a standardului

SM EN 206:2013+A2:2021, Cod Practic CP H.04.04:2018

Schema de certificare a produsului:

Schema 3 (schema 3 din SM SR EN ISO/CEI 17067:2014)

"Selecția, determinarea caracteristicilor, prin încercări, inspecție, evaluarea proceselor, analiza prin examinarea dovezilor de conformitate obținute în etapa de determinare, decizia referitoare la certificare, acordarea, menținerea, extinderea, restrângerea, suspendarea, retragerea certificării, emiterea certificatului. Supravegherea periodică o dată pe an și prelevarea probelor punctuale din fabrică pentru încercările din producția curentă o dată la 6 luni."

Valabilitatea certificatului este condiționată de efectuarea supravegherii confirmată prin rapoartele rezultate și de reevaluarea completă la recertificarea acestuia înainte de expirarea perioadei de valabilitate (3 ani).

Certificatul poate fi suspendat sau retras, dacă se constată că nu se mențin condițiile în baza cărora a fost emis.

Certificatul rămâne valabil dacă nu sunt modificate semnificativ: documentele de referință, metodele de evaluare a condițiilor de fabricație și caracteristicile declarate.

Valabilitatea certificatului este condiționată de efectuarea supravegheților anuale la data de:

09- 09-
2023 2024


Data emiterii: 23.09.2022
Data expirării: 23.09.2025

№ 00191

Conducătorul organismului



E.Oprea



认证证书



QUALITY MANAGEMENT SYSTEM CERTIFICATE

Registration No. D35011803104DR2M

This is to certify that the quality management system of
SHAHE CITY FANGYUAN CASTING CO., LTD.

WEST OF NANGAO VILLAGE SHAHE CITY, 054100

Social Credit Code: 91130582752415989W

is in conformity with

GB/T 19001-2016 / ISO 9001:2015 Standard

This certificate is valid to the following product (s)
DUCTILE IRON MANHOLE COVER AND GULLY GRATE MANUFACTURE AND
SERVICE (Site Covered: WEST OF NANGAO VILLAGE SHILITING TOWN SHAHE
CITY XINGTAI CITY HEBEI PROVINCE CHINA).


Date of issue: September 15, 2018

Date of expiry at most: September 14, 2021

Representative: *Wang Honglin*



(ZIL Tower 2, Jiyuan Plaza, No. 9
Shangdi 2 St., Haidian, Beijing)



中国认可
国际互认
管理体系
MANAGEMENT SYSTEM
CNASC035-M

NOTE: This certificate shall be maintained by regular surveillance audit.
The validity of the certificate can be verified by scanning QR code.



Сертификат Прием. люк.

KIG TECH

www.kig-tech.com

Test Report

600manhole cover

Test items	Technical requirement	Test Result	Result
Exterior	The surface should be complete, the material should be uniform, and there should be no defects affecting the use. Keep the top flat, the upper surface should not have camber, and the contact surface between the cover and the seat should be flat and smooth.	Meet	OK
Anti-skid pattern height (mm)	≥ 2	2.2	OK
Elevation angle ($^{\circ}$)	≥ 100	135	OK
Dive deep (mm)	≥ 40	42	OK
Support surface width (mm)	≥ 24	25	OK
Ground support strength (N/mm ²)	≥ 7.5	8.2	OK
Compatibility of cover and seat	It should be quiet and stable during use	Meet	OK
Manhole size deviation (mm)	± 10	+2	OK
Test load	15KN should be non-destructive	Meet	OK
Residual deformation (mm)	≤ 1	0.2	OK
	blank below		

Test date: 5/5/2022



Xi'an KIG Technology Co., Ltd
No.1 building, Saigao Guoji, Weiyang Economic-Technological
Development Area, Xi'an city, Shaanxi, China

☎ +86 29 62577373 📞 +86 15929725176

110x 250

HEBEI YONGQIAN TRADING CO.,LTD.									
TEST REPORT									
COMMODITY	MATERIAL	OVERALL BASE	CLEAR OPENING	DEPTH	WEIGHT	SAMPLE CLASS			
MANHOLE COVER	DUCTILE IRON GGG50	Φ684MM	Φ600MM	93MM	37.0KG	EN124 C250			
MECHANICAL PROPERTY REPORT									
ITEM	MATERIAL	FURNACE	LADLE	TENSILE STRENGTH/m ²	ELONGATION %	HARDNESSHB	LOAD REQUESTED	LOAD TESTED	REMARKS
MANHOLE COVER	GGG50	7	4	521	8.2	186	250KN	280KN	NO CRACK
MICROSTRUCTURE TEST REPORT (100TIMES)									
ITEM	MATERIAL	FURNACE	LADLE	GRAPHITE SHAPE	GRAPHITE SIZE mm	FERRITE	PERALITE	REMARKS	
MANHOLE COVER	GGG50	7	4	95% ROUND SPHERE	3mm	32	68		
CHEMICAL ANALYSIS REPORT									
ITEM	MATERIAL	FURNACE	LADLE	C	Si	MN	S	P	
MANHOLE COVER	GGG50	7	4	3.75	2.75	0.53	0.023	0.043	

Test conducted: BS EN124:1994 Gully Tops and manhole tops for vehicular and pedestrian areas-Design requirements, type testing, marking, quality control.

BUYER: _____ Note: This is our factory sample Date of inspection: JAN 05, 2023 Inspector: YONG QIAN

WE HEREBY CERTIFY THAT THE MATERIAL DESCRIBED HEREIN HAS BEEN MADE IN ACCORDANCE WITH THE ABOVE SPECIFICATION AND WITH THE REQUIREMENT CALLED FOR BY THE ABOVE ORDER AND HAS BEEN TESTED TO THE SATISFACTION OF THE MANUFACTURER'S Q.C. INSPECTOR.

河北勇乾贸易有限公司
 HEBEI YONGQIAN TRADING CO., LTD