

WEIDMANN

QUALITY CERTIFICATE # 25

Description of goods

Cable paper K – 120

Date of manufacture 02.2023

Date of shipment

Lot №	27	
Technical data:		
Index	Norm	Average data on a lot
1 Thickness, mkm	120±7	118
2 Apparent density, g/cm³	0,78±0,05	0,83
3 Tensile force, N, minimum		
- in machine direction	128	179
- in cross direction	59	86
4 Elongation at break, %, minimum		
- in machine direction	2,0	3,3
- in cross direction	4,5	6,4
5 Air permeability, cm³/min, maximum	40	20
6 Ash, %, maximum	1,0	0,3
7 Conductivity of aqueous extract, mkS/cm, maximum		
- 1:50	60	16
- 1:20	120	40
8 pH of aqueous extract, pH units	7,0 - 9,0	7,0
9 Moisture content, %, maximum	8	4

Products manufactured under controlled conditions established ISM certified (ISO 9001, ISO 14001, ISO 45001) Certification # 4410019320266, # 4410419320266, # 4412619320266.

Laboratory engineer	Lida Kyrychenko Digitally signed by: Lida Kyrychenko DN: CN = Lida Kyrychenko email = lida.kyrychenko@weidmann-group.com OU = _WICOR, Users, UKRML_WMPPM Date: 2023.03.02 13:35:07 +02'00'
---------------------	--

PrJSC "Weidmann-MPM"
66 Prykhodko Street. 11602, Malyn. Zhytomyr region. Ukraine
T +380 4133 67 222, F+380 4133 53 343, www.weidmann-electrical.com

A Member of the Wicor Group