



Number	KIP-15438/G	Replaces	-
Issued	19-12-2017	Scope	Directive 2009/142/EC
Report	2001134/3	Page	1 of 1
PIN	0476CS1134		

## EC TYPE EXAMINATION CERTIFICATE

**Kiwa Cermet Italia hereby declares that the product**

Central heating condensing boilers

Trade mark: **ROMSTAL**  
 Models: HABITAT 25 K, HABITAT 30 K, HABITAT 35 K, HABITAT 25 KR, HABITAT 35 KR  
 Manufactured for **S.C. ROMSTAL IMEX S.R.L.**  
 Bucuresti, sos.  
 Vitan-Barzesti, nr.11A, sector 4  
 Romania

meet the essential requirements as described in the  
**Directive on appliances burning gaseous fuels 2009/142/EC**

Mentioned products have been approved for

Appliance type: B<sub>23</sub>, B<sub>23P</sub>, B<sub>53</sub>, B<sub>53P</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>, C<sub>93</sub>

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Related to the following gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	Esi	20/25	E(R)	20
H	20;25	E(S)	20	M	20
L	25	Er	20/25	P	30; 37; 50



The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012+A1:2015  
 EN 15502-2-1:2012+A1:2016

*The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it  
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive, as well as on updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia*

Chief Operating Officer  
 Giampiero Belcredi

Organismo Notificato n. 0476

**Kiwa Cermet Italia S.p.A.**  
 Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl  
 Via Cadriano, 23  
 40057 Granarolo dell'Emilia (BO)  
 Unità locale  
 Via Treviso 32/34  
 31020 San Vendemiano (TV)  
 Tel +39. 0438 411755  
 Fax +39.0438 22428  
 E-mail: info@kiwacermet.it  
 www.kiwa.it  
 www.kiwacermet.it

Certificato