



Product Service

Attestation of Conformity

No. D6 001466 0003 Rev. 00

Holder of Attestation: Zhejiang Taifu Pump Co.,Ltd

Southeast Industrial Zone Songmen Town
317511 Wenling City, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product:

**Circular Pumps
Circulation pump**

Model(s):

STAR40/10F, RGN 40FX

Parameters:

Rated voltage:	230VAC
Rated frequency:	50/60Hz
Rated input power:	345W
Protection class:	I
Degree of protection:	IP 42
Rated Head:	5.5m
Rated Flow:	9.0m ³ /h
Declared EEI:	Less than 0.23

Implementation Measure EC Regulation

No 641/2009:22.07.2009

amended by (EC) 622/2012:11.07.2012, (EU) 2016/2282:2016-11-30

Stage 2 (01 Aug. 2015)

**Tested
according to:**

PPP 11093D:2017

EN 16297-1:2012

EN 16297-2:2012

EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to TÜV SÜD PRODUCT SERVICE GMBH for testing and evaluation and to its technical documentation. See also notes overleaf.

Test report no.:

7040118124401-01

Date, 2018-12-27

(Lucy Lu)