

NATIONAL INSTITUTE OF PUBLIC HEALTH

- National Institute of Hygiene

Environmental Hygiene Department

HYGIENIC CERTIFICATE

HK/K/0944/01/2016

Product: **Modular diffusers with laminar flow outflow type ALF: (ALF-1 / 1,1 / 2,1 / 3,1 / 4, 1/5, 1/6, 2/2, 2/3, 2/4, 2/5 , 3/3, 3/4, 3/5, 4/4, 4/5, 5/5); Hygienic drying grates**

Containing: stainless steel, other components according to manufacturer's documentation

Destined for: application in health care (including: operating theater rooms, intensive care units), veterinary medicine, laboratories, pharmaceutical and cosmetics industry, sanitary and hygienic rooms, aseptic rooms

The above product is acceptable according to hygienic criteria with the following conditions:

- The use of products must comply with the regulations for the facility in which they are installed
- Hygienic Certificate does not cover filters used in ALF laminar diffusers
- Silver ions cannot be released into the room air
- In case of using ALF laminar diffusers in operating rooms, they cannot contain PVC curtain strips
- Installation and operation in accordance with the manufacturer's instructions

Hygienic certificate does not apply to technical parameters and utility value of the product

Producer ALVO Spółka z ograniczoną odpowiedzialnością Sp. k.

64-030 Śmigiel, ul. Południowa 21

This certificate was issued for ALVO Spółka z ograniczoną odpowiedzialnością Sp. k.

64-030 Śmigiel, ul. Południowa 21

The certificate may be corrected or cancelled after appropriate motivation. The certificate loses its validity after 2021-09-13 or in the case of changes in composition or in technology of production.

The date of issue of the certificate: 13<sup>th</sup> of September 2016

Manager of the Environmental Hygiene Department, dr Bożena Krogulska

Contact regarding this hygienic certificate: Department of Environmental Hygiene NIPH-NIH  
e-mail: [sek-zhk@pzh.gov.pl](mailto:sek-zhk@pzh.gov.pl) tel.+48 22 54-21-354, +48 22 54-21-349, fax: +48 22 54-21-287