

CPRI

TEST REPORT



Central Power Research Institute
(A Govt. of India Society)
Medipally P.O., Warangal Road,
Hyderabad – 500 098 (INDIA)

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

CPRI

Test Report Number	:	CPRIHYDUHVMISC24T0079	Date: 01 April 2024
Name and Address of the Customer	:	M/s. CG Power and Industrial Solutions Limited, D-2, MIDC, Waluj, Aurangabad-431136, Maharashtra State, India	
Name and Address of the Manufacturer	:	M/s. CG Power and Industrial Solutions Limited, D-2, MIDC, Waluj, Aurangabad-431136, Maharashtra State, India	
Particulars of sample tested	:	132 kV Inductive Voltage Transformer	
Type	:	VEOT:145/650/50	
Description of test sample	:	132 kV Inductive Voltage Transformer	
Serial Number	:	234656	
Number of samples tested	:	One	
Date(s) of test(s)	:	22 March 2024 to 23 March 2024	
CPRI Sample Code number(s)	:	UHV24S0073	
Particulars of test conducted	:	Refer sheet 3 of 7	
Test in accordance with Standard/ Specification	:	IEC 61869-1: 2007 and IEC 61869-3: 2011	
Sampling plan	:	Not applicable	
Customer's requirement	:	Short circuit withstand capability test to be performed on 3a-3n secondary winding	
Deviations, if any	:	Nil	
Name of the witnessing persons	:	Mr. Gajanan Khadke	
Customer representatives	:	Nil	
Other than customer's representatives	:	Nil	
Test subcontracted with address of the laboratory	:	None	
Documents constituting this report (in words)			
Number of Sheets(s)	:	Seven	
Number of Oscillogram(s)	:	One	
Number of Graph(s)	:	Nil	
Number of Photograph(s)	:	Nil	
Number of Test circuit diagram(s)	:	Two	
Number of Drawing(s)	:	Two	


(B. Krishna)
Test Engineer




(K. Devender Rao)
Joint Director

Reviewed and Authorized by

Sheet 1 of 7

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

CPRI

Test Report Number: CPRIHYDUHVMISC24T0079

Dated: 01 April 2024

DESCRIPTION OF SAMPLE TESTED
(As assigned by the manufacturer)

145 kV Inductive Voltage Transformer

Rated primary voltage (U_{pr}) : 132 / $\sqrt{3}$ kV_{rms}
 Highest system voltage (HSV) : 145 kV_{rms}
 Frequency : 50 Hz
 Insulation Level : 275 kV_{rms} / 650 kV_p
 Voltage factor : 1.2 continuous and 1.5 for 30 seconds

Rated secondary voltage (V)	Terminal marking	Burden (VA)	Accuracy class
110 / $\sqrt{3}$	1a – 1n	200	3P
110 / $\sqrt{3}$	2a – 2n	50	3P
110 / $\sqrt{3}$	3a – 3n	50	0.5


 (B. Krishna)
 Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

CPRI

Test Report Number : CPRIHYDUHVMISC24T0079

Date: 01 April 2024

SUMMARY OF TEST CONDUCTED

1. Tests conducted	:	Routine, type and special tests
2 Rating for which tested	:	132 kV _{mA}
3. Schedule of test results		

Tests conducted	Clause Number and Standard	Sheet Number
Short circuit withstand capability test	7.2.301 of IEC 61869-3:2011	4 of 7
Test for Accuracy after short circuit withstand capability test	7.2.6 of IEC: 61869-5:2011	5 & 6 of 7

4. Oscillogram Numbers	:	CPRIHYDUHVMISC24T0079S001
5. Graph Numbers	:	Nil
6. Photograph Numbers	:	Nil
7. Test Circuit Diagram Numbers	:	CPRIHYDUHVMISC24T0079TCD01 and CPRIHYDUHVMISC24T0079TCD02

Drawing Numbers

The manufacturer has guaranteed that the sample submitted for the test(s) has been manufactured in accordance with the following drawings:

Sl. No.	Drawing Number	Sheet Number	Revision Number
1	413695829 IVT4900 GA/R0	---	---
2	413695829 IVT4900 RS_R0	---	---

It is verified that these drawings adequately represent the sample tested. Verification of these drawings by CPRI is limited to dimensional check only wherever possible.


(B. Krishna)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRIHYDUHVMISC24T0079

Date: 01 April 2024

TEST RESULTS

Test: Short circuit withstand capability test (As per clause 7.2.301 of IEC 61869-3:2011)

Test condition	:	Under dry condition
Test frequency	:	50 Hz
Ambient conditions	:	
Dry bulb temperature	:	30 °C
Wet bulb temperature	:	25 °C
Atmospheric pressure	:	95.06 kPa

Test procedure: The power frequency AC voltage applied on the primary terminal of the IVT. Terminals N, 1n and 2n were connected to earth along with the tank. The secondary winding terminals 3a – 3n were shorted for duration of 1 s at rated primary voltage (U_{pr}) i.e., 76.2 kV_{ms} using contactor. The secondary current was measured using a CT of 150 / 5 A ratio along with a burden of 10 Ω connected across CT secondary. The primary voltage, secondary voltage and the secondary current through 3a – 3n were recorded using a four channel PicoScope. It is indicated as upper, middle and lower traces, respectively in the oscillogram no. CPRIHYDUHVMISC24T0079S001

Observations:

1. No physical damage was observed to the IVT after the test
2. No examination of insulation next to surfaces of primary and secondary windings was conducted, as the current density in the secondary winding calculated from the measured symmetrical short-circuit current in the secondary winding was less than 180 A / mm²


(B. Krishna)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

CPRI

Test Report Number : CPRIHYDUHVMISC24T0079

Date: 01 April 2024

TEST RESULTS

Test: Test for Accuracy after short circuit withstand capability test (7.2.6 of IEC 61869-3: 2011)

Test condition : Under dry condition
Test frequency : 50 Hz

Ambient conditions :
Dry bulb temperature : 29°C
Wet bulb temperature : 24°C
Atmospheric pressure : 94.92 kPa
1. Primary voltage : 132 / $\sqrt{3}$ kV_{rms}
2. Secondary voltage : 110 / $\sqrt{3}$ V_{rms}

Secondary winding under test	Burden (VA)	Test Voltage in percentage of primary voltage (%)	Voltage (Ratio) Error (%)	Phase Displacement (Minutes)	Remarks
1a – 1n Accuracy class: 3P PF: 0.8 (lag)	200	150	-0.446	11.06	The winding is within limits of voltage ratio error ($\pm 3\%$) and phase displacement (± 120 minutes) as specified in the standard
		120	-0.266	4.77	
		100	-0.217	3.01	
		5	-0.235	3.18	
		2	-0.242	3.42	
	50	150	-0.0907	8.55	
		120	0.0748	3.11	
		100	0.1362	0.763	
		5	0.1206	0.633	
		2	0.1187	0.723	

Secondary winding under test	Burden (VA)	Test Voltage in percentage of primary voltage (%)	Voltage (Ratio) Error (%)	Phase Displacement (Minutes)	Remarks
2a – 2n Accuracy class: 3P PF: 0.8 (lag)	50	150	-0.0649	9.52	The winding is within limits of voltage ratio error ($\pm 3\%$) and phase displacement (± 120 minutes) as specified in the standard
		120	0.0873	3.38	
		100	0.1368	1.349	
		5	0.1219	1.046	
		2	0.1193	1.526	
	12.5	150	0.0202	9.02	
		120	0.1769	2.71	
		100	0.226	0.670	
		5	0.217	0.069	
		2	0.219	0.012	


(B. Krishna)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



TEST REPORT

CPRI

Test Report Number : CPRIHYDUHVMISC24T0079

Date: 01 April 2024

TEST RESULTS

1. Primary voltage : $132 / \sqrt{3}$ KV_{rms}
 2. Secondary voltage : $110 / \sqrt{3}$ V_{rms}

Secondary winding under test	Burden (VA)	Test Voltage in percentage of primary voltage (%)	Voltage (Ratio) Error (%)	Phase Displacement (Minutes)	Remarks
3a – 3h Accuracy class: 0.5 PF: 0.8 (lag)	60	120	0.1317	2.93	The winding is within limits of voltage ratio error ($\pm 0.5\%$) and phase displacement (± 20 minutes) as specified in the standard
		100	0.1748	0.055	
		80	0.1823	0.486	
	12.5	120	0.203	2.57	
		100	0.244	0.557	
		80	0.252	0.152	

Conclusion: Test sample tested complies with the requirement of clause no. 7.2.301 & 7.2.6 of 61869-3: 2011 and customer request for the tests conducted.


 (B. Krishna)
 Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number. CPRIHYDUHVMISC24T0079

Date: 01 April 2024

NOTE

- a) The Test results relate only to the sample(s) tested.
- b) Publication or reproduction of this Test Report /Test Certificate in any form other than by complete set of the whole Test Report /Test Certificate and in the language written is not permitted without the written consent of CPRI.
- c) Any Corrections/erasure invalidates the Test Report/Test Certificate
- d) NABL has Accredited this laboratory as per ISO/IEC17025:2017, vide certificate no.TC-6198 for the tests carried out.


(B. Krishna)
Test Engineer

-----End of Test Report-----

CENTRAL POWER RESEARCH INSTITUTE




CPRI

Test Report Number. CPRIHYDUHVMISC24T0079

Date: 01 April 2024

TEST CIRCUIT DIAGRAMS

1. Short-circuit withstand capability test & Ferro-resonance check




Legend:

1: HV AC source	2: Protective Resistor	3: Voltage divider	4: Test Sample
5: Burden (10 Ω)	6: 150 / 5 A CT	7: RMS voltmeter	8: Contactor
9: 4 Channel digital storage oscilloscope			

Test Circuit Diagram Number. CPRIHYDUHVMISC24T0079TCD01

2. Test for accuracy



Legend:

1: HV AC Source
2: HV Divider
3: Voltmeter
4: IVT under test
5: Standard Capacitor with LV arm
6: Burden
7: Automatic instrument transformer test set with electronic potential divider

Test Circuit Diagram Number: CPRIHYDUHVMISC24T0079TCD02


(B. Krishna)
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE




TEST REPORT

CPRI

Test Report Number. CPRIHYDUHVMISC24T0079


Date: 01 April 2024

OSCILOGRAM



Oscillogram Number: CPRIHYDUHVMISC24T0079S001


(R. Krishna)
Test Engineer



TECHNICAL SPECIFICATIONS 132 KV INDUCTIVE VOLTAGE TRANSFORMER

ITEM NO.	QTY.	DESCRIPTION	MATERIAL
1	1	PRIMARY TERMINAL - Ø30x80 (Min.)	COPPER
2	1	TANK	ALUMINUM CAST
3	1	PORCELAIN INSULATOR	PORCELAIN BROWN COLOUR
4	1	RATING & SCHEMATIC DIAGRAM	ALUMINUM
5	1	SECONDARY TERMINAL BOX	ALUMINUM CAST

NOTE :

- 1) PRIMARY WINDING NO OF TURNS : 37120
- 2) CROSS SECTION AREA OF PRIMARY WIDING : 38 SWG. (0.01824 Sq.mm)
- 3) SECONDARY WINDING :

NO.OF WINDING	NUMBER OF TURNS	SWG/Sq.mm
WINDING-I	31	(14x2)/6.48
WINDING-II	31	(14x2)/6.48
WINDING-III	31	(14x4)/12.97

- 4) CORE MATERIAL : CRGO M4



SECTIONAL SIDE VIEW

FRONT VIEW

परीक्षण इंजीनियर
पूर्णवीआरएल, राष्ट्रीयउत्तराहार्द
हेदराबाद
Test Engineer
UHYURL, CPRI,
HYDERABAD

Dimensions shown are tentative and may change during detailed design engineering.

IF IN DOUBT ASK

NO.	REVISION	SIGN DATE	SIGN	NAME	DRN	STJ	GENERAL ARRANGEMENT DRAWING
R6			R2				RR 12 KV INDUCTIVE VOLTAGE TRANSFORMER
R5			R3		CHD	SDS	RR 12 KV INDUCTIVE VOLTAGE TRANSFORMER

CC Power and Industrial Solutions Limited, Bangalore
DRG NO - 41165829 M4500 Q4/EO

