

STEELMET ROMANIA S.A.  
 42nd DRUMUL INTRE TARLALE STR.  
 032982 BUCHAREST 3rd SECTOR

**INSPECTION CERTIFICATE**
**Type 3.1 acc. EN 10204**
**Certificate No : 1000444792**
**DATE: 30.07.2020**
**Delivery No : 0085212664**

Customer	<b>STEELMET ROMANIA S.A.</b>		
Cust's Ref No	<b>OR095</b>	Cust's Part No	
Our Order No	<b>1200109106 / 30</b>	Quantity	<b>7.700,00 MTR</b>
		Inspection Lot	<b>020000631745</b>

Designation	<b>CuT m 012,700x0,64x50000 JJHBO XE09-17 R</b>		
according to	<b>EN 12735-1:2001,R220.</b>		
Material	<b>Cu-DHP</b>		
Chem. Anal.:	<b>CU&gt;99,90-P:0,015-0,040</b>	OK	

Characteristic	Unit of meas.	Specifications	Values	Sample No
ODav	mm	12,660 - 12,740	12,700 - 12,710	2
Smin	mm	>=0,576	0,610 - 0,640	2
Smax	mm	<=0,704	0,650 - 0,660	2
LENGTH	mm	>=50000	50000	2
OVALITY	mm	<=0,89	0,08 - 0,15	2
Rm	N/mm <sup>2</sup>	>=220,0	246,1 - 247,2	2
A50	%	>=40,0	51,8 - 52,9	2
EXPANSION	%	>=30,0	OK	2
C TOT. RES. IN.	mg/dm <sup>2</sup>	<=0,38	0,10 - 0,14	2
ECT EN 1971	%	100	OK	-

**DECLARATION OF COMFORMITY**

The products detailed above, conform to the conditions and requirements of the purchaser and to the description, quantities and spec. stated. The Quality Assurance System applied to monitor their production, complies with the requirements of ISO 9001:2015, independently certified by TÜV HELLAS, with certification No 041070119.

ISSUE: C

REV: 2

DATE: DEC. 2017

Athens

31.07.2020

Q.C. INSPECTOR

Q.A. MANAGER



D. SKARMOUTSOS

FORM N3

e-mail: info@halcor.com  
 website: www.halcor.com  
 VAT number: EL094061318

**Offices @ Copper Tube Plant (Mailing Address)**  
 62<sup>nd</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 48111, Fax: +30 22620 48911

**Foundry**  
 60<sup>th</sup> km Athens-Lamia National Road,  
 GR-32011 Inofita-Viotia, GREECE  
 Tel.: +30 22620 53479, Fax: +30 22620 53925

**Domestic Sales Dept**  
 252 Pireos str.  
 GR-17778, Tavros, Athens, GREECE  
 Tel.: +30 210 4898111, Fax: +30 210 4898397