



ATTESTATION Industrie Service
No. IS-SHA-272510 Rev.1

1. Name of the certificate holder: **BLUCAST JSC**

2. Pattern and Size of Product:

Ductile Iron Gate Valves for Water Supply,
Type PN16/DN40~DN600 with body material grade: EN-GJS-500-7 (QT500-7),
and construction dimension per DIN3352 series F4/ DIN3352 series F5.
As detailed in Drawing No.: JMP-F-RZF-F4_F5-50_600-00/01/02/03 dated 2012.11.06.

- The products comply with the requirements of EN 1074-2:2004

Taking into account the following survey carried out by the inspector from Shanghai Office:

- Satisfactory examination of the documents annexed to the Application for Type Approval.
- Satisfactory audit of the above mentioned manufacturer and issuance of the inspection Report No. 229997 and last annual report no.P-PRC-22-01-614638-001 dated on 2022-01-28 as well as refer to previous report no. 216724(first revision).
- Attendance to the satisfactory testing on samples prepared by manufacturer according to related standards.

TÜV SÜD Industrie Service GmbH certifies that the above company has been assessed for Type Approval of its product Ductile Iron Gate Valves for Water Supply, it is found that the products comply with the International Standard mentioned above.

This certificate is valid until January 27th, 2025 based its original certificate no.IS-SHA-229996 Rev.2 meantime it should be provided with annual surveillance audits by TÜV SÜD. It may be extended upon request.

1 st Surveillance		2 nd Surveillance	
Date:	Signature:	Date:	Signature:

At: Shanghai, P. R. China

For

On:  January 28th, 2022

