



INDEPENDENT LABORATORY FOR ELECTRICAL
TESTING MAREL,
VELIKO GOLOVODE bb, 37000 KRUŠEVAC, SERBIA

Tel/fax: 037 3566 262, 037 3566 266
www.marellaboratory.rs; e-mail: laboratory@marel.rs;
marellaboratory@gmail.com



EA MLA and ILAC MRA
Signatory

TYPE TESTING REPORT № 43.2/23

User: MAREL

Manufacturer: MAREL

Tested product - Cable lugs with shear bolts for voltage grade up to 42 kV
markings: BLMT-M 95-240 mm² M16

Catalog No
/ Data Sheet No:

375933

Room
temperature
& RH:

23°C ±3°C
55% ±5% RH

Shear head torque range
(Nm):

35 - 38

Sampled by
/ Date:

MAREL Lab / 24.11.2023.

Number of
pages:

22

Reference testing
documents:

SRPS EN 61238 – 1 – 3:2019/ EN 61238 – 1 – 3:2019

Class A Connector

Kruševac;

20.12.2023.

Date

Head of Laboratory

Miljana Milenković Nikolić

MAREL CEO

Vladimir Raičević




LIST OF CONDUCTED TESTS		TEST RESULT	TEST №
1. Mechanical test			
1.1	Mechanical test (SRPS EN 61238-1:2010 / EN 61238-1:20034:2009; clause 7)	PASS	43.2/23-01
2. Electrical test			
2.1	Electrical ageing test – Class A: heat cycles and short circuit test, (SRPS EN 61238-1:2010 / EN 61238-1:2003, clause 6)	PASS	43.2/23-02



INDEPENDENT LABORATORY FOR ELECTRICAL
TESTING MAREL,
VELIKO GOLOVODE bb, 37000 KRUŠEVAC, SERBIA

Tel/fax: 037 3566 262, 037 3566 266
www.marellaboratory.rs; e-mail: laboratory@marel.rs;
marellaboratory@gmail.com



EA MLA and ILAC MRA
Signatory

TESTING REPORT № 43.2/23

43.2/23-01

MECHANICAL TEST

TEST 1.1

User: MAREL

Manufacturer: MAREL

Tested product - Cable lugs with shear bolts for voltage grade up to 42 kV
markings: BLMT-M 95-240 mm² M16

Catalog № / Data Sheet №: 375933

Room temperature & RH: 22,1° C, 53% RH

Sampled by / Date: MAREL Lab / 24.11.2023.

Number of pages: 6

Cables used for test: ACSR 240 mm²

Sample № used for this test: 1 2 3

Reference testing documents: SRPS EN 61238 – 1 – 3:2019 / EN 61238 – 1 – 3:2019; clause 7

Kruševac; 27.11.2023.
Date

Head of Laboratory

Miljana Milenković Nikolić

MAREL CEO

Vladimir Raičević



Testing procedure:

The purpose of these tests is to ensure an acceptable mechanical strength for the connections to the conductors of power cables.

NOTE: The pull-out force does not give any reliable indication of the electrical quality of the connector.

The test shall be made on three additional connectors identical to those used for the electrical test. The connectors are fitted as for the electrical test of 6.1. The conductor lengths, between connectors or between connector and tensile test machine jaws, shall be ≥ 500 mm. The rate of application of the load shall not exceed 10 N per square millimeter of cross-sectional area and per second up to the value in Table 3, which is then maintained for 1 min.

If the connector is tested electrically for conductors with a different cross-sectional area, the different connectors shall be tested individually, in accordance with Table 1.

Table 1. Tensile forces (tolerance of applied forces is $\pm 5\%$)

Conductor material	Tensile force (N)
Aluminum	40 x A ^a ; maximum 20000
Copper	60 x A ^a ; maximum 20000

^a A = nominal cross-sectional area (mm²).

Equipment under test:

- **Connectors**

Table 2. - Connectors

Connector type (through, branch, terminal lugs)	Terminal connector
Type of jointing (crimping, mechanical, IPC)	Mechanical
Type of plating if applicable	Tinned Al



- **Conductors**

Table 3. - Conductors

Side 1 (Main) - Nominal cross section (mm²)	240	Al
Side 2 (Branch) - Nominal cross section (mm²)	/	/
Type of conductor (solid, stranded)	Stranded	
Shape of conductor (sectorial, circular...)	Circular	
Stranded conductor (compacted, non-compacted)	Compacted	
Stranded conductor (flexible, rigid)	Flexible	
Diameter of conductor (mm)	21,9	
Number of strands	26 / 7	
Diameter on insulation (mm)	Not applicable	
Material and thickness of insulation (only for IPC's)	Not applicable	
Maximum conductor temperature in normal operation (only for IPC's)	Not applicable	

- **Test arrangement**

Table 4. - Test arrangements

Preparation of contact surfaces	
Cable preparation before installation (dry brushing, brushing under neutral grease, no brushing...)	Brushing under neutral grease
Connector preparation (brushing contact palms for terminal lugs)	Not applicable
Connector installation	
Tooling (torque wrench, crimping dies, jack ...)	Torque wrench
Tightening torque for mechanical connectors (Nm)	35 - 38
Number of indents for crimped connector	Not applicable
Tightening torque on palms of terminal lugs (Nm)	Not applicable
Temperature of connector installation (C°)	22



Requirements:

No slipping shall occur during the last minute of the test.

Testing results:

Table 5. – Testing results

No	Main / Side 1 (mm ²)	Branch / Side 2 (mm ²)	Force 1 (N)	Slippage (mm)	Test score (Satisfactory / Unsatisfactory)	Examiner / Date
1	240	/	9600	0	Satisfactory	Dušan Radivojević
2				0	Satisfactory	Ivan Stanković
3				0	Satisfactory	27.11.2023.



EQUIPMENT USED FOR TESTING

№	Type	Model	Latest calibration
1	Torque wrench	Unior – Model 266	05.10.2023.
2	Hydraulics crimping press	Elmark	Calibration not needed
3	Tape measuring ruler 1m	Orion 0-1000 mm	13.05.2021.
4	Caliper with digital dial	Tesa / 0.002mm with digital dial	25.02.2021.
5	Stopwatch	JS-505A	17.05.2021.
4	Tensile machine with one axis dynamometer	Axis / Zemic FB20K/H3C3-3.0t-6B	24.03.2021.
5	Electrohydraulic tensioning system for cable accessories	AFS-MRL	
5.1	Load cell 1 (Axis 1)	HBM U10M/125 kN	24.03.2021.
5.2	Load cell 2 (Axis 2)	HBM U10M/125 kN	24.03.2021.
5.3	Weight 20 kg – 01	Marel	05.04.2022.
5.4	Weight 20 kg – 02	Marel	05.04.2022.
5.5	Thermocouple K1	ICS controller A10	18.04.2022.
5.6	Thermocouple K2	ICS controller A10	18.04.2022.
5.7	Thermocouple K3	ICS controller A10	18.04.2022.
5.8	Thermocouple K4	ICS controller A10	18.04.2022.
5.9	Test transformer	Amper KV T01	Calibration not needed



DECLARATION OF CONFORMITY FOR TESTS PERFORMED (by user request):

TESTED PRODUCT IS IN COMPLIANCE WITH TESTED STANDARD CLAUSE.

OPINIONS AND INTERPRETATIONS (by user request):

Head of mechanical testing procedure:

Milan Radojković


Head of electrical testing procedure:

Vladimir Rilak



INDEPENDENT LABORATORY FOR ELECTRICAL
TESTING MAREL,
VELIKO GOLOVODE bb, 37000 KRUŠEVAC, SERBIA

Tel/fax: 037 3566 262, 037 3566 266
www.marellaboratory.rs; e-mail: laboratory@marel.rs;
marellaboratory@gmail.com



EA MLA and ILAC MRA
Signatory

TESTING REPORT № 43.2/23

43.2/23-02

ELECTRICAL AGEING TEST

TEST 2.1

User: MAREL

Manufacturer: MAREL

Tested product - Cable lugs with shear bolts for voltage grade up to 42 kV
markings: BLMT-M 95-240 mm² M16

Catalog №
/ Data Sheet №: 375933

Room
temperature & RH: 22,5° C, 54%
RH

Sampled by
/ Date: MAREL Lab / 24.11.2023.

Number of
pages: 14

Sample № used
for this test: 4 5 6 7 8 9

Reference testing
documents: SRPS EN 61238 – 1:2010 / EN 61238 – 1:2003, clause 6
– Class A Connector

Kruševac; 04.04.2023.
Date

Head of Laboratory

Miljana Milenković Nikolić

MAREL CEO

Vladimir Raičević



Testing procedure:

There are six (6) connectors in test loop, connectors are installed on appropriate conductors. They are subjected to 1 000 cycles of heating and cooling with alternate current. Test is done in compliance with EN 61238-1 standard.

Equipment under test:

- **Connectors**

Table 1. - Connectors

Connector type (through, branch, terminal lugs)	Terminal connector
Type of jointing (crimping, mechanical, IPC)	Mechanical
Type of plating if applicable	Tinned Al

- **Conductors**

Table 2. - Conductors

Side 1 (Main) - Nominal cross section (mm²)	240	Al
Side 2 (Branch) - Nominal cross section (mm²)	/	/
Type of conductor (solid, stranded)	Stranded	
Shape of conductor (sectorial, circular...)	Circular	
Stranded conductor (compacted, non-compacted)	Compacted	
Stranded conductor (flexible, rigid)	Flexible	
Diameter of conductor (mm)	21,9	
Number of strands	26 / 7	
Diameter on insulation (mm)	Not applicable	
Material and thickness of insulation (only for IPC's)	Not applicable	
Maximum conductor temperature in normal operation (only for IPC's)	Not applicable	



- **Test condition**

Table 3. - Test Conditions

Test loop by figure	1a
Total number of cycles	1000
Class	A
Heating time used (min)	33
Cooling time used (min)	14
Pause time used (min)	4
Current value of heating start (A)	760
Equilibrium heating current I_N (A)	720
Median connector number	8
Median connector temperature at 1 st adjusting cycle on reference cable (C°)	72,4
Reference cable temperature at 2 nd heating cycle (C°)	117,9
DC current for resistance measurement (A)	36
Number of cycles before short circuit	200
Number of short circuits	6
Initial θ of reference cable (C°)	22,8
Final θ of reference cable (C°)	118,6
Required short-circuit vale (s)	4,5
Theoretical short-circuit current value (A)	9160


The adjustments of temperatures and currents are carried out in accordance with clause 6.3 of the standard.



- **Test arrangement**

Table 4. - Test arrangements

Preparation of contact surfaces		
Cable preparation before installation (dry brushing, brushing under neutral grease, no brushing...)		Brushing under neutral grease
Connector preparation (brushing contact palms for terminal lugs)		Not applicable
Connector installation		
Tooling (torque wrench, crimping dies, jack ...)		Torque wrench
Tightening torque for mechanical connectors (Nm)		35 - 38
Number of indents for crimped connector		Not applicable
Tightening torque on palms of terminal lugs (Nm)		Not applicable
Temperature of connector installation (C°)		22
Testing circuit		
Equalizers type used (welded, crimped, mechanical ...)		Welded
Virtual length of connectors: l_i (mm)		112 / Not applicable
Minimum distance between equalizers and test loop connection l_r (Al) / l_r (Cu) (l_r (main) / l_r (branch)) (mm)		700 / Not applicable
Distance d between connectors (mm)		1230
Distance between equalizers and connectors	l_a (mm)	230
	l_b (mm)	Not applicable
Characteristic of linking bars between lugs if used	Nature	Not applicable
	Cross section (mm ²)	Not applicable
	Length (mm)	Not applicable
	Width (mm)	Not applicable
	Thickness (mm)	Not applicable



1. temperature axis
2. reference conductor temperature θ_R
3. median connector temperature
4. temp. ≤ 35 °C for connectors and reference conductors
5. time axis

Diagram 1. – Second heating cycle




Figure 1a – Through connectors




Figure 1b – Terminal lugs

where

$d \geq 80 \sqrt{A}$ or 500 mm, whichever is the greater

A is the corresponding conductor cross-sectional area, in mm^2

$l_f \geq l_a + l_b + l_j$ (for l_j , see Figure 3)


For stranded conductors:

$l_a, l_b = 15 \sqrt{A}$ or 150 mm, whichever is the greater

Key

- 1 reference conductor
- 2 equalizers (for stranded conductors)
- 3 through connectors
- 4 terminal lugs
- 5 linking bars

Figure 1. – Typical test circuit for through connectors and terminal lugs



where

$d \geq 80 \sqrt{A}$ or 500 mm, whichever is the greater

A is the main conductor sectional area, in mm²

$\ell_r, \ell_{rb} \geq d$

For stranded conductors:

$\ell_a, \ell_b \approx 15 \sqrt{A}$ or 150 mm, whichever is the greater

NOTE For IPC ℓ_a, ℓ_b may be increased if necessary.

Key

- 1 main reference conductor
- 2 branch reference conductor
- 3 equalizer (for stranded conductors)
- a branch connector
- c current control;
- Sw switch (for branch resistance measurement)

Figure 2. – Typical test circuit for branch connectors

* Test loop by figure 1a.

Requirements:

Table 5. – Requirements


Parameter	Maximum value
Initial scatter δ	$\leq 0,3$
Mean scatter β	$\leq 0,3$
Change in resistance factor D	$\leq 0,15$
Resistance factor ratio λ	≤ 2
Maximum temperature $\theta_{max j}$ of each connector	θ_{REF}



Testing results:

Table 6. – Temperatures, test loop

Cycle	Reference conductor R1 (°C)	Reference conductor R2 (°C)	Ambient temp. (°C)	Sample №					
				4	5	6	7	8	9
				θ_j (°C)	θ_j (°C)	θ_j (°C)	θ_j (°C)	θ_j (°C)	θ_j (°C)
0	117,9	/	22,8	69,6	66,8	66,3	67,4	72,4	67,7
200	117,6	/	22,5	71,7	67,9	68,3	69,1	73,7	69,7
200	118,2	/	23,2	74,5	71,8	69,8	71,1	75,6	72,5
250	117,0	/	23,0	74,6	72,1	71,2	72,0	75,6	72,1
325	116,8	/	22,6	75,0	71,8	71,3	72,0	75,8	72,6
400	117,5	/	23,5	75,5	72,3	71,1	72,5	76,9	73,0
475	117,6	/	23,3	75,9	73,1	71,6	72,4	77,4	73,4
550	118,1	/	22,9	75,3	73,0	72,2	72,5	76,9	73,2
625	118,6	/	23,1	75,6	73,4	72,0	72,9	77,5	72,7
700	118,5	/	23,4	75,9	73,8	73,4	73,2	77,9	73,5
775	118,0	/	22,6	76,1	74,3	73,8	73,5	78,2	73,1
850	117,9	/	22,6	76,5	74,1	74,2	73,6	78,7	73,6
925	118,2	/	23,2	77,3	74,9	74,7	73,9	79,3	74,5
1000	118,6	/	23,4	77,8	75,6	75,3	74,4	79,5	75,1




Temperature diagram (class A) – Test Loop




Table 7. – Resistance, test loop

Sample №											
Cycle	1			2			3			Ref. (R1)	λ ≤ 2
	R (μΩ)	k	R ratio: λ	R (μΩ)	k	R ratio: λ	R (μΩ)	k	R ratio: λ	R (μΩ)	
0	106,755	4,987	/	101,203	4,728	/	99,006	4,625	/	133,779	
200	107,923	5,016	1,006	102,197	4,750	1,005	99,825	4,640	1,003	134,464	
200	109,876	5,061	1,015	103,917	4,786	1,012	101,936	4,695	1,015	135,697	
250	110,110	5,052	1,013	104,396	4,790	1,013	102,225	4,695	1,014	136,225	
325	110,026	5,036	1,010	104,716	4,793	1,014	102,671	4,699	1,016	136,554	
400	110,404	5,034	1,009	105,484	4,810	1,017	103,134	4,702	1,017	137,074	
475	110,763	5,047	1,012	106,016	4,831	1,022	103,550	4,718	1,020	137,160	
550	111,056	5,052	1,013	106,406	4,841	1,024	104,052	4,734	1,023	137,380	
625	111,136	5,045	1,012	106,802	4,848	1,025	104,205	4,730	1,023	137,681	
700	111,365	5,046	1,012	107,266	4,861	1,028	104,587	4,739	1,025	137,927	
775	111,500	5,031	1,009	107,963	4,872	1,030	104,454	4,714	1,019	138,504	
850	111,957	5,049	1,012	108,758	4,905	1,037	104,772	4,725	1,022	138,586	
925	112,503	5,067	1,016	109,157	4,916	1,040	105,360	4,745	1,026	138,779	
1000	112,448	5,049	1,012	109,668	4,924	1,042	105,376	4,732	1,023	139,191	
\bar{R}_j \bar{k}_j	111,2061	5,0463		106,9664	4,8536		104,0350	4,7208			
b		0,0011			0,0141			0,0041			
M		0,0021			0,0291			0,0087			
S		0,0040			0,0028			0,0052			
D		0,0061			0,0319			0,0139			≤ 0,15
Cycle	4			5			6			Ref. (R2)	
0	95,511	4,462	/	108,198	5,055	/	101,360	4,735	/	/	
200	96,747	4,497	1,008	109,904	5,108	1,011	102,816	4,779	1,009	/	
200	98,237	4,525	1,014	111,595	5,140	1,017	104,225	4,800	1,014	/	
250	98,590	4,523	1,014	112,194	5,147	1,018	104,647	4,801	1,014	/	
325	98,865	4,525	1,014	112,720	5,159	1,021	104,581	4,787	1,011	/	
400	99,161	4,521	1,013	112,830	5,145	1,018	104,908	4,783	1,010	/	
475	99,942	4,554	1,021	113,687	5,180	1,025	105,464	4,806	1,015	/	
550	100,336	4,565	1,023	113,965	5,185	1,026	105,689	4,808	1,015	/	
625	100,568	4,565	1,023	114,280	5,188	1,026	106,028	4,813	1,016	/	
700	100,934	4,574	1,025	114,774	5,201	1,029	106,478	4,825	1,019	/	
775	100,931	4,555	1,021	114,837	5,182	1,025	107,074	4,832	1,020	/	
850	101,314	4,569	1,024	115,085	5,190	1,027	107,710	4,858	1,026	/	
925	101,723	4,581	1,027	115,381	5,196	1,028	107,657	4,848	1,024	/	
1000	102,138	4,586	1,028	115,743	5,197	1,028	107,735	4,838	1,022	/	
\bar{R}_j \bar{k}_j	100,4092	4,5562		114,1360	5,1791		106,1793	4,8180			
b		0,0063			0,0050			0,0065			
M		0,0138			0,0097			0,0136			
S		0,0050			0,0045			0,0048			
D		0,0188			0,0142			0,0184			≤ 0,15



Resistance diagram (class A) – Test loop



K ratio diagram (class A) – Test loop



Table 8. – Results, test loop

\bar{K}	4,8623	
\bar{K}_0	4,7656	
S_0	0,2222	
δ	0,0769	$\leq 0,3$
S	0,2236	
β	0,0759	$\leq 0,3$

Table 9. – Results – Conclusion, test loop

Parameter	Results	Maximum value
Initial scatter δ	Table 8	≤ 0.3
Mean scatter β	Table 8	≤ 0.3
Assessment of resistance stability	Table 7	$\leq 0,15$
Resistance factor ratio λ	Table 7	≤ 2
Maximum temperature θ_{\max} of each connector	Table 6	θ_{\max}

Examiner / Date
Vladimir Rilak 
Milan Radojković 
Ivan Stanković 
20.12.2023.

Expanded measurement uncertainty $U = 0,86 \%$ (exp. measurement uncertainty 95% - ILAC G8)



EQUIPMENT USED FOR TESTING



No	Type	Model	Latest calibration
1	Torque wrench	Unior – Model 266	05.10.2023.
2	Hydraulics crimping press	Elmark	Calibration not needed
3	Tape measuring ruler 1m	Orion 0-1000 mm	13.05.2021.
4	Caliper with digital dial	Tesa / 0.002mm – with digital dial	25.02.2021.
5	Electrical ageing test bench	UES-185	Calibration not needed
5.1	Millivoltmeter	MVC-109-8	13.01.2021.
5.2	Temperature regulator	Termomir BP-10	29.12.2020.
5.3	Temperature regulator	Termomir BP-10-2	29.12.2020.
5.4	Temperature regulator	Termomir BP-10-8	29.12.2020.
5.5	Time relay	ETI CRM-91H	23.03.2022.
6	Digital multimeter	Fluke 289	01.11.2021.

DECISION RULE:

BINARY STATEMENT FOR SIMPLE ACCEPTANCE RULE

$\Omega = 0$ – Guard band equal zero, AL = TL

Standard ILAC – G8:09/19, Clause 4.2.1





DECLARATION OF CONFORMITY FOR TESTS PERFORMED (by user request):

TESTED PRODUCT IS IN COMPLIANCE WITH TESTED STANDARD CLAUSE.

OPINIONS AND INTERPRETATIONS (by user request):

Head of mechanical testing procedure:

Milan Radojković

Head of electrical testing procedure:

Vladimir Rilak