

Certificate of Product Approval

Certificate Number: 717a Issue: 08



Texecom Ltd

Bradwood Court St Crispin Way Haslingden Lancashire BB4 4PW United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

PSS-0068 PSS-0079
PSS-0073 PSS-0080
PSS-0084 PSS-0089
PBS-0003 PBS-0009
PSC-0045 PSC-0051
PSC-0054 PSC-0055
PBS-0015 PSC-0062
PSC-0063

(Refer to Appendix for details)

Standards

EN 54-3: 2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

UKAS MANAGEMENT SYSTEMS 0007 P Halligan Verifier 26 July 2016 Date of Issue 01 November 2005

Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.







Appendix to Certificate No: 717a Texecom Ltd

Certified Product	Description			
PSS-0068	Conventional Sounder with LED Strobe (Red Head / Red Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 3. Certification excludes the strobe function	717a/01		
PSS-0079	Conventional Sounder with LED Strobe (Red Head / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 3. Certification excludes the strobe function	717a/02		
PSS-0073	Conventional Sounder with LED Strobe (Amber Head / Red Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 3. Certification excludes the strobe function			
PSS-0080	Conventional Sounder with LED Strobe (Amber Head / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13	717a/04		

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

P Halligan 26 July 2016 01 November 2005
Signed for LPCB Verifier Date of Issue Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Issue: 08



Appendix to Certificate No: 717a

Issue: 08

Texecom Ltd

Certified Product	Description			
	3. Certification excludes the strobe function			
PSS-0084	Conventional Sounder (Red) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes:	717a/05		
	 The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 			
PSS-0089	Conventional Sounder (White) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13	717a/06		
PBS-0003	Universal base sounder (White) Notes: 1. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13			
PBS-0009	Universal base sounder (Cream) Notes: 1. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13			
PSC-0045	Conventional Sounder with LED Strobe Common Operation (Red Head / Red Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 3. Certification excludes the strobe function	717a/10		

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

f. Halligan

P Halligan

26 July 2016

01 November 2005

ate of Issue Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.







Appendix to Certificate No: 717a Texecom Ltd

Certified Product	Description			
PSC-0051	Conventional Sounder with Red LED Strobe Common Operation (Clear Lens / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes:			
	 The above sounder is Type A when used with the shallow base & Type B when used with the deep base only Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 Certification excludes the strobe function 			
PSC-0054	Conventional Sounder with LED Strobe Common Operation (Amber Head / Red Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 3. Certification excludes the strobe function	717a/12		
PSC-0055	Conventional Sounder with Red LED Strobe (Clear Lens / White Base) (PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases) Notes: 1. The above sounder is Type A when used the with the shallow base & Type B when used with the deep base only 2. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 3. Certification excludes the strobe function			
PBS-0015	Universal base sounder (Red) Notes: 1. Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13			
PSC-0062	Conventional Sounder with LED Strobe Common Operation (Red Head / White Base)			

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

f. Halligar.

P Halligan

26 July 2016

01 November 2005

Date of Issue Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com





Issue: 08



Appendix to Certificate No: 717a

Issue: 08

Texecom Ltd

Certified Product	Description			
	(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)			
	Notes:			
	 The above sounder is Type A when used with the shallow base & Type B when used with the deep base only Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 Certification excludes the strobe function 			
PSC-0063	Conventional Sounder with LED Strobe Common Operation (Amber Head / White Base)	717a/17		
	(PSO-0001, PSO-0006, PSO-0003 & PSO-0007 bases)			
	Notes:			
	 The above sounder is Type A when used with the shallow base & Type B when used with the deep base only Meets the requirements of EN 54-3:2001 at tones 1,2,3,6,7 & 13 Certification excludes the strobe function 			

Bases

PSO-0001 Shallow base (red) PSO-0006 Shallow base (white) PSO-0003 Deep base (red) PSO-0007 Deep base (white)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

f. Malligan

P Halligan

26 July 2016 Date of Issue 01 November 2005

Date of First Issue

LPCB R



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.







Appendix to Certificate No: 717a Issue: 08

Texecom Ltd

Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
717a/01	PSS-0068	XPA-SN-14003-APO	Apollo Fire Detectors Limited	010af/03
717a/01	PSS-0068	CP-500IMC	Context Plus Ltd	717a-(cl-1)
717a/01	PSS-0068	LF-SB-4228	Lichfield Fire & Safety Equipment Co. Ltd (LIFECO)	717a-(cl-2)
717a/01	PSS-0068	1000-100	Syncoln Ltd	717a-(cl-3)
717a/01	PSS-0068	1000-101	Syncoln Ltd	717a-(cl-3)
717a/04	PSS-0080	XPA-SN-14004-APO	Apollo Fire Detectors Limited	010af/04
717a/05	PSS-0084	XPA-SO-14001-APO	Apollo Fire Detectors Limited	010af/01
717a/05	PSS-0084	CP-400IMC	Context Plus Ltd	717a-(cl-1)
717a/05	PSS-0084	LF-SD-4229	Lichfield Fire & Safety Equipment Co. Ltd (LIFECO)	717a-(cl-2)
717a/05	PSS-0084	1000-200	Syncoln Ltd	717a-(cl-3)
717a/05	PSS-0084	1000-201	Syncoln Ltd	717a-(cl-3)
717a/06	PSS-0089	XPA-SO-14002-APO	Apollo Fire Detectors Limited	010af/02
717a/10	PSC-0045	CP-600IMC	Context Plus Ltd	717a-(cl-1)
717a/13	PSS-0055	XPA-SN-14005-APO	Apollo Fire Detectors Limited	010af/05

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

P Halligan

26 July 2016 Date of Issue 01 November 2005

Date of First Issue





This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.







Appendix to Certificate No: 717a

Issue: 08

Texecom Ltd

Bases

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
717	PSO-0001	SB-400IMC	Context Plus Ltd	717
717	PSO-0001	LF-SSBB	Lichfield Fire & Safety Equipment Co. Ltd (LIFECO)	717
717	PSO-0001	PSO-0001	Syncoln Ltd	717
717	PSO-0003	PSO-0003	Syncoln Ltd	717
717	PSO-0003	DB-450IMC	Context Plus Ltd	717
717	PSO-0003	LF-DSSBB	Lichfield Fire & Safety Equipment Co. Ltd (LIFECO)	717

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

f. Malligar

P Halligan

26 July 2016

01 November 2005

Date of Issue Date of First Issue

LPCB E



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.



