

CERTIFICAT DE CALITATE

Nr. 1288 / Data: 07.03.2024

Denumire produs: HIPOCLORIT DE SODIU SOLUTIE

Destinatia: Apa Canal Chisinau

Aviz de insotire a marfii:-

Nr auto: -

Nr ambalaje:-

Nr lot:1940/03.03.2024

Cantitate:-

CARACTERISTICI DE CALITATE

Nr crt.	Caracteristica	U.M.	Valori realizate	Valori prevazute in EN 901:2013 Tip 1 + Cerinta client	Metode de analiza
1	Aspect (miros, culoare)	-	soluție limpede, de culoare galben pal sau verzui, cu miros slabde clor	soluție limpede, de culoare galben pal sau verzui, cu miros slabde clor	Vizual
2	Densitate la 20°C	g/dm3	1266	1230-1270	ASTM D 891
3	Conținutul de clor activ	% g/dm3	14,8 187	13,8-14,9 170-190	STAS 918/83
4	Continut in clorat de sodiu (NaClO3)	% g/100g clor activ	< 5,4	Max. 5,4	STAS 918/83
5	Continut de hidroxid de sodiu (NaOH)	g/dm3	16,5	10-20	STAS 918/83
6	Continut de cloruri	%	0,9	Max. 1,4	STAS 918/83
7	Arsen (As)	mg/kg clor activ	< 1	max. 1	EN 901:2013
8	Stibiu (Sb)	mg/kg clor activ	< 20	max. 20	EN 901:2013
9	Cadmium (Cd)	mg/kg clor activ	< 2,5	max. 2,5	EN 901:2013
10	Plumb (Pb)	mg/kg clor activ	< 15	max. 15	EN 901:2013
11	Mercur (Hg)	mg/kg clor activ	< 3,5	max. 3,5	EN 901:2013
12	Nichel (Ni)	mg/kg clor activ	< 2,5	max. 2,5	EN 901:2013
13	Seleniu (Se)	mg/kg clor activ	< 20	max. 20	EN 901:2013
14	Bromat de sodiu	g/kg clor activ	< 2,5	max.2,5	EN 901:2013

Data fabricatiei: 03.03.2024

Data expirarii: 16.04.2024

Birou CTC

Ing. Adriana Jitea



CHIMCOMPLEX S.A. BORZEȘTI

Str. Industriilor nr. 3, Onești, jud. Bacău, România

Tel. 0234/302.250; Fax 0234/302.102

E-mail: office@chimcomplex.com

Web: www.chimcomplex.com

Reg. Com. J04/493/1991, Cod Unic 960322

Capital Social subscris și vărsat: 304907851 RON

Cont: RO53BUCU1111215962133EUR

RO60BUCU1111215962132RON

RO50BUCU1111215962134USD

ALPHA BANK BUCUREȘTI



RO2021.055.061Q RO2021.055.061E RO2018.055.061