
tyco

Electronics**Energy Division**<http://energy.tycoelectronics.com>

Bowthorpe EMP

Test Report

Type	OCP2- M
PPR Number	PPR-2227
Test Specification	Insulation withstand tests on the arrester housing IEC 60099-4 (2004-05)

Test Information:

Laboratory	CESI
Date	19/10/2005
External Test Ref	A5/049798
Report Prepared by	M. Gregori
Test Verified by	R. Malgesini
Test Approved by	M. de Nigris

Tyco Approvals:

R&D Manager Brendan Normoyle	Signature 	Date 10/01/2006
--	--	-----------------

Product Manager Brian McGowan	Signature 	Date 10/01/2006
---	--	-----------------

For further information contact:
Tyco Electronics Energy Division
Bay 100-109
Shannon Industrial Estate
Co. Clare, Ireland
Tel: + 353-61-472885
Fax: + 353-61-472676
Email: mvsurgearresters@tycoelectronics.com

Client TYCO Electronics Energy Division – Shannon (IRL)

Tested equipment Housing for polymer housed metal-oxide surge arrester
type OCP2

Tests carried out Insulation withstand tests

Standards/Specifications IEC 60099-4 (2004-05)

Test date from October 19, 2005 to October 19, 2005

The results reported in this document relate only to the tested equipment.

Partial reproduction of this document is permitted only with the written permission from CESI.

No. of pages

13

No. of pages annexed

5

Issue date

October 19, 2005

Prepared

BU PeC - M. Gregori

Mario Gregori

Verified

BU PeC - R. Malgesini

R. Malgesini

Approved

BU PeC - M. de Nigris

CESI
CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO
Business Unit
Prove e Componenti
Il Responsabile del Laboratorio

Tests witnessed by:-----

Identification of the object:

The Manufacturer guarantees that the tested object is manufactured according to the submitted drawing.
CESI checked that this drawing adequately represents in shape and dimensions the essential details and the parts of the tested object.
This drawing, identified by CESI and numbered A5049800, is annexed to this document.

The data necessary to permit repetition of the tests are contained in the document marked: ---


- dielectric tests with impulse voltage : **peak voltage:** $\pm 3 \%$; **time parameters:** $\pm 10 \%$
- dielectric tests with impulse current : **peak value:** $\pm 3 \%$; **time parameters:** $\pm 10 \%$
- dielectric tests with alternating voltage : **voltage (rms):** $\pm 3 \%$
- dielectric tests with direct voltage : **voltage:** $\pm 3 \%$

The measurement uncertainties are estimated at the level of twice the standard deviation (corresponding, in the case of normal distribution, to confidence level of about 95%) and have to be considered as maximum values

Laboratory information

Receipt date of the sample	October 10, 2004
Test location	CESI – Via Rubattino 54 – Milan
CESI testing team	Mr L. Podavitte , Mr I. Guacci, Mr M. Gregori
Test laboratory	P180
Activity code	41652U

content	page	test date
Rated characteristics of the test object	4	October 19, 2005 October 19, 2005
Panoramic view of the test object	5	
Panoramic view of the test arrangement	6	
Reference standard	7	
Test carried out	7	
Test procedure	8	
Summary of test result	8	
Dry lightning impulse withstand tests	9	
Wet power frequency withstand tests	10	
Technical data of the test circuit	11-13	
Pages annexed: oscillograms n.4 pages Tyco drawing n.MV-OCp2-00280-S; CESI n. A5049800 – n.1 page		



Rated characteristics of the tested object assigned by the Client**Metal-oxide surge arrester**

Manufacturer	TYCO Electronics Energy division - Shannon (IRL)
Year of manufacture	2005

Electrical characteristics

Nominal discharge current (I_r)	10 kA
Line discharge class	2
Rated voltage (U_r)	51,25 kV
Continuous operating voltage (U_c)	41 kV
High short circuit	40 kA
Low short circuit	600 A
Rated frequency	50 Hz

Geometrical characteristics

Total height	533 mm
Number of sheds	n.8 large – n.7 small
Shed diameter	137mm large – 107 mm small
Shed spacing	41 mm
Arcing distance	418 mm
Creepage (leakage) distance	1279 mm

Other characteristics

Housing material	silicone
Housing color	grey

Name and signature of Client's witness:

Photograph of the test object




Photo no. 1

Test setting for dielectric tests



Photo no. 2

Reference Standard

IEC 60099-4 (2004-05): "Metal-oxide surge arrester without gaps for a.c. system", clause 8.2

Test carried out and identification of the test objects

Test carried out	Number of test objects	Test object identification
Dry lightning impulse withstand tests	1	IWT1
Wet power frequency withstand tests		

Test procedure

Dry lightning impulse withstand test

The test sample has been submitted to fifteen voltage impulses for each polarity having waveshape 1,2/50 μ s and peak value equal to 250 kVpeak . The test has been performed in dry condition (as defined by IEC st. 60060-1) .

Wet power frequency withstand test

The power frequency voltage has been applied for 60 second on the sample at the value equal to 122 kVrms.
The test has been performed in wet condition (as defined by IEC st. 60060-1) .

Summary of test results

Dry lightning impulse withstand test

No flashover occurred during any of the impulse application

Wet power frequency withstand test

Non flashover occurred

The test result positive

Dry lightning impulse withstand voltage test

Test No.: 1


Test object: Housing for polymer housed metal-oxide surge arrester
Test circuit: A0002
Arrangement: see photograph pag n.6

Atmospheric conditions and correction factor				
b	t_d/t_w	h	K_i	
kPa	°C	g / m ³		
101,03	15,5 (12,0)	8,70	0,996	

Date: October 19, 2005

test condition	polarity	impulse generator charging voltage kV	Required U kV _{peak}	voltage applied U x K _i kV _{peak}	A: (o) withstand (x) flashover B: oscillogram No. C: peak voltage [kV] D: time to discharge (μs)													
					A	o	o	o	o	o	o	o	o	o	o	o	o	o
IWT1	NEG	64	250	249	B	03												
					C	248	249	248	249	249	249	249	248	250	249	249	249	249
					D													
					A	o	o	o	o	o	o	o	o	o	o	o	o	o
IWT1	POS.	64	250	249	B	04												
					C	250	249	249	249	249	250	249	249	249	249	249	249	249
					D													

continued



CESI

Wet power frequency withstand voltage test

Test No.: 2

Test object: Housing for polymer housed metal-oxide surge arrester
Test circuit: A0058-A0059
Arrangement: see photograph pag n.6


Atmospheric conditions and correction factor			
b	t_d/t_w	h	K_t
kPa	°C	g / m ³	
101,03	15,5 (12,0)	8,70	1,00

	Precipitation conditions					Water temperature °C	Water resistivity Ω * m
	Precipitation rate (mm/min)			bottom			
	top	center					
vertical	1,2	1,2		1,2	11	100	
horizontal	1,2	1,2		1,2			

Date: October 19, 2005


test condition	voltage		test voltage		test duration	Test result	Notes
	required U	applied U x K_t	V_1	$V_{AT} = k_1 V_1$ ($k_1 = 3500$)			
	kV _{rms}	kV _{rms}	V _{rms}	kV _{rms}	s		
IWT1	122	122	34,85	122	60	withstand	

continued



n° 0030

CESI

Circuit A0002**Impulse generator**


No. of stages: 4
 C_g : 125 nF
 R_t : 280 Ω (140 x 2)
 R_f : 320 Ω (140+60+40+80)
 C_c : 0,6 nF

Voltage measuring system CESI No. 9792

D - divider PASSONI & VILLA type RC series CESI No. 6700; scale factor 25662,7
 HV - high voltage capacitance 600 pF
 Lv - low voltage unit CESI No. 6704
 K - coaxial cable
 S - attenuation and termination unit CESI No. 14924
 OSC - digital oscilloscope type TEKTRONIX TDS 430A CESI No. 14232

Measured waveshape			
	polarity	time	oscillogram
		μ s	No.
front	negative	1,15	01
tail		55,0	02

Check of the test circuit			
	Charging voltage V_c	Measured voltage V_m	η $V_m / (V_c \cdot n_{\text{stages}})$
polarity	kV/stage	kV	
negative		195,6	0,978


Circuit A0058**Power frequency test circuit**

- R - regulation group PIVI composed by:
- single-phase voltage converter PIVI; power 210 kVA; voltage 380 V/0÷610 V
 - booster transformer PIVI; power 200 kVA; voltage 600 V / 6 kV
- R_{IV} - protection resistor TELEMA; $R = 2 \Omega$
- TA - current transformer type CGS; ratio 50 A/5 A; CESI No. 03399
- I - direct reading digital amperometer
- TV_1 - voltage transformer type ALSTOM; ratio 6 kV/100 V
- V_1 - digital voltmeter AGILENT 34401A; CESI No. 23082
- T - booster transformer CGE mod. KOC; secondary winding power 700 kVA; voltage 6 kV / 350 kV; No. of units 1; ratio /
- RE - variable reactor PIVI; power 600 kVA; voltage / kV; No. of units /

Tripping of the circuit breaker S

I_N	k_{TA}	instantaneous tripping			time delayed tripping		
		setting			setting		
		s_1	$s_1 3 I_N$	t_1	s_2	$s_2 3 I_N$	t_2
5	10	1	5	0,05	0,5	2,5	0,05

Circuit A0059



Power frequency measuring circuit

TA - current transformer type CGS; ratio 50 A/5 A; CESI No. 03399

I - direct reading digital amperemeter

TV₁ - voltage transformer type ALSTOM; ratio 6 kV/100 V

V₁ - digital voltmeter AGILENT 34401A CESI No. 23082

D - voltage divider / type RC series; voltage / kV; HV capacitance / pF; CESI No. /; low voltage arm CESI No. / scale factor /

V₃ - voltmeter CESI No. Not used


TV₂ - voltage transformer type SCARPA & MAGNANO; ratio 130/100 V; CESI No.5133

V₂ - digital voltmeter AGILENT 34401A CESI No. 23083

Functional check of the test circuit


Date: October 19, 2005

Low voltage				High voltage				k _t
V ₁	V _{lv}	I	I _{lv}	k ₂ = 1300		k ₃ =		
V	V	A	A	V ₂	V _{HV}	V ₃	V _{HV}	V _{HV} / V ₁
14,27	856,2	--	1,0	38,34	48,83	-	-	3492




Vp[kV] T1/Tp[us] T2/Tc[us]

-195.567 1.154 55.225




Vp[kV] T1/Tp[us] T2/Tc[us]

-195.567 1.154 55.225




Vp[KV]	T1/Tp[uS]	T2/Tc[uS]
-247.865	1.112	55.137




Vp[kV]	T1/Tp[us]	T2/Tc[us]
249.745	1.146	55.650

SCD



NOTE:-
UC = 41kV
NDM CREEPAGE = 1279mm
NDM DRY ARC DIST = 418mm
CANT. STRENGTH = 350Nm
TENSILE STRENGTH = 2kN
TORQUE = 50Nm
HIGH SHORT CIRCUIT = 40kA
LOW SHORT CIRCUIT = 600A



tyco
ELECTRONICS

ENERGY DIVISION

Bowthorpe EMP

REV	DATE	SIGN	MODIFICATION	ORIGINAL	ISSUE	DATE	BY	0
0	09/05	JM	ORIGINAL	ISSUE				
A 5 / 4 9 8 0 0						1 8 OCT. 2005		
Firma								

CESI

DATA

PROTOCOLLO

09/05

09/05

09/05

41kV 10kA

MV SURGE ARRESTOR

DCP2-41M

TITLE

*****-000

PCN

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

SHEET 1 OF 1

MV-DCP2-00280-S

DRG NO

*****-000

PCN

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05

09/09/05