



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

[Signature] D. R. Dovgun
« 28 » « 09 » 2020

TYPE TESTING REPORT № 40/20

Of the insulation piercing connectors PC 120-16 testing

Requirements: EN 50483:2009, the manufacturer's specifications.

The test methods: EN 50483:2009.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: ***Insulation piercing connectors PC 120-16 passed the tests by the parameters which were tested, satisfy the manufacturer's declared characteristics and requirements of EN 50483:2009.***

(the testing results are given at the additional testing reports №№ 40/20-1 ... 40/20-12, which is the integral part of this testing report)

This testing report is valid only for the tested samples.


This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

List and numbers of the testing reports where the testing results are given

| Test | Testing report |
|---|-----------------------|
| 1. Visual examination test and dimensional and material verification test (EN 50483-1:2009 Annex A, Table A.1 and clause 6) | 40/20-1 |
| 2. Test for permanent marking (EN 50483-1:2009 clause 9.2) | 40/20-2 |
| 3. Dielectrical voltage test in water (EN 50483-4:2009 clause 8.1.3.1) | 40/20-3 |
| 4. Corrosion aging tests (EN 50483 - 4:2009 clause 8.1.5.1, 8.1.5.1.3.2 method 1, EN 50483-6:2009 clauses 8.4.1 and clause 8.4.2 method 1 | 40/20-4 |
| 5. Climatic aging test (EN 50483 - 4:2009 clause 8.1.5.2, 8.1.5.2.3.2 method 2, EN 50483-6:2009 clause 8.5.2) | 40/20-5 |
| 6. Test for mechanical damage of the main conductor (EN 50483-4:2009 clause 8.1.2.1) | 40/20-6 |
| 7. Branch cable pull-out test (EN 50483-4:2009 clause 8.1.2.2) | 40/20-7 |
| 8. Connector bolt tightening test (EN 50483-4:2009 clause 8.1.2.3) | 40/20-8 |
| 9. Shear head function test (EN 50483-4:2009 clause 8.1.2.4) | 40/20-9 |
| 10. Low temperature impact test (EN 50483-4:2009 clause 8.1.2.5) | 40/20-10 |
| 11. Low temperature assembly test (EN 50483-4:2009 clause 8.1.4) | 40/20-11 |
| 12. Electrical ageing test (EN 50483-4:2009 clause 8.1.6, EN 50483-5:2009) | 40/20-12 |

IPC CHARACTERISTICS



Name: Insulation piercing connector.
Model and type: PC 120-16.
Purpose: Purposed for aluminum and copper conductors.

Technical characteristics

| | |
|------------------------------------|--|
| Class: | A1. |
| Main conductor cross-sections: | (6 – 120) mm ² . |
| Branch conductor cross-sections: | (1,5 – 16) mm ² . |
| The tightening torque of the bolt: | (9 ± 1,5) Nm. |
| Batch number: | 05/20. |
| Installation temperature: | From -10 °C to +50 °C. |
| Weight: | (65 ± 1) g. |
| Overall dimension (L / W / H): | (31 ± 1) mm / (36 ± 2) mm / (57 ± 2) mm. |

Engineering data

| | |
|----------------|--|
| Body: | Polyamide resistant to UV, wet and temperature difference. |
| Contact plate: | Tinned copper. |
| Sealants: | Polymer resistant to UV, wet and temperature difference. |
| Bolt, washers: | Galvanized steel. |
| Shear head: | Zinc alloy. |





The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

Engineer:

Engineer:

| | |
|---|------------------|
|  | S. S. Lakhovskyi |
|  | O. O. Nepyivoda |
|  | D. S. Denys |
|  | A. S. Shevtsiv |



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року


79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel.: (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The Head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-1

***Visual examination test, dimensional and material verification test of
insulation piercing connectors PC 120-16***

Requirements: EN 50483-1:2009 Annex A, Table A.1 and clause 6.

The test methods: EN 50483:2009.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: ***Insulation piercing connector PC 120-16 satisfy the
manufacturer's declared characteristics and
requirements of EN 50483-1:2009 Annex A,
Table A.1 and clause 6.***

This testing report is valid only for the tested samples.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 1.
 Identification numbers of the samples: №13.
 The testing dates: 17.07.2020.
 The environmental conditions:
 temperature: 22,8 °C;
 air pressure: 96,6 kPa;
 humidity: 70 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

2. Testing procedure:

Verification is performed visually, by the method of measuring and material's determining.

3. Requirements:

IPCs shall be made of the materials, declared by the manufacturer, and to correspond with the dimensions from the drawings. Marking shall be marked in accordance with EN 50483-1:2009 clause 6.

4. Testing results:

During the visual inspection it was found that the samples were executed correctly, the surfaces of the products were smooth, without sharp edges.

Results of examinations of sizes, materials and information for marking are given in Table 1 – Table 3.

Table 1 – The materials, used in production of IPC PC 120-16

| № | Component | Material | Correspondence with requirements |
|---|----------------|---------------------------|----------------------------------|
| 1 | Body | Polyamide resistant to UV | Satisfy |
| 2 | Contact plates | Aluminum alloy | Satisfy |
| 3 | Sealants | Polymer resistant to UV | Satisfy |
| 4 | Bolt | Galvanized steel | Satisfy |
| 5 | Washers | Galvanized steel | Satisfy |
| 6 | Shear head | Zinc alloy | Satisfy |

Table 2 – Dimensions of the IPC PC 120-16

| № | Dimension | Declared, mm | In fact, mm | Correspondence with requirements |
|---|-----------|--------------|-------------|----------------------------------|
| 1 | Length | (31 ± 1) | 31,0 | Satisfy |
| 2 | Width | (36 ± 2) | 36,2 | Satisfy |
| 3 | Height | (57 ± 2) | 56,8 | Satisfy |

Table 3 – Visual examination of the IPC PC 120-16

| № | Controlled marking items | Factual marking | Correspondence with requirements |
|---|---|---------------------|----------------------------------|
| 1 | Manufacturer's trade mark or logo | FEMAN | Satisfy |
| 2 | Product code or reference | PC 120-16 | Satisfy |
| 3 | Traceability code / batch number | 05/20 | Satisfy |
| 4 | The minimum and maximum conductor cross sections for which the unit is suitable Main conductor, mm ² : Branch conductor, mm ² : | 6 – 120 1,5 – 16 | Satisfy |
| 5 | Tightening torque or die reference, if applicable | - | - |
| 6 | Recycling code, if any | - | - |

There are no defects found during the visual examination of IPC PC 120-16. Submitted testing sample was not used earlier and wasn't processed additionally before the testing. The connector corresponds with the dimensions from the drawings and is made from the materials declared by the manufacturer. The information about manufacturer, product type and reference, usage parameters are clear indicated at sample (Fig.1).

5. Conclusion:

Insulation piercing connectors PC 120-16 satisfy the manufacturer's declared characteristics and requirements of EN 50483-1:2009 Table A.1 and clause 6.


6. Pictures:

Fig.1 – Clamp's marking



Fig.2 – IPC during the dimension's measurement



7. Test equipment:

| № | Type | Model | Latest calibration |
|---|-------------|---------------|--------------------|
| 1 | Slide gauge | ШЦ-1 №0701295 | 05.04.2020 |

The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

S. S. Lakhovskyi

A. S. Shevtsiv



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net


Accreditation certificate

№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel.: (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » « 09 » 2020

TESTING REPORT № 40/20-2

Test for permanent marking of insulation piercing connectors PC 120-16

Requirements: EN 50483-1:2009 clause 9.2.4.

The test methods: EN 50483-1:2009 clause 9.2.

| | |
|-------------------------|--|
| Product name: | Insulation piercing connector (IPC) |
| Model and type: | PC 120-16 |
| Manufacturer: | "FEMAN" D.O.O Vihorska 1, 35000 Jagodina, Serbia |
| Customer: | "FEMAN" D.O.O Vihorska 1, 35000 Jagodina, Serbia |
| Reason: | Contract № 12-06-20 of 25.06.2020 |
| Testing results: | <i>The insulation piercing connectors PC 120-16 passed the test for marking resistance, satisfy manufacturer's declared characteristics and requirements of EN 50483-1:2009 clause 9.2.</i> |

This testing report is valid only for the tested samples.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

| | |
|--|-------------|
| Samples' receiving date: | 15.07.2020 |
| Quantity of the tested samples: | 2. |
| Identification numbers of the samples: | №13, №14. |
| The testing dates: | 03.08.2020. |
| The environmental conditions: | |
| temperature: | 23,0 °C; |
| air pressure: | 98,2 kPa; |
| humidity: | 71 %. |

1. Tested samples:

Insulation piercing connectors:

| | |
|------------------------------------|------------------------------|
| Model and type: | PC 120-16. |
| Class: | A1. |
| Main conductor cross-sections: | (6 – 120) mm ² . |
| Branch conductor cross-sections: | (1,5 – 16) mm ² . |
| The tightening torque of the bolt: | (9 ± 1,5) Nm. |
| Batch number: | 05/20. |
| Installation temperature: | From -10 °C to +50 °C. |

2. Testing procedure:

The tests were performed in accordance with EN 50483-1:2009 clause 9.2.

The tests were performed at two samples of the IPC. The marking of the connector was rubbed by hand for 15 s with a piece of cloth soaked by water and another 15 s with a piece of cloth soaked by petroleum spirit.

3. Requirements:

The marking shall remain clear and allow the IPC to be easily identified.

4. Testing results:

Since the marking of the IPC is embossed, cast by casting, stability tests have not been carried out. The IPC marking is clear and allows easy identification the IPC (Fig.1).

5. Conclusion:

Marking of the insulation piercing connectors PC 120-16 is clear, allow the IPC to be easily identified, and satisfy requirements of EN 50483-1:2009 clause 9.2.

6. Pictures:






Fig.1 – The IPC after testing

The tests were performed by:

deputy head of the testing laboratory:

engineer:

_____  S. S. Lakhovskyi
_____  A. S. Shevtsiv



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року


79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 2020

TESTING REPORT № 40/20-3

Dielectrical voltage test in water of the insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.3.1.4.

The test methods: EN 50483-4:2009 clause 8.1.3.1.

| | |
|------------------|---|
| Product name: | Insulation piercing connector (IPC) |
| Model and type: | PC 120-16 |
| Manufacturer: | "FEMAN" D.O.O Vihorska 1, 35000 Jagodina, Serbia |
| Customer: | "FEMAN" D.O.O Vihorska 1, 35000 Jagodina, Serbia |
| Reason: | Contract № 12-06-20 of 25.06.2020 |
| Testing results: | <i>The insulation piercing connectors PC 120-16 passed the dielectrical voltage test in water with high voltage 4 kV and satisfy the manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.3.1.</i> |

This testing report is valid only for the tested samples.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 4.
 Identification numbers of the samples: №15, №16, №17, №18.
 The testing dates: 04.08.2020.
 The environmental conditions:
 temperature: 22,8 °C;
 air pressure: 97,2 kPa;
 humidity: 70 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПВ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | |
|--------------------------|-------------------------------------|
| Type: | ПВ-3 1,5 |
| Conductor cross-section: | 1,5 mm ² |
| Conductor diameter: | 1,4 mm |
| Number of strands: | 31 |
| Shape: | Round |
| Conductor material: | Copper |
| Insulation thickness: | 0,7 mm |
| Insulation material: | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine |
| Standard: | IEC 60227-1:2007 |

2. Testing procedure:

The tests were performed in accordance with EN 50483-4:2009 clause 8.1.3.1.

Two samples of IPC are tested in each of the following conductors' cross-sections combinations of main and branch conductors: max – min and min – min.

IPC is installed at the core in accordance with manufacturer's installation instruction. The bolt is tightened to the minimum torque 7,5 Nm indicated by the manufacturer. Any changes in orientation of the core are absent in zone 10 cm from the IPC.

The connectors assembled at the cores (assemblies) are put into the tank with water into the deep (30 – 40) cm from the connector to water surface.

After IPCs stay in tank under water during 30 min the testing voltage 4 kV is applied between the main core conductor and the metallic electrode, immersed into the water, during 60 s. The voltage is applied with the speed approximately 1 kV/s in accordance with EN 50483-1:2009 clause 9.1.7.

3. Requirements:

No flashovers or breakdowns of the core or IPCs should occur after testing by high voltage 4 kV during 60 s. The maximum leakage current should not exceed $(10 \pm 0,5)$ mA in accordance with EN 50483-1: 2009 clause 9.1.5.

4. Testing results:

Table 1 – Testing results

| № | Identification number of IPC | Conductors: main - branch (mm ² - mm ²) | The tightening torque of the bolt, Nm | Leakage current at voltage 4 kV, mA | Flashovers, breakdowns |
|---|------------------------------|--|---------------------------------------|-------------------------------------|------------------------|
| 1 | 15 | min – min | 7,5 | 2,0 | Absent |
| | 16 | 6 – 1,5 | | 2,0 | Absent |
| 2 | 17 | max – min | | 1,0 | Absent |
| | 18 | 120 – 1,5 | | 1,0 | Absent |

5. Conclusion:

The insulation piercing connectors PC 120-16 have passed the dielectrical voltage test in water at high voltage 4 kV and satisfy the manufacturer declared characteristics and requirements of EN 50483-4:2009 clause 8.1.3.1.


6. Pictures:

Fig.1 – IPC during the testing



7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|------------------|---------------------------|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 3 | High voltage set | ЛІЗО №001 | Don't need calibration |
| 4 | Voltmeter | E365-1 №913751 | 08.04.2020 |
| 5 | Milliamperemeter | E377 №777768 | 08.04.2020 |
| 6 | Stopwatch | COC np-26-2-010 №2284 | 24.04.2020 |

The tests were performed by:

deputy head of the testing laboratory:

engineer:

 S. S. Lakhovskyi
 O. O. Nepyivoda



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The Head of the
testing laboratory of "LIZO Ltd."

[Signature] D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-4

Corrosion aging tests of insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.5.1.4.

The test methods: EN 50483-4:2009 clause 8.1.5.1, 8.1.5.1.3.2 method 1,
EN 50483-6:2009 clause 8.4.1 and clause 8.4.2 method 1.

| | |
|------------------|---|
| Product name: | Insulation piercing connector (IPC) |
| Model and type: | PC 120-16 |
| Manufacturer: | "FEMAN" D.O.O Vihorska 1, 35000 Jagodina, Serbia |
| Customer: | "FEMAN" D.O.O Vihorska 1, 35000 Jagodina, Serbia |
| Reason: | Contract № 12-06-20 of 25.06.2020 |
| Testing results: | <i>The insulation piercing connectors PC 120-16 have passed the corrosion aging tests and satisfy the manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.5.1, 8.1.5.1.3.2 method 1.</i> |

This testing report is valid only for the tested samples.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
Quantity of the tested samples: 2.
Identification numbers of the samples: №19, №20.
The testing dates: 16.07.2020 - 10.09.2020.
The environmental conditions:
temperature: (16 – 24) °C;
air pressure: (96 – 101) kPa;
humidity: (45 – 75) %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
Class: A1.
Main conductor cross-sections: (6 – 120) mm².
Branch conductor cross-sections: (1,5 – 16) mm².
The tightening torque of the bolt: (9 ± 1,5) Nm.
Batch number: 05/20.
Installation temperature: From -10 °C to +50 °C.

The main conductors:

Type: ПБ-1 6
Conductor cross-section: 6 mm²
Conductor diameter: 2,75 mm
Number of strands: 1
Shape: Round
Conductor material: Copper
Insulation thickness: 1,0 mm
Insulation material: PVC
Manufacturer / country: PJSC «Yuzhcable works» / Ukraine
Standard: IEC 60227-1:2007

The branch conductors:

Type: ПБ-3 1,5
Conductor cross-section: 1,5 mm²
Conductor diameter: 1,4 mm
Number of strands: 31
Shape: Round
Conductor material: Copper
Insulation thickness: 0,7 mm
Insulation material: PVC
Manufacturer / country: PJSC «Yuzhcable works» / Ukraine
Standard: IEC 60227-1:2007

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.5.1, 8.1.5.1.3.2 method 1.

Two samples of IPCs are tested in each of the following conductors' cross-sections combinations of main and branch conductors: min – min.

The IPC is placed at the middle of the main core of length (0,5 – 1,5) m. The bolt of the IPC is tightened with minimum torque 7,5 Nm specified by the manufacturer.

The tests are performed in 4 cycles of 14 days. The 14-day cycle consists of 7 days of continuously stay at salt fog chamber and of 7 days of continuously stay at chamber with higher temperature and humidity atmosphere saturated by sulphur dioxide (SO₂) (Fig.1 – Fig.2) in accordance with EN 50483-6:2009 clause 8.4.1 and clause 8.4.2.

2.1. Climatic aging test in the salt fog chamber

The testing equipment and the testing procedure are corresponded with the requirements of EN 60068-2-11:1999.

Dispersion of the salt fog are controlled during the tests by two prefabricated manifolds with area 80 cm² of each. The fog gathered in each manifold with speed (1 – 2) ml/hour with average time of dispersion not less than 16 hours.

The brine, which is used for testing, has weight-part concentration (5 ± 2) %. The pH of the brine is within the normal range of 6,5 to 7,2.

Compressed air without impurities of dust and oils with maintaining pressure (120 ± 50) kPa is used to generate the fog. The air is warmed and moistened before feeding to the pulverizer by passing through the heated to 40 °C water.

The temperature in the testing chamber is maintained (35 ± 2) °C.

2.2. Climatic aging test in chamber with higher temperature and humidity atmosphere saturated by sulfur dioxide (SO₂)

The testing equipment and the testing procedure satisfy requirements of EN ISO 3231. (2 ± 0,2) litres of distilled water are filled into the chamber before each cycle.

Sulphur dioxide in chamber with concentration 0,0667 % is made with the help of the reaction of sodium pyrosulfate (Na₂S₂O₅) and sulfamic acid (HSO₃ NH₂).

The temperature in the chamber is maintained (40 ± 3) °C during 8 hours. Then chamber is opened and temperature is falling to the environmental temperature during 16 hours.

3. Requirements:

At visual control, there shall be no significant traces of rust (over 10 % of the open surface of metal parts of the samples).

The sample's identification marking shall be legible when examined with normal or corrected vision without magnification.

No deterioration of the main parts of the connectors shall occur which would impair their normal function.

It shall be able to remove IPCs with a torque below or equal to the manufacturer's specified maximum torque 10,5 Nm.

4. Testing results:

The rust traces not exceed 10 % of the open surface of metal parts of the samples.

The samples' identification marking were legible when examined with normal or corrected vision without magnification.

There are no deteriorations of the main parts of the IPCs, which would impair their normal function.

The IPCs removal were realized with torque less than maximum manufacturer's specified torque 10,5 Nm.

Table 1 – Testing results when removing the IPCs after corrosion tests

| № | Identification number of IPC | Conductors: main – branch (mm ² / mm ²) | Torque of disassembling when removing the IPCs, Nm | Testing result |
|---|------------------------------|--|--|-------------------|
| 1 | 19 | min – min | 7,24 | Satisfy |
| | 20 | 6 – 1,5 | 8,36 | Satisfy |

5. Conclusion:

Insulation piercing connectors PC 120-16 after stay in the salt fog chamber and in the chamber with higher temperature and humidity atmosphere saturated by sulphur dioxide passed the corrosion aging tests and satisfy manufacturer's declared characteristics and EN 50483-4:2009 clause 8.1.5.1, 8.1.5.1.3.2 method 1.

6. Pictures:




Fig.1 – IPCs after the fourth cycle of testing




Fig.2 – IPCs after the testing

7. Test equipment:

| № | Type | Model | Latest calibration date |
|----|---|-------------------------------------|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 3 | Stopwatch | COC np-26-2-010 №2284 | 24.04.2020 |
| 4 | Salt fog chamber | ЛІЗО №001 | Don't need calibration |
| 5 | Measurement and control device with resistive temperature transducer | PT 0102 №14-558 ТСП-1388 №15-201 | 08.04.2020 |
| 6 | pH-meter | PH-009 інв. №00133 | Calibrated before using |
| 7 | Working standard pH | PH 4,01±0,01 | 15.06.2020 |
| 8 | Working standard pH | PH 7,00±0,01 | 15.06.2020 |
| 9 | Chamber with higher temperature and humidity atmosphere saturated by sulfur dioxide | ЛІЗО №001 | Don't need calibration |
| 10 | Measurement and control device with resistive temperature transducer | PT 0102 №14-557 ТСП-1388 №15-201 | 08.04.2020 |
| 11 | Tensile test machine, factory №001 | ЛІЗО №001 | Don't need calibration |
| 12 | Load cell | FB 50K №0032 | 06.04.2020 |





The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

Engineer:

Engineer:

 S. S. Lakhovskyi
 O. O. Nepyivoda
 D. S. Denys
 A. S. Shevtsiv



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel.: (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-5

Climatic aging test (UV-radiation) of insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clauses 8.1.5.2.4, 8.1.5.2.4.1, 8.1.5.2.4.3.

The test methods: EN 50483-4:2009 clauses 8.1.5.2, 8.1.5.2.3.2 method 2,
EN 50483-6:2009 clause 8.5.2.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: ***The insulation piercing connectors PC 120-16 have
passed the climatic aging test (UV-radiation).
Connectors satisfy the manufacturer's declared
characteristics and requirements of
EN 50483-4:2009 clauses 8.1.5.2, 8.1.5.2.3.2
method 2.***

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 4.
 Identification numbers of the samples: №21, №22, №23, №24.
 The testing dates: 16.07.2020 - 10.09.2020.
 The environmental conditions:
 temperature: (16 – 24) °C;
 air pressure: (96 – 101) kPa;
 humidity: (45 – 75) %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПВ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | |
|--------------------------|-------------------------------------|
| Type: | ПВ-3 1,5 |
| Conductor cross-section: | 1,5 mm ² |
| Conductor diameter: | 1,4 mm |
| Number of strands: | 31 |
| Shape: | Round |
| Conductor material: | Copper |
| Insulation thickness: | 0,7 mm |
| Insulation material: | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine |
| Standard: | IEC 60227-1:2007 |

2. Testing procedure:

2.1. Climatic aging test (UV-radiation)

The tests were performed in accordance with EN 50483-4:2009 clause 8.1.5.2, 8.1.5.2.3.2 method 2.


Two samples of IPC are tested in each of the following conductors' cross-sections combinations of main and branch conductors: min – min and max – min. IPC is installed at the core in accordance with manufacturer's installation instruction. The IPC bolt is tightened to the minimum torque - 7,5 Nm indicated by the manufacturer. Any changes in orientation of the core are absent in zone 10 cm from the IPC. Samples were tested for climatic aging in the solar radiation simulation chamber (Fig.2).

Testing chamber ensured radiation $1,120 \text{ kW/m}^2 \pm 10 \%$ in the measuring plane with the spectral distribution according to Table 1. Radiation was irradiated by the cylindrical lamp with xenon arc, with power 1 kW which was situated vertically at the center of the chamber. The IPCs samples were situated at the lamp center plane at the distance from the lamp center, which ensures the indicated power ($1,120 \text{ kW/m}^2 \pm 10 \%$). The radiation was controlled by the radiometer in the range of (300- 400) nm at the beginning of each cycle. Radiated power value was set $4,3 \text{ mW/cm}^2$ by the lamp electrical current change in case of necessity.

56 cycles with 24 hours durability were performed. Each cycle includes 20 hours of radiation and 4 hours with radiation power off with temperature modes in accordance with Fig.1. The temperature was measured by the shielded from the heat source thermometer in the plane which was situated 50 mm lower from the radiation measurement plane, at the middle of the distance from the sample to the chamber wall.

Table 1 – Spectral energy distribution and the tolerance

| № | Spectral range | Ultraviolet B | Ultraviolet A | Visible light | | | Infrared radiation |
|---|-----------------|--------------------|---------------------|----------------------|----------------------|----------------------|----------------------|
| 1 | Wavelength | 0,28 nm - 0,32 nm | 0,32 nm - 0,40 nm | 0,40 nm - 0,52 nm | 0,52 nm - 0,64 nm | 0,64 nm - 0,78 nm | 0,78 nm - 3,0 nm |
| 2 | Radiation power | 5 W/m ² | 63 W/m ² | 200 W/m ² | 186 W/m ² | 174 W/m ² | 492 W/m ² |
| 3 | Tolerance | ± 35 % | ± 25 % | ±10 % | ± 10 % | ± 10 % | ± 10 % |



1. 1 cycle;
2. radiation period (20 hours);

3. Y = temperature axis;
4. X = time axis in hours.

Fig.1 – Temperature – Radiation – Time dependence

2.2. Dielectrical voltage test in air after the climatic aging test (UV-radiation)

The tests were performed in accordance with EN 50483-4:2009 clause 8.1.3.1.3.2.

After the climatic aging test, the connectors, assembled together with core in the assemblies, are put into the tank and covered by (1 – 2) cm of metallic balls with (1,3 – 1,7) mm diameter.

After IPCs stay in tank under balls during 60 s the testing voltage 4 kV is applied between the main core conductor and the metallic balls during 60 s. The voltage is applied with the speed approximately 1 kV/s in accordance with EN 50483-1:2009 clause 9.1.7.

2.3. Dielectrical voltage test in water after the dielectrical voltage test in air

The tests were performed in accordance with EN 50483-4:2009 clause 8.1.3.1.3.1.

After dielectrical voltage test in air, the connectors assembled are put into the tank with water into the deep (30 – 40) cm from the connector to water surface.

After IPCs stay in tank under water during 30 min the testing voltage 1 kV is applied between the main core conductor and the metallic electrode, immersed into the water, during 60 s. The voltage is applied with the speed approximately 1 kV/s in accordance with EN 50483-1:2009 clause 9.1.7.

3. Requirements:

There shall be no degradation of the main parts, which will influence to the samples characteristics.

The sample's identification marking should be legible when examined with normal and corrected vision.

No flashover or breakdown of the core or IPC shall occur after testing by high voltage 4 kV during 60 s in air. The maximum leakage current shall not exceed $(10 \pm 0,5)$ mA in accordance with EN 50483-1:2009 clause 9.1.5.

No flashover or breakdown of the core or IPC shall occur after testing by high voltage 1 kV during 60 s in water. The maximum leakage current shall not exceed $(10 \pm 0,5)$ mA in accordance with EN 50483-1:2009 clause 9.1.5.

4. Testing results:

4.1. Testing results of climatic aging test (UV-radiation)

Insulation piercing connectors PC 120-16 have no any damages, which would influence the samples characteristics after the climatic aging test (UV-radiation).

The samples' identification markings are legible when examined with normal and corrected vision.

4.2. Testing results for the dielectrical voltage test in air after the climatic aging test (UV-radiation)

Table 2 – Testing results for the dielectrical voltage test in air

| № | Identification number of IPC | Conductors: main – branch (mm ² – mm ²) | Leakage current at voltage 4 kV with duration 60 s, mA |
|---|------------------------------|--|--|
| 1 | 21 | min – min | 0,0 |
| | 22 | 6 – 1,5 | 0,0 |
| 2 | 23 | max – min | 0,0 |
| | 24 | 120 – 1,5 | 0,0 |

4.3. Testing results for the dielectrical voltage test in water after the dielectrical voltage test in air

Table 3 – Testing results for the dielectrical voltage test in water

| № | Identification number of IPC | Conductors: main – branch (mm ² – mm ²) | Leakage current at voltage 1 kV with duration 60 s, mA |
|---|------------------------------|--|---|
| 1 | 21 | min – min | 3,0 |
| | 22 | 6 – 1,5 | 3,0 |
| 2 | 23 | max – min | 1,0 |
| | 24 | 120 – 1,5 | 2,0 |

5. Conclusion:

All samples of the insulation piercing connectors PC 120-16 have passed the dielectrical voltage test in air at high voltage 4 kV during 60 s and the dielectrical voltage test in water at high voltage 1 kV during 60 s after the climatic aging test (UV-radiation), satisfy the manufacturer declared characteristics and requirements of EN 50483-4:2009 clauses 8.1.5.2, 8.1.5.2.3.2 method 2.

6. Pictures:



Fig.2 – IPC during the testing in the solar radiation simulation chamber

7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|--|-------------------------------------|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 3 | Stopwatch | COC пр-26-2-010 №2284 | 24.04.2020 |
| 4 | Solar radiation simulation chamber | ЛІЗО №001 | Don't need calibration |
| 5 | Measurement and control device with resistive temperature transducer | PT-0102 №14-513 ТСП-1388 №14-026 | 08.04.2020 |
| 6 | UV radiometer | ТЕНЗОР-31 №P028/2014 | 31.03.2020 |
| 7 | High voltage set | ЛІЗО №001 | Don't need calibration |
| 8 | Voltmeter | E365-1 №913751 | 08.04.2020 |
| 9 | Milliamperemeter | E377 №777768 | 08.04.2020 |





The tests were performed by:

deputy head of the testing laboratory:

engineer:

engineer:

engineer:

 S. S. Lakhovskyi
 O. O. Nepyivoda
 D. S. Denys
 A. S. Shevtsiv



2H1383
DСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року


79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel.: (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The Head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-6

***Test for mechanical damage of the main conductor
of insulation piercing connectors PC 120-16***

Requirements: EN 50483-4:2009 clause 8.1.2.2.4.

The test methods: EN 50483-4:2009 clause 8.1.2.1.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: *The insulation piercing connectors PC 120-16 passed the test for mechanical damage of the main conductor and satisfies manufacturer's declared characteristics and requirement of EN 50483-4:2009 clause 8.1.2.1.*

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 6.
 Identification numbers of the samples: №25, №26, №27, №28, №29, №30.
 The testing dates: 17.08.2020.
 The environmental conditions:
 temperature: 24,6 °C;
 air pressure: 96,8 kPa;
 humidity: 69 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПВ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x16 | ПВ-3 1,5 |
| Conductor cross-section: | 16 mm ² | 1,5 mm ² |
| Conductor diameter: | 4,7 mm | 1,4 mm |
| Number of strands: | 7 | 31 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,2 mm | 0,7 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.2.1.

Two samples of IPCs are tested in each of the following conductors' cross-sections combinations of main and branch conductors: max-max, min – min and min – max.

The main core is inserted to the tensile machine as showed at Fig.1. Tensile load 10 % of MBL of the conductor is applied to it. The length of the main core is between 0,5 m to 1,5 m (EN 50483-4:2009 clause 8.1.2.1.2).

IPCs' samples are installed in accordance with manufacturer's installation instruction. The IPC bolt is tightened to the maximum torque 10,5 Nm indicated by the manufacturer. The tensile test load is applied to the main conductor until it reached values from Table 1 and maintained during 60 s.

Table 1 – Tensile test load applied to the main conductor

| № | System type | Conductor | Tensile test load |
|---|-----------------|---|---|
| 1 | Self supporting | Aluminium (16 mm ² to 25 mm ²) | 1200 N or 40 % MBL of the cable, whichever is the greater |
| | | Aluminium (> 25 mm ²) | 80 % MBL of the cable |

3. Requirements:

Main conductor shall sustain the tensile test load for 60 s without breaking or any damages that would prevent the correct function of the cable.

4. Testing results:

MBL determination of the ПБ-1 6. Three samples of the conductor were broken at tensile machine. Load applied with speed 50 N/s.

Calculated value of MBL of the conductor is 90% of intermediate value of last three breakes.

Table 2 – MBL of the cable ПБ-1 6

| № | № of the conductor sample | Conductor cross-section, mm ² | Breaking load of the conductor, kN | Mean value of breaking load of the conductor, kN | Calculated value of MBL of the conductor, kN |
|---|---------------------------|--|------------------------------------|--|--|
| 1 | 1 | 6 | 1,30 | 1,31 | 1,18 |
| 2 | 2 | | 1,32 | | |
| 3 | 3 | | 1,30 | | |

Table 3 – Testing results

| № | Identification number of IPC | Conductors: main - branch (mm ² - mm ²) | The tightening torque of the bolt, Nm | MBL of the main conductor, kN | Tensile test load for 60s, kN | Breaking or damages of the conductor |
|---|------------------------------|--|---------------------------------------|-------------------------------|-------------------------------|--------------------------------------|
| 1 | 25 | max – max 120 – 16 | 10,5 | 18,43 | 14,74 | Absent |
| | 26 | | | | | Absent |
| 2 | 27 | min – min 6 – 1,5 | 10,5 | 1,18 | 0,24 | Absent |
| | 28 | | | | | Absent |
| 3 | 29 | min – max 6 – 16 | 10,5 | 1,18 | 0,24 | Absent |
| | 30 | | | | | Absent |

5. Conclusion:

The main conductors at which IPCs PC 120-16 were installed and to which the tensile test load were applied, have passed the test for mechanical damage of the main conductor and satisfies requirement of EN 50483-4:2009 clause 8.1.2.1.

6. Pictures:




Fig.1 – IPCs in the test



7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|------------------------------------|---------------------------|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 3 | Stopwatch | COC np-26-2-010 №2284 | 24.04.2020 |
| 4 | Tensile test machine, factory №001 | ЛІЗО №001 | Don't need calibration |
| 5 | Load cell | FB 50K №0032 | 06.04.2020 |

The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

 S. S. Lakhovskyi
 O. O. Nepyivoda



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net


Accreditation certificate

№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel.: (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."


D. R. Dovgun
« 28 » « 09 » 2020

TESTING REPORT № 40/20-7

Branch cable pull-out test of insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.2.2.4.

The test methods: EN 50483-4:2009 clause 8.1.2.2.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: ***Insulation piercing connectors PC 120-16 passed the branch cable pull-out test, satisfies manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.2.2.***

The testing results are valid for the tested samples only.
This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 4.
 Identification numbers of the samples: №31, №32, №33, №34.
 The testing dates: 16.08.2020.
 The environmental conditions:
 temperature: 23,6 °C;
 air pressure: 96,7 kPa;
 humidity: 70 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПВ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | |
|--------------------------|-------------------------------------|
| Type: | ПВ-3 1,5 |
| Conductor cross-section: | 1,5 mm ² |
| Conductor diameter: | 1,4 mm |
| Number of strands: | 31 |
| Shape: | Round |
| Conductor material: | Copper |
| Insulation thickness: | 0,7 mm |
| Insulation material: | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine |
| Standard: | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.2.2.

Two samples of IPC are tested in each of the following conductors' cross-sections combinations of main and branch conductors: max – min, min – min.

IPC is inserted into the tensile machine as showed at Fig.1 in accordance with manufacturer's installation instruction. The branch core length is between 0,2 m to 0,5 m (EN 50483-4:2009 clause 8.1.2.2.2).

The IPC bolt is tightened to the maximum torque 10,5 Nm indicated by the manufacturer. The mark is made near the IPC at the branch cable, which will permit to measure its slippage. The tensile load is applied approximately axially between the branch conductor and opposing main conductor with the rate between 100 N/min to 500 N/min. This load is 10 % of the MBL of the branch conductor and is maintained for 60 s.

3. Requirements:

Branch core slippage shall not exceed 3 mm. The cores shall maintain the test load for 60 s without breaking or any damages that would prevent the correct function of the cable.

4. Testing results:

MBL determination of the ПБ-3 1,5. Three samples of the conductor were broken at tensile machine. Load applied with speed 50 N/s.

Calculated value of MBL of the conductor is 90% of intermediate value of last three breakes.

Table 1: MBL of the cable ПБ-3 1,5

| № | № of the conductor sample | Conductor cross-section, mm ² | Breaking load of the conductor, kN | Mean value of breaking load of the conductor, kN | RTS of the conductor, kN |
|---|---------------------------|--|------------------------------------|--|--------------------------|
| 1 | 1 | 1,5 | 0,40 | 0,41 | 0,37 |
| 2 | 2 | | 0,42 | | |
| 3 | 3 | | 0,40 | | |

Table 2 – Testing results

| № | Identification number of IPC | Conductors: main – branch (mm ² – mm ²) | The testing load: 60 s, 10 % of the MBL, kN | Branch conductor slippage, mm | Breaking or damages of the conductors |
|---|------------------------------|--|---|-------------------------------|---------------------------------------|
| 1 | 31 | max – min | 0,04 | 0 | Absent |
| | 32 | 120 – 1,5 | | 0 | Absent |
| 2 | 33 | min – min | 0,04 | 0 | Absent |
| | 34 | 6 – 1,5 | | 0 | Absent |

5. Conclusion:

There was no slippage of the branch conductors during the testing of the IPCs PC 120-16. The cores maintained the test load for 60 s without breaking or any damages that would prevent the correct function of the cable.

Insulation piercing connectors PC 120-16 passed the branch cable pull-out test and satisfies requirements of EN 50483-4:2009 clause 8.1.2.2.

6. Pictures:

Fig.1 – IPC in the test


7. Test equipment:


| № | Type | Model | Latest calibration date |
|---|------------------------------------|---------------------------|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 3 | Stopwatch | COC np-26-2-010 №2284 | 24.04.2020 |
| 4 | Tensile test machine, factory №001 | ЛІЗО №001 | Don't need calibration |
| 5 | Load cell | FB 50K №0032 | 06.04.2020 |
| 6 | Slide gage | ШЦ-1 №0701295 | 05.04.2020 |

The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

 S. S. Lakhovskyi

 D. S. Denys



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-8

Connector bolt tightening test for insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.2.3.4.

The test methods: EN 50483-4:2009 clause 8.1.2.3.

Product name: Insulation piercing connector (IPC)

Model and type: PC 120-16

**Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia**

**Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia**

Reason: Contract № 12-06-20 of 25.06.2020

Testing results: *Insulation piercing connectors PC 120-16 have passed the connector bolt tightening test, satisfies manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.2.3.*

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 6.
 Identification numbers of the samples: №35, №36, №37, №38, №39, №40.
 The testing dates: 17.08.2020.
 The environmental conditions:
 temperature: 24,6 °C;
 air pressure: 96,8 kPa;
 humidity: 69 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПБ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x16 | ПБ-3 1,5 |
| Conductor cross-section: | 16 mm ² | 1,5 mm ² |
| Conductor diameter: | 4,7 mm | 1,4 mm |
| Number of strands: | 7 | 31 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,2 mm | 0,7 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.2.3.

Two samples of IPCs are tested in each of the following conductors' cross-sections combinations of main and branch conductors: max – max, min – min and min – max.

The connector is installed at the main core, which is tensioned previously to 20 % of MBL of the core.

The connectors are installed as shown at Fig. 1 and tightened with torque 12,6 Nm which is 20 % greater than maximum torque (10,5 Nm) specified by the manufacturer.

3. Requirements:

The connector shall be undamaged.

4. Testing results:

Table 1 – Testing results

| № | Identification number of IPC | Conductors: main – branch (mm ² – mm ²) | MBL of the main conductor, kN | Tensile load of the main core 20 % of the MBL, kN | The tightening torque of the connector's bolt, Nm | Breaking or damaging of the IPC |
|---|------------------------------|--|-------------------------------|---|---|---------------------------------|
| 1 | 35 | max – max 120 – 16 | 18,43 | 3,69 | 12,6 | Absent |
| | 36 | | | | | Absent |
| 2 | 37 | min – min 6 – 1,5 | 1,18 | 0,24 | 12,6 | Absent |
| | 38 | | | | | Absent |
| 3 | 39 | min – max 6 – 16 | 1,18 | 0,24 | 12,6 | Absent |
| | 40 | | | | | Absent |

5. Conclusion:

Insulation piercing connectors PC 120-16 have no any damages after applying of the torque 12,6 Nm to the connectors' bolts. This torque is 20 % greater than maximum torque specified by the manufacturer (10,5 Nm). IPC PC 120-16 satisfy requirements of EN 50483-4:2009 clause 8.1.2.3.

6. Pictures:

Fig.1 – IPC in the test

7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|------------------------------------|---------------------------|-------------------------|
| 1 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 2 | Tensile test machine, factory №001 | ЛІЗО №001 | Don't need calibration |
| 3 | Load cell | FB 50K №0032 | 06.04.2020 |

The tests were performed by:

Deputy Head of the testing laboratory:

S. S. Lakhovskyi

Engineer:

O. O. Nepyivoda



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-9

Shear head function test of insulation piercing connector PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.2.4.4.

The test methods: EN 50483-4:2009 clause 8.1.2.4.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: *The insulation piercing connectors PC 120-16 passed the shear head function test, satisfies the manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.2.4.*

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 24.
 Identification numbers of the samples: №41 ... №64.
 The testing dates: 21.08.2020.
 The environmental conditions:
 temperature: (23,6 – 24,0) °C;
 air pressure: 97,8 kPa;
 humidity: (70 – 71) %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПВ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x16 | ПВ-3 1,5 |
| Conductor cross-section: | 16 mm ² | 1,5 mm ² |
| Conductor diameter: | 4,7 mm | 1,4 mm |
| Number of strands: | 7 | 31 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,2 mm | 0,7 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.2.4.

Six samples of IPC are tested in each of the following conductors' cross-sections combinations of main and branch conductors: min – min, max – max.

The tests are performed for each of the testing temperatures:

- minimum temperature: -10°C ($\pm 3^{\circ}\text{C}$);
- maximum temperature: 50°C ($\pm 3^{\circ}\text{C}$).

Prepared assemblies are placed in the chamber with controlled temperature until they reach the testing temperature. The testing temperature is maintained in the chamber during 15 minutes. The shear head is tightened in accordance with the manufacturer's installation instruction. Value of the tightening torque is registered by the electronic torque wrench (Fig.1, Fig.2).

3. Requirements:

For each of the testing temperatures and cross-section combinations, the torque, at which the shear head is sheared, should be within the tolerances of the manufacturer's specified torque range ($9 \pm 1,5$) Nm.

4. Testing results:

Table 1 – Testing results

| № | Identification number of IPC | Conductors: main - branch ($\text{mm}^2 - \text{mm}^2$) | Environmental temperature the assembly preliminary equalizing, $^{\circ}\text{C}$ | IPC shear heads tightening torque value, Nm | Testing results |
|---|------------------------------|---|---|---|-----------------|
| 1 | 41 | min – min 6 – 1,5 | -10 | 7,62 | Satisfy |
| | 42 | | | 7,51 | Satisfy |
| | 43 | | | 9,55 | Satisfy |
| | 44 | | | 9,99 | Satisfy |
| | 45 | | | 8,16 | Satisfy |
| | 46 | | | 7,53 | Satisfy |
| 2 | 47 | | 50 | 7,68 | Satisfy |
| | 48 | | | 8,62 | Satisfy |
| | 49 | | | 7,52 | Satisfy |
| | 50 | | | 7,54 | Satisfy |
| | 51 | | | 9,48 | Satisfy |
| | 52 | | | 7,86 | Satisfy |
| 3 | 53 | max – max 120 – 16 | -10 | 8,45 | Satisfy |
| | 54 | | | 8,65 | Satisfy |
| | 55 | | | 9,43 | Satisfy |
| | 56 | | | 9,15 | Satisfy |
| | 57 | | | 8,02 | Satisfy |
| | 58 | | | 9,19 | Satisfy |
| 4 | 59 | | 50 | 9,17 | Satisfy |
| | 60 | | | 8,40 | Satisfy |
| | 61 | | | 8,12 | Satisfy |
| | 62 | | | 7,52 | Satisfy |
| | 63 | | | 7,97 | Satisfy |
| | 64 | | | 7,59 | Satisfy |

5. Conclusion:

The insulation piercing connectors PC 120-16 passed the shear head function test within the bounds of the manufacturer indicated tightening torque ($9 \pm 1,5$) Nm under low temperature -10°C ($\pm 3^{\circ}\text{C}$) and under high temperature 50°C ($\pm 3^{\circ}\text{C}$). The insulation piercing connectors PC 120-16 satisfy the manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.2.4.

6. Pictures:



Fig.1 – Testing under maximal temperature




Fig.2 – Testing under minimal temperature



7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|--|-------------------------------------|-------------------------|
| 1 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 2 | Cold chamber | ЛІЗО № 001 | Don't need calibration |
| 3 | Temperature measurement and control device with resistive temperature transducer | РТ-0102 №14-571 ТСП-0287 №14-039 | 08.04.2020 |
| 4 | Electrical chamber (heat chamber) | Едельвейс №0298 | Don't need calibration |
| 5 | Temperature measurement and control device with resistive temperature transducer | РТ-0102 №15-398 ТСП-0287 №15-009 | 09.04.2020 |

The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

 S. S. Lakhovskyi
 D. S. Denys



2H1383
DСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року


79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The Head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-10

Low temperature impact test of insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.2.5.4.

The test methods: EN 50483-4:2009 clause 8.1.2.5.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: *Insulation piercing connectors PC 120-16 passed low temperature impact test, satisfy the manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.2.5.*

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 4.
 Identification numbers of the samples: №65, №66, №67, №68.
 The testing dates: 21.08.2020.
 The environmental conditions:
 temperature: 24,0 °C;
 air pressure: 97,2 kPa;
 humidity: 70 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

Type: AsXSn 4x120
 Conductor cross-section: 120 mm²
 Conductor diameter: 12,5 mm
 Number of strands: 19
 Shape: Round
 Conductor material: Aluminum
 Insulation thickness: 1,7 mm
 Insulation material: XLPE
 Manufacturer / country: PJSC «Yuzhcable works» /
 Ukraine
 Standard: HD626:S1

The branch conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x16 | ПВ-3 1,5 |
| Conductor cross-section: | 16 mm ² | 1,5 mm ² |
| Conductor diameter: | 4,7 mm | 1,4 mm |
| Number of strands: | 7 | 31 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,2 mm | 0,7 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.2.5.

Two samples of IPCs are tested in each of the following conductors' cross-sections combinations of main and branch conductors: max – min and max – max.

Assemblies are placed in the cold chamber with controlled temperature until they reached the testing temperature -10°C ($\pm 3^{\circ}\text{C}$).

The assemblies are removed from the cold chamber by turns and are tested for impact from top and from side with help of the impact test device shown at Fig.1.

The testing samples of the IPCs are placed between the metallic plane and anvil 50 mm in diameter with a spherical contact radius of 300 mm and mass 100 g. The impacts are dashed to anvil with the help of cylindrical weight 900 g falling freely through 200 mm.

3. Requirements:

No damage should occur which would affect the correct function of the connector.

4. Testing results:

Table 1 – Testing results

| № | Identification number of IPC | Conductors: main – branch ($\text{mm}^2 - \text{mm}^2$) | The samples temperature during the testing, $^{\circ}\text{C}$ | Damages |
|---|------------------------------|---|--|---------|
| 1 | 65 | max – min | -10 | Absent |
| | 66 | 120 – 1,5 | | Absent |
| 2 | 67 | max – max | -10 | Absent |
| | 68 | 120 – 16 | | Absent |

5. Conclusion:

Insulation piercing connectors PC 120-16 have no any damages which would impede the correct function of the connectors after the low temperature -10°C ($\pm 3^{\circ}\text{C}$) impact test. Connectors have passed the tests and satisfy the manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.2.5.


6. Pictures:

Fig.1 – IPCs during the testing



7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|--|-------------------------------------|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 3 | Cold chamber | ЛІЗО № 001 | Don't need calibration |
| 4 | Temperature measurement and control device with resistive temperature transducer | PT-0102 №14-571 ТСР-0287 №14-039 | 08.04.2020 |
| 5 | Impact device | ЛІЗО №001 | Don't need calibration |

The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

S. S. Lakhovskyi

O. O. Nepyivoda



2H1383
DSTU ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року

79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate

№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The Head of the
testing laboratory of "LIZO Ltd."

D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-11

Low temperature assembly test of insulation piercing connectors PC 120-16

Requirements: EN 50483-4:2009 clause 8.1.4.4.

The test methods: EN 50483-4:2009 clause 8.1.4.

Product name: Insulation piercing connector (IPC)

Model and type: PC 120-16

Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia

Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia

Reason: Contract № 12-06-20 of 25.06.2020

Testing results: *The assemblies of the insulation piercing connectors PC 120-16 passed the test for stability of the electrical contact between conductors under low temperature, satisfy manufacturer's declared characteristics and requirements of EN 50483-4:2009 clause 8.1.4.*

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 6.
 Identification numbers of the samples: №69, №70, №71, №72, №73, №74.
 The testing dates: 21.08.2020.
 The environmental conditions:
 temperature: 24,0 °C;
 air pressure: 97,8 kPa;
 humidity: 70 %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПВ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x16 | ПВ-3 1,5 |
| Conductor cross-section: | 16 mm ² | 1,5 mm ² |
| Conductor diameter: | 4,7 mm | 1,4 mm |
| Number of strands: | 7 | 31 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,2 mm | 0,7 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-4:2009 clause 8.1.4.

Two samples of IPCs are tested in each of the following conductors' cross-sections combinations of main and branch conductors: max – max, min – max and max – min.

The conductors and IPCs are cooled to the testing temperature -10°C ($\pm 3^{\circ}\text{C}$) before the tests.

The connector's bolt is tightened with the help of electronic torque wrench before the stable electrical contact occurrence between the conductors, which is fixed with the help of ohmmeter after the assembly of the conductors and connectors achieved the temperature -10°C ($\pm 3^{\circ}\text{C}$). We are fixing the tightening torque of the connector's bolt at which stable electrical contact is obtained (Fig.1).

3. Requirements:

Stable electrical contact should be achieved between the conductors under the low temperature -10°C ($\pm 3^{\circ}\text{C}$) with connector's nut tightening torque less or equal to 70 % of the minimum tightening torque declared by the manufacturer (7,5 Nm), notably 5,25 Nm.

4. Testing results:

Table 1 – Testing results

| No | Identification number of IPC | Conductors: main - branch (mm^2 - mm^2) | The sample's temperature during the testing, $^{\circ}\text{C}$ | The tightening torque of the connector's bolt at which stable electrical contact between conductors was achieved, Nm | Testing result |
|----|------------------------------|---|---|--|----------------|
| 1 | 69 | max – max | -10 | 4,36 | Satisfy |
| | 70 | 120 – 16 | | 4,44 | Satisfy |
| 2 | 71 | min – max | -10 | 3,86 | Satisfy |
| | 72 | 6 – 16 | | 4,10 | Satisfy |
| 3 | 73 | max – min | -10 | 4,80 | Satisfy |
| | 74 | 120 – 1,5 | | 5,02 | Satisfy |

5. Conclusion:

The assemblies of the insulation piercing connectors PC 120-16 passed the test for stability of the electrical contact between conductors under low temperature -10°C ($\pm 3^{\circ}\text{C}$) with connector's bolt tightening torque less or equal to 70 % of the minimum tightening torque declared by the manufacturer (7,5 Nm), satisfies requirements of EN 50483-4:2009 clause 8.1.4.


6. Pictures:

Fig.1 – IPC during the test

7. Test equipment:

| № | Type | Model | Latest calibration date |
|---|--|-------------------------------------|-------------------------|
| 1 | Torque wrench | DG2-030 №DG2-030-07000584 | 05.04.2020 |
| 2 | Cold chamber | ЛІЗО № 001 | Don't need calibration |
| 3 | Temperature measurement and control device with resistive temperature transducer | PT-0102 №14-571 ТСП-0287 №14-039 | 08.04.2020 |
| 4 | Multimeter | Topex №11602228 | Don't need calibration |

The tests were performed by:

Deputy Head of the testing laboratory:

S. S. Lakhovskyi

Engineer:

A. S. Shevtsiv



2H1383
ДСТУ ISO/IEC 17025

Атестат акредитації
№ 2H1383
Дійсний до
16 червня 2021 року


79035, Україна, м. Львів
вул. М.Пимоненко, 3
тел.: (032) 294-82-87,
e-mail: lablizo@ukr.net

Accreditation certificate
№ 2H1383
Expiry date:
16 June, 2021

79035, Ukraine, Lviv
st. Pymonenko, 3
Tel. : (032) 294-82-87,
e-mail: lablizo@ukr.net



Approved by
The head of the
testing laboratory of "LIZO Ltd."

 D. R. Dovgun
« 28 » 09 2020

TESTING REPORT № 40/20-12

Electrical ageing test of insulation piercing connectors PC 120-16

Requirements: EN 50483-5:2009 clause 8.6.

The test methods: EN 50483-4:2009 clause 8.1.6 and EN 50483-5:2009.

Product name: Insulation piercing connector (IPC)
Model and type: PC 120-16
Manufacturer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Customer: "FEMAN" D.O.O
Vihorska 1, 35000 Jagodina, Serbia
Reason: Contract № 12-06-20 of 25.06.2020
Testing results: *Insulation piercing connectors PC 120-16 have passed the electrical ageing test, satisfies manufacturer's declared characteristics and requirements of EN 50483-5:2009.*

The testing results are valid for the tested samples only.

This testing report can't be reproduced partly, duplicated and distributed as an official document without permission of the testing laboratory.

Lviv - 2020

Samples' receiving date: 15.07.2020
 Quantity of the tested samples: 12.
 Identification numbers of the samples: №1 ... №12.
 The testing dates: 20.07.2020 - 29.08.2020.
 The environmental conditions:
 temperature: (16 – 24) °C;
 air pressure: (96 – 101) kPa;
 humidity: (45 – 75) %.

1. Tested samples:

Insulation piercing connectors:

Model and type: PC 120-16.
 Class: A1.
 Main conductor cross-sections: (6 – 120) mm².
 Branch conductor cross-sections: (1,5 – 16) mm².
 The tightening torque of the bolt: (9 ± 1,5) Nm.
 Batch number: 05/20.
 Installation temperature: From -10 °C to +50 °C.

The main conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x120 | ПБ-1 6 |
| Conductor cross-section: | 120 mm ² | 6 mm ² |
| Conductor diameter: | 12,5 mm | 2,75 mm |
| Number of strands: | 19 | 1 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,7 mm | 1,0 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

The branch conductors:

| | | |
|--------------------------|-------------------------------------|-------------------------------------|
| Type: | AsXSn 4x16 | ПБ-3 1,5 |
| Conductor cross-section: | 16 mm ² | 1,5 mm ² |
| Conductor diameter: | 4,7 mm | 1,4 mm |
| Number of strands: | 7 | 31 |
| Shape: | Round | Round |
| Conductor material: | Aluminum | Copper |
| Insulation thickness: | 1,2 mm | 0,7 mm |
| Insulation material: | XLPE | PVC |
| Manufacturer / country: | PJSC «Yuzhcable works» / Ukraine | PJSC «Yuzhcable works» / Ukraine |
| Standard: | HD626:S1 | IEC 60227-1:2007 |

2. Testing procedure:

The tests are performed in accordance with EN 50483-5:2009.

Two circuits (Fig.2) are mounted with main and branch conductors for the following conductors' cross-sections combinations: max – max and min – min.

The conducting paths lengths and configuration are chosen in accordance with Fig.1 and Table 1 of EN 50483-5:2009 and specified in Table 1.

Table 1 – The conducting paths lengths

| № | The conducting paths lengths, mm | | | | |
|---|----------------------------------|-------|----------|----------|-----|
| | l_a | l_b | l_{ra} | l_{rb} | d |
| 1 | 200 | 150 | 350 | 350 | 880 |
| 2 | 150 | 150 | 300 | 300 | 600 |

The circuit is made by welding of the conductors, which insures uniform distribution of the electrical current in the measurement points.

The dimensional stabilization of the insulating sheath of the conductors is performed in the heat chamber during 1 hour under temperature 30 °C higher than rated temperature of the conductor, before conductors' welding.

IPCs are installed in accordance with manufacturer's installation instructions with nut tightening torque 7,5 Nm, which is minimal tightening torque specified by the manufacturer. Tightening is provided in accordance with EN 50483-1:2009 clause 9.1.8, speed of tightening complied to EN 50483-1:2009 clause 9.1.10.

The temperature of the reference conductors and the connectors is measured by the resistive temperature transducer in accordance with EN 50483-5:2009 clause 5.4.1.

The electrical resistance of the IPCs and the reference conductors are measured between two adjacent measurement points (points of the potential balancing) under the direct current. Measurements are performed by volt-ammeter method. The resistance is calculated by division of the voltage drop to the direct current value which is not more than 10 % of the heat cycle current value. Direct current and voltage drop measurement is performed with the precision of measurements within the range $\pm 0,2$ %.


1000 heat cycles are needed.

Measurements of the temperature and resistance valuation are made for the next cycles:

- 0 (before the heat cycle), only valuation of the resistance;
- 200, before short circuit;
- 200, after short circuit;
- 250;
- else after each 75 cycles (14 measurements in sum).

Temperature measurement and resistance valuation are provided for the reference conductors and all IPCs. The results are documented. Maximum temperatures of the reference conductors and of each IPC are fixed immediately before or after the heat cycle.

The resistance of each IPC of the circuit is measured before the first heat cycle. The purpose of the first heat cycle is to determine the reference conductor temperature for its application in subsequent cycles and to identify the median temperature connector. The curve of a heat cycle is shown at Fig.1.




1. temperature axis;
2. temperature of the reference conductor θ_R ;
3. median temperature of the connector;
4. temperature $\leq 35^\circ\text{C}$ for connectors and reference conductor;
5. time axis.

Fig.1 – First heat cycle

The resistance calculations for the testing loop connectors are performed after 200 cycles of heating and cooling. Then six short-circuits are applied for each connector from the testing loop. The short-circuit test is performed by short impulses. The duration of each impulse is $(t_{sc} \pm 0,15)$ s. The testing loop is cooled to the temperature $\leq 35^\circ\text{C}$ after each impulse. The short-circuit current I_{sc} depends of the testing loop conductor with smaller cross-section.

The measurements results evaluation and the calculation of the following parameters are performed after 1000 cycles of heating-cooling:

- the initial scatter δ , between six initial values of resistances R_j , calculated before the first heat cycle;
- the mean scatter β , between the six values of resistance R_j , averaged over the last 11 measurement intervals;
- ratio λ of the resistances, calculated for heat cycles to the resistances, calculated for initial cycle;
- the resistance stability, calculated for last 11 measurements;
- the maximum temperature $\theta_{j\max}$ on each connector;
- the stability of the connector's temperature $\Delta\theta_j$;



A – cross section of the conductor (mm^2);
 d – length of the conductor between IPC's;
 $d \geq 80\sqrt{A}$ or 500 mm minimum;
 p.p. – potential point;
 TC – thermocouple.

1. Reference conductor A_2R_2 with insulation between equalizers;
2. Reference conductor A_1R_1 with insulation between equalizers;
3. IPCs;
4. Conductor A_2R_2 with insulation between equalizers;
5. Conductor A_1R_1 with insulation between equalizers;
6. Resistance adapter;
7. Switch.

Fig.2 – Testing loop

3. Requirements:

Table 2 – Test requirements

| No | Parameter | Maximum value |
|----|--|--|
| 1 | Initial scatter δ | 0,3 |
| 2 | Mean scatter β | 0,3 |
| 3 | Assessment of resistance stability | 15 % |
| 4 | Resistance factor ratio λ | 2,0 |
| 5 | Temperature stability $\Delta\theta_j$ | $\overline{\Delta\theta_j} - 10 \quad \Delta\theta_j \quad \overline{\Delta\theta_j} + 10$ |
| 6 | Maximum temperature θ_j of each connector | θ_R |

4. Testing results:

4.1. Connectors testing results in circuit with conductors combination (max – max) 120 mm² – 16 mm²

Table 3 – Medium value, stability and ratio of the connectors' resistances *

| № | Cycle | IPC №1 | | IPC №2 | | IPC №3 | | IPC №4 | | IPC №5 | | IPC №6 | |
|----|------------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|
| | | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ |
| 1 | 0 | 82,1 | - | 80,3 | - | 68,5 | - | 77,1 | - | 94,1 | - | 83,3 | - |
| 2 | 200 | 138,7 | 1,69 | 125,0 | 1,56 | 109,9 | 1,61 | 118,9 | 1,54 | 164,0 | 1,74 | 131,2 | 1,57 |
| 3 | 200 | 128,8 | 1,57 | 113,2 | 1,41 | 99,2 | 1,45 | 119,8 | 1,55 | 165,7 | 1,76 | 121,3 | 1,46 |
| 4 | 250 | 142,1 | 1,73 | 122,9 | 1,53 | 111,6 | 1,63 | 122,9 | 1,59 | 166,8 | 1,77 | 142,6 | 1,71 |
| 5 | 325 | 144,5 | 1,76 | 123,9 | 1,54 | 117,5 | 1,72 | 125,9 | 1,63 | 168,5 | 1,79 | 146,0 | 1,75 |
| 6 | 400 | 150,0 | 1,83 | 125,6 | 1,57 | 118,0 | 1,72 | 130,4 | 1,69 | 167,5 | 1,78 | 154,4 | 1,85 |
| 7 | 475 | 153,6 | 1,87 | 128,6 | 1,60 | 118,7 | 1,73 | 133,1 | 1,73 | 169,8 | 1,80 | 157,2 | 1,89 |
| 8 | 550 | 149,9 | 1,83 | 133,9 | 1,67 | 116,3 | 1,70 | 134,1 | 1,74 | 173,4 | 1,84 | 158,2 | 1,90 |
| 9 | 625 | 152,1 | 1,85 | 132,3 | 1,65 | 119,6 | 1,75 | 136,8 | 1,78 | 174,5 | 1,86 | 157,2 | 1,89 |
| 10 | 700 | 154,6 | 1,88 | 138,1 | 1,72 | 127,8 | 1,87 | 141,5 | 1,84 | 178,1 | 1,89 | 159,4 | 1,91 |
| 11 | 775 | 161,5 | 1,97 | 141,6 | 1,76 | 124,8 | 1,82 | 142,0 | 1,84 | 179,4 | 1,91 | 161,8 | 1,94 |
| 12 | 850 | 158,5 | 1,93 | 140,9 | 1,76 | 124,8 | 1,82 | 142,9 | 1,85 | 179,9 | 1,91 | 157,6 | 1,89 |
| 13 | 925 | 159,0 | 1,94 | 141,2 | 1,76 | 126,6 | 1,85 | 142,3 | 1,85 | 182,6 | 1,94 | 160,9 | 1,93 |
| 14 | 1000 | 159,0 | 1,94 | 141,4 | 1,76 | 127,8 | 1,87 | 142,5 | 1,85 | 182,3 | 1,94 | 161,5 | 1,94 |
| 15 | Mean resistances value | 153,2 | - | 133,7 | - | 121,2 | - | 135,9 | - | 174,8 | - | 156,1 | - |
| 16 | Resistance stability | 12,7 % | - | 14,0 % | - | 13,4 % | - | 14,7 % | - | 9,0 % | - | 12,3 % | - |

* Value of the connectors resistance indicated for temperature 20 °C.

Thermal profile: I_N = 450 A, I_B = 130 A, t_{1-a} = 12 min, t_{1-b} = 12 min, t₂ = 11 min, I = 15 A.SC test: I_{sc} = 1918 A, t_{sc} = 1,0 s.

Table 4 – Maximum temperature and temperature stability of the connectors

| № | Cycle | Main conductor | Branch conductor | IPC №1 | | IPC №2 | | IPC №3 | | IPC №4 | | IPC №5 | | IPC №6 | | In circuit |
|----|------------|----------------|------------------|--------|------|--------|------|--------|------|--------|------|--------|------|--------|------|------------|
| | | T (°C) | T (°C) | T (°C) | Δθj | T (°C) | Δθj | T (°C) | Δθj | T (°C) | Δθj | T (°C) | Δθj | T (°C) | Δθj | T (°C) |
| 1 | 1 | 98,0 | 97,0 | 71,0 | - | 75,0 | - | 72,0 | - | 74,0 | - | 73,0 | - | 70,0 | - | 19,5 |
| 2 | 200 | 97,0 | 97,0 | 75,0 | 22,0 | 78,0 | 19,0 | 75,0 | 22,0 | 80,0 | 17,0 | 83,0 | 14,0 | 72,0 | 25,0 | 23,0 |
| 3 | 200 | 98,0 | 97,0 | 75,0 | 23,0 | 79,0 | 19,0 | 76,0 | 22,0 | 83,0 | 15,0 | 85,0 | 13,0 | 73,0 | 25,0 | 23,2 |
| 4 | 250 | 98,0 | 98,0 | 76,0 | 22,0 | 78,0 | 20,0 | 77,0 | 21,0 | 84,0 | 14,0 | 85,0 | 13,0 | 74,0 | 24,0 | 23,8 |
| 5 | 325 | 98,0 | 99,0 | 77,0 | 21,0 | 79,0 | 19,0 | 77,0 | 21,0 | 85,0 | 13,0 | 86,0 | 12,0 | 75,0 | 23,0 | 23,4 |
| 6 | 400 | 98,0 | 98,0 | 79,0 | 19,0 | 79,0 | 19,0 | 78,0 | 20,0 | 86,0 | 12,0 | 85,0 | 13,0 | 75,0 | 23,0 | 23,6 |
| 7 | 475 | 98,0 | 98,0 | 80,0 | 18,0 | 80,0 | 18,0 | 79,0 | 19,0 | 86,0 | 12,0 | 85,0 | 13,0 | 75,0 | 23,0 | 23,2 |
| 8 | 550 | 98,0 | 99,0 | 80,0 | 18,0 | 80,0 | 18,0 | 80,0 | 18,0 | 88,0 | 10,0 | 86,0 | 12,0 | 75,0 | 23,0 | 26,9 |
| 9 | 625 | 98,0 | 99,0 | 80,0 | 18,0 | 82,0 | 16,0 | 82,0 | 16,0 | 87,0 | 11,0 | 85,0 | 13,0 | 74,0 | 24,0 | 26,0 |
| 10 | 700 | 98,0 | 99,0 | 81,0 | 17,0 | 83,0 | 15,0 | 84,0 | 14,0 | 88,0 | 10,0 | 85,0 | 13,0 | 74,0 | 24,0 | 21,6 |
| 11 | 775 | 98,0 | 98,0 | 81,0 | 17,0 | 83,0 | 15,0 | 85,0 | 13,0 | 88,0 | 10,0 | 85,0 | 13,0 | 75,0 | 23,0 | 23,6 |
| 12 | 850 | 98,0 | 98,0 | 82,0 | 16,0 | 83,0 | 15,0 | 86,0 | 12,0 | 88,0 | 10,0 | 85,0 | 13,0 | 74,0 | 24,0 | 23,8 |
| 13 | 925 | 98,0 | 98,0 | 82,0 | 16,0 | 83,0 | 15,0 | 86,0 | 12,0 | 88,0 | 10,0 | 85,0 | 13,0 | 74,0 | 24,0 | 24,0 |
| 14 | 1000 | 98,0 | 98,0 | 82,0 | 16,0 | 84,0 | 14,0 | 87,0 | 11,0 | 90,0 | 8,0 | 86,0 | 12,0 | 75,0 | 23,0 | 24,3 |
| 15 | Max. value | 98,0 | 99,0 | 82,0 | - | 84,0 | - | 87,0 | - | 90,0 | - | 86,0 | - | 75,0 | - | 26,9 |
| 16 | Δθj | - | - | - | 18,0 | - | 16,7 | - | 16,1 | - | 10,9 | - | 12,7 | - | 23,5 | - |

4.2. Connectors testing results in circuit with conductors combination (min – min) 6 mm² – 1,5 mm²

Table 5 – Medium value, stability and ratio of the connectors' resistances *

| № | Cycle | IPC №1 | | IPC №2 | | IPC №3 | | IPC №4 | | IPC №5 | | IPC №6 | |
|----|------------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|----------------|---------------------|
| | | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ | Resistance, mΩ | Resistance ratio, λ |
| 1 | 0 | 149,3 | - | 132,3 | - | 148,6 | - | 159,8 | - | 140,1 | - | 154,9 | - |
| 2 | 200 | 181,7 | 1,22 | 143,5 | 1,08 | 179,0 | 1,20 | 189,3 | 1,18 | 158,2 | 1,13 | 185,3 | 1,20 |
| 3 | 200 | 185,8 | 1,24 | 141,0 | 1,07 | 173,8 | 1,17 | 186,6 | 1,17 | 159,2 | 1,14 | 179,5 | 1,16 |
| 4 | 250 | 198,5 | 1,33 | 147,1 | 1,11 | 182,8 | 1,23 | 192,2 | 1,20 | 166,8 | 1,19 | 185,8 | 1,20 |
| 5 | 325 | 201,9 | 1,35 | 154,6 | 1,17 | 185,0 | 1,25 | 195,3 | 1,22 | 168,7 | 1,20 | 188,5 | 1,22 |
| 6 | 400 | 208,9 | 1,40 | 158,9 | 1,20 | 186,3 | 1,25 | 197,5 | 1,24 | 172,2 | 1,23 | 189,8 | 1,23 |
| 7 | 475 | 208,5 | 1,40 | 157,3 | 1,19 | 191,1 | 1,29 | 198,9 | 1,24 | 175,7 | 1,25 | 196,1 | 1,27 |
| 8 | 550 | 208,3 | 1,40 | 164,4 | 1,24 | 196,9 | 1,33 | 207,6 | 1,30 | 183,6 | 1,31 | 204,0 | 1,32 |
| 9 | 625 | 214,6 | 1,44 | 163,1 | 1,23 | 198,2 | 1,33 | 205,3 | 1,28 | 183,5 | 1,31 | 201,1 | 1,30 |
| 10 | 700 | 211,0 | 1,41 | 161,9 | 1,22 | 194,8 | 1,31 | 201,7 | 1,26 | 185,7 | 1,33 | 206,0 | 1,33 |
| 11 | 775 | 214,7 | 1,44 | 164,7 | 1,24 | 201,1 | 1,35 | 205,8 | 1,29 | 181,5 | 1,30 | 208,8 | 1,35 |
| 12 | 850 | 217,3 | 1,46 | 170,9 | 1,29 | 201,8 | 1,36 | 207,9 | 1,30 | 188,5 | 1,35 | 210,1 | 1,36 |
| 13 | 925 | 216,9 | 1,45 | 167,8 | 1,27 | 202,7 | 1,36 | 213,1 | 1,33 | 189,4 | 1,35 | 211,0 | 1,36 |
| 14 | 1000 | 222,9 | 1,49 | 170,6 | 1,29 | 201,8 | 1,36 | 214,8 | 1,34 | 189,6 | 1,35 | 214,2 | 1,38 |
| 15 | Mean resistances value | 211,2 | - | 161,9 | - | 194,8 | - | 203,6 | - | 180,5 | - | 201,4 | - |
| 16 | Resistance stability | 11,5 % | - | 14,7 % | - | 10,2 % | - | 11,1 % | - | 12,6 % | - | 14,1 % | - |

* Value of the connectors resistance indicated for temperature 20 °C.

Thermal profile: I_N = 75 A, I_B = 31 A, t_{1-a} = 10 min, t_{1-b} = 11 min, t₂ = 10 min, I = 10 A.
SC test: I_{sc} = 218 A, t_{sc} = 1,0 s.

Table 6 – Maximum temperature and temperature stability of the connectors

| № | Cycle | Main conductor | Branch conductor | IPC №1 | | IPC №2 | | IPC №3 | | IPC №4 | | IPC №5 | | IPC №6 | | In circuit |
|----|-----------------|----------------|------------------|--------|-----------------|--------|-----------------|--------|-----------------|--------|-----------------|--------|-----------------|--------|-----------------|------------|
| | | T (°C) | T (°C) | T (°C) | Δθ _j | T (°C) | Δθ _j | T (°C) | Δθ _j | T (°C) | Δθ _j | T (°C) | Δθ _j | T (°C) | Δθ _j | T (°C) |
| 1 | 1 | 77,0 | 75,0 | 41,0 | - | 41,7 | - | 41,4 | - | 40,0 | - | 42,8 | - | 44,6 | - | 24,2 |
| 2 | 200 | 78,0 | 77,0 | 41,6 | 36,4 | 42,5 | 35,5 | 41,9 | 36,1 | 40,5 | 37,5 | 43,1 | 34,9 | 45,6 | 32,4 | 24,6 |
| 3 | 200 | 78,0 | 77,0 | 42,6 | 35,4 | 42,0 | 36,0 | 41,9 | 36,1 | 40,0 | 38,0 | 43,3 | 34,7 | 44,8 | 33,2 | 24,6 |
| 4 | 250 | 78,0 | 76,0 | 42,0 | 36,0 | 42,0 | 36,0 | 42,0 | 36,0 | 40,0 | 38,0 | 43,0 | 35,0 | 45,0 | 33,0 | 23,9 |
| 5 | 325 | 78,0 | 76,0 | 42,4 | 35,6 | 42,0 | 36,0 | 43,0 | 35,0 | 40,5 | 37,5 | 43,4 | 34,6 | 45,2 | 32,8 | 24,1 |
| 6 | 400 | 78,0 | 76,0 | 42,6 | 35,4 | 42,0 | 36,0 | 44,0 | 34,0 | 41,0 | 37,0 | 43,5 | 34,5 | 46,0 | 32,0 | 24,0 |
| 7 | 475 | 78,0 | 76,0 | 43,0 | 35,0 | 42,1 | 35,9 | 44,3 | 33,7 | 41,2 | 36,8 | 44,0 | 34,0 | 46,4 | 31,6 | 23,0 |
| 8 | 550 | 78,0 | 75,0 | 43,8 | 34,2 | 42,1 | 35,9 | 44,5 | 33,5 | 41,3 | 36,7 | 44,0 | 34,0 | 46,0 | 32,0 | 22,0 |
| 9 | 625 | 78,0 | 76,0 | 44,0 | 34,0 | 42,5 | 35,5 | 44,6 | 33,4 | 41,6 | 36,4 | 44,2 | 33,8 | 46,5 | 31,5 | 23,1 |
| 10 | 700 | 78,0 | 77,0 | 44,0 | 34,0 | 43,0 | 35,0 | 44,4 | 33,6 | 41,5 | 36,5 | 44,0 | 34,0 | 46,4 | 31,6 | 23,0 |
| 11 | 775 | 78,0 | 76,0 | 44,0 | 34,0 | 43,0 | 35,0 | 44,4 | 33,6 | 42,0 | 36,0 | 44,5 | 33,5 | 46,8 | 31,2 | 23,8 |
| 12 | 850 | 78,0 | 78,0 | 44,2 | 33,8 | 43,4 | 34,6 | 44,6 | 33,4 | 42,5 | 35,5 | 44,5 | 33,5 | 46,6 | 31,4 | 22,4 |
| 13 | 925 | 78,0 | 76,0 | 44,4 | 33,6 | 43,7 | 34,3 | 45,0 | 33,0 | 42,9 | 35,1 | 44,6 | 33,4 | 47,0 | 31,0 | 22,3 |
| 14 | 1000 | 78,0 | 76,0 | 45,0 | 33,0 | 44,0 | 34,0 | 45,0 | 33,0 | 43,0 | 35,0 | 44,5 | 33,5 | 47,2 | 30,8 | 22,8 |
| 15 | Max. value | 78,0 | 78,0 | 45,0 | - | 44,0 | - | 45,0 | - | 43,0 | - | 44,6 | - | 47,2 | - | 24,6 |
| 16 | Δθ _j | - | - | - | 34,4 | - | 35,3 | - | 33,8 | - | 36,4 | - | 34,0 | - | 31,7 | - |

Table 7 – Testing results

| № | Parameter | Result | | Accepted value |
|---|--|--------------------------|--------------------------|--|
| | | Circuit 1 (max – max) | Circuit 2 (min – min) | |
| 1 | Initial scatter δ | 0,170 | 0,111 | $\leq 0,3$ |
| 2 | Mean scatter β | 0,217 | 0,155 | $\leq 0,3$ |
| 3 | Assessment of resistance stability | Table 3 | Table 5 | $\leq 15 \%$ |
| 4 | Resistance factor ratio λ | Table 3 | Table 5 | $\leq 2,0$ |
| 5 | Temperature stability $\Delta\theta_j$ | Table 4 | Table 6 | $\overline{\Delta\theta_j} - 10 \quad \Delta\theta_j \quad \overline{\Delta\theta_j} + 10$ |
| 6 | Maximum temperature θ_j of each connector | Table 4 | Table 6 | θ_R |

5. Conclusion:

At the basis of comparison of the calculated parameters with maximum accessible parameters after 1000 cycles of heating-cooling all tested samples of IPCs PC 120-16 passed the test and satisfies requirements for class A in accordance with EN 50483-5:2009.

6. Pictures:




Fig.3 – IPCs in circuit with conductors' combination max – max during the testing

7. Test equipment:

| № | Type | Model | Latest calibration date |
|----|--|---|-------------------------|
| 1 | Ruler 1m | VaGo-Tools №003 | 05.04.2020 |
| 2 | Torque wrench | DT-030S2 №17000067 | 05.04.2020 |
| 3 | Stopwatch | COC np-26-2-010 №2284 | 24.04.2020 |
| 4 | Millivoltmeter | M2016 №7824 | 08.04.2020 |
| 5 | Voltmeter | M2007 №12341 | 08.04.2020 |
| 6 | Amperemeter | Ќ514 №45541 | 08.04.2020 |
| 7 | Heat chamber | ILKA №20200113 | Don't need calibration |
| 8 | Measurement and control device with resistive temperature transducer | PT-0102 №14-070 ТСП-0287 №14-352, №14-355 | 08.04.2020 |
| 9 | Source of current | РГ-53С-М2 №001 | Don't need calibration |
| 10 | Measurement and control device with resistive temperature transducer | PT-0102 №16-005 ТСП-0287 №№ 16-001, 16-002, 16-004, 16-005, 16-006, 16-007, 16-008, 16-009 | 07.04.2020 |
| 11 | Measurement and control device with resistive temperature transducer | PT-0102 №16-286 ТСП-0287 №14-027 | 08.04.2020 |
| 12 | Shunt | 75ШСМ0М3 №375802 | 27.09.2016 |
| 13 | Panel for electrical ageing test | ЛІЗО №002 | Don't need calibration |
| 14 | Source of current | РГ-53С №001 | Don't need calibration |
| 15 | Measurement and control device with resistive temperature transducer | PT-0102 №17-004 ТСП-0287 №№ 16-010, 16-011, 16-012, 16-013, 16-014, 16-016, 16-017, 16-018 | 06.04.2020 |
| 16 | Measurement and control device with resistive temperature transducer | PT-0102 №16-287 ТСП-0287 №14-025 | 08.04.2020p |
| 17 | Shunt | 75ШСМ №035109 | 04.01.2017 |
| 18 | Panel for electrical ageing test | ЛІЗО №001 | Don't need calibration |
| 19 | Source of current for short-circuit testing | ЛІЗО №001 | Don't need calibration |





The tests were performed by:

Deputy Head of the testing laboratory:

Engineer:

Engineer:

Engineer:

 S. S. Lakhovskyi
 O. O. Nepyivoda
 D. S. Denys
 A. S. Shevtsiv