



## Concise form of the test report No.: 1/01.02.19./PhM-08

### Information about laboratory

Name of testing laboratory	SIA Baltic Research Center
Date of issue of test report	01.02.2019.
Test report number	1/01.02.19./PhM-08
Laboratory contact name	Ingmārs Felcis
Signature, Head of Laboratory Ingmārs Felcis	Welm

<sup>-</sup> Note: By signing this form, the signatory is attesting that the information on the form is correct and the same as on the original, complete test report(s).

#### **Product information**

Manufacturer	SIA "VIZULO"		
Brand name	MICRO MARTIN ECO		
Model number	MRUE 035 740 L22 A008 CSN DG1		
Type of luminaire	Street luminaire		
Luminaire length	51.7	cm	
Luminaire width	17.0	cm	


#### **Electrical measurements**

# Goniophotometer output

Wattage	35	w
Current	0.157	Α
Voltage (AC)	230	V
Power factor	0.97	

#### **Photometric characteristics**

Total lumen output	4112.12	Lm
Luminaire efficiency	117.49	Lm/W
Correlated colour temperature CCT	4003	K
Colour rendering index CRI	72	



**BALTIC RESEARCH CENTER SIA** 

Ph: +371 26648433 www.brc-lab.com E-mail: office@brc-lab.com

Test Report No.: 1/01.02.19./PhM-08 Page 1 of 1 R3-01.02.2016.

The signatory also attests that all of the results on this form measured entirely in accordance with IES LM-79-08 and EN 13032:1 standards.