Specialists in High-Voltage Switching and Protection

6601 NORTH RIDGE BOULEVARD CHICAGO, ILLINOIS 60626-3997, USA TELEPHONE: (773) 338-1000 FAX: (773) 338-3657

Reference Number: CERT-94

Original Issue Date: September 13, 1996

Revision Date: July 12, 2002

### CERTIFIED TEST ABSTRACT

## Temperature-Rise

#### TYPE OF EQUIPMENT

S&C Fuse Cutout — Type XS — Outdoor Distribution — Extra-Heavy-Duty Overhead Pole-Top Style, Catalog No. 89071R11 and 89071R11-P

Nominal Voltage	14.4	kV
Maximum Voltage	15	kV
BIL	110	kV
Amperes Maximum		

#### APPLICABLE TEST SPECIFICATIONS

Test procedure in accordance with ANSI/IEEE C37.41-2000, IEEE Standard Design Tests for High-Voltage Fuses, Distribution Enclosed Single-Pole Air Switches, Fuse Disconnecting Switches, and Accessories, ANSI C37.42-1996, Distribution Cutouts and Fuse Links — Specifications and IEC 60282-2-1997, High Voltage Fuses — Part 2: Expulsion Fuses.

#### TEST RESULTS

S&C Test Reference Number: 9712

The device tested was Type XS Fuse Cutout, Catalog No. 89071R11. All of the devices listed under Type of Equipment utilize the same fuse tube and live parts, therefore, the temperature rise will be identical.

Reference Number: CERT-94

Original Issue Date: September 13, 1996

Revision Date: July 12, 2002

Refer to the following table, "Summary of Temperature-Rise Tests."

# Summary of Temperature-Rise Tests

	TEMPERA	TEMPERATURE-RISE (°C)		
THERMOCOUPLE LOCATION	MAXIMUM	MAX. PERMISSIBLE		
	DURING TEST	IEEE	IEC	
Upper parallel groove connector	18	40	65	
Conducting strip at connector	17	40	65	
Conducting strip at contact loop	18	40	65	
Contact loop at center	20	40	65	
Contact cup	23	40	65	
Fuse tube cap contact	25	40	65	
Fuse tube upper ferrule top	23	40	65	
Fuse tube upper ferrule body	22	40	65	
Right trunnion contact	27	40	65	
Left trunnion contact	27	40	65	
Right hinge - contact	25	40	65	
Left hinge - contact	25	40	65	
Right hinge at auxiliary contact spring	21	40	65	
Left hinge at auxiliary contact spring	21	40	65	
Right hinge at reduced section	20	40	65	
Left hinge at reduced section	21	40	65	
Conducting strip at hinge connector	20	40	65	
Hinge parallel groove connector	19	40	65	

Average ambient temperature: 24°C

Reference Number: CERT-94

Original Issue Date: September 13, 1996

Revision Date: July 12, 2002

STATE OF ILLINOIS )

)ss

COUNTY OF COOK

Mark W. Stavnes, being sworn, states that: He is Manager — Fuse Product Engineering — Fuse Products Division of S&C Electric Company and is authorized to execute this certificate on its behalf; and said tests were conducted in the manner above set forth, and the results are accurately reported above.

Subscribed and sworn to before me

this 12 day of

2002.

S&C ELECTRIC COMPANY

Affixed hereon s my Cook County,

Illinois Notary Public Seal

Mark W. Stavnes

Manager — Fuse Product Engineering

**Fuse Products Division** 

"OFFICIAL SEAL"

Margaret Lizak, Notary Public County of Cook, State of Illinois My Commission Expires 07-09-05